



Oneida County, NY

Chasing Wet Weather and Cost Savings All the Way to Compliance



Dan Davis and Diane Nascimento

January 27 | 2015




Outline

- Background
- Site Constraints
- Alternatives Considered
- What is Chemically Enhanced Primary Treatment (CEPT)
- What is High Rate Disinfection (HRD)
- Bench Testing Results
- Schedule




Project Background



- Oneida Regional WPCP:
 - 14 Towns/Villages (Sanitary Sewage)
 - City of Utica (Combined Sewage)
- Consent Order - SSO at Sauquoit Creek Pump Station (SCPS)
 - Consent Order in 2007 ; Compliance by 2021
- City of Utica - LTCP to mitigate CSO
 - Will result in increased wet weather flows to WPCP
- Industrial development

Oneida WPCP - Existing



Existing Flows

- SPDES permit requires:
 - Minimum capacity of 53 mgd during winter (November – May)
 - Minimum capacity of 48 mgd during summer (June – October)
- Current operating procedure is to limit peak flow to 53 mgd due to hydraulic restrictions


Projected Peak Flows

Flow source	Existing conditions (mgd)	Future conditions (mgd)
SCPS Basin	15	35
City of Utica	28	49
Other Basins	12	18
Microchip Plant and Spin-Offs	0	9
Total at WPCP	55	111


WPCP Expansion – Split Flow Concept

- Easy to separate combined and sanitary flows at the head of the plant (yard piping modifications)
- During wet weather, combined flows through one train; sanitary flows through another train
- Combined flows receive primary settling and disinfection to comply with EPA CSO regulations
- Sanitary flows receive secondary treatment
- **Capacity of secondary treatment system always maximized (65 mgd)**

Split Flow Concept – Dry Weather



Split Flow Concept – Wet Weather



Split Flow Concept


- Advantages:
 - Screening and grit removal for 100% of flows reaching the WPCP
 - Primary settling for all flows
 - Primary settling and disinfection for all CSO flow
 - Secondary treatment for all sanitary flow
 - Maximize capacity of secondary treatment system
 - Minimize amount of new tanks and equipment required
 - Lower cost than conventional plant expansion or other wet weather technologies
 - City of Utica and County in compliance with regulations and Consent Order

Split Flow Concept - Constraint

- PST Area Site Constraint
 - SOR with largest tanks > Ten State Standards SOR Criteria
 - CSO: Average SOR 1,052 gal/sf-d > 1,000 gal/sf-d
 - Sanitary: Peak SOR 2,296 gal/sf-d > 2,000 gal/sf-d
- PST Options
 - Conventional with Waiver from NYSDEC on SORs
 - Chemically Enhanced Primary Treatment for CSO flows


PST Layout Alt 1 - Conventional


- Maximum PST Size
- Hydraulic Loading Criteria above Ten State Standards
- Requested Waiver from NYSDEC
- Wet Weather - 2 Combined Sewer Tanks



PST Layout Alt 2 - CEPT

- Hydraulic Loading Criteria meets Ten State Standards
- Wet Weather - 1 Combined Sewer Tank with CEPT
- Wet Weather - 3 Sanitary Tanks






Chemically Enhanced Primary Treatment (CEPT)

Chemically Enhanced Primary Treatment (CEPT)

- Enhanced performance through chemical addition
 - Convert slow settling and colloidal solids into **rapidly settleable solids**
 - Allows for **much higher loading** than traditional primary treatment
- Two-step chemical addition process
 - Metal coagulant – neutralizes particle charge
 - Polymer flocculant – aggregates coagulated particles



Objective is to create a floc like...

This:



Flocculated primary influent



Not this:




Normal primary influent



High-Rate Disinfection (HRD)

High-Rate Disinfection (HRD)

- Bacteria reductions achieved at detention times less than conventional 15-30 minutes
- HRD detention time can be as low as **~ 5 minutes**
- High intensity, rapid mix for instantaneous chlorine dispersion
- Typically higher doses of disinfectant
- Develop dose-kill relationship






CEPT and HRD Projects



Chemically Enhanced Primary Treatment (CEPT)

- Where else is CEPT applied
 - **Cleveland, OH (+HRD)**
 - *Hartford, CT (+HRD)*
 - *Portland, OR*
 - *Seattle, WA*




NEORSD CEPT Facility Size Comparison

- Southerly PST No. 18 Demo
70 mgd
- Westerly CSTOF Tank A Demo
18 mgd
- Easterly Pilot
100 gpm




Southerly – Average TSS



Southerly – Pushing the limits, but not really




Pilot HRD Tank




Sodium Hypochlorite Induction Mixer



Southerly – Disinfection Performance



Southerly – Disinfection Performance





Oneida Bench Testing

Calendar of Events Captured

	2014											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Oneid a 6 events							●	● ● ●	●	●		


- Bench scale - Jar testing
- Storm variations
 - Range in storm types and influent conditions

Storms Sampled

- variability


Event	Date	Peak Intensity	Duration of Peak Intensity	Cumulative Rain Volume during Event
		[in./hr]	[min]	[in.]
Event 1	7/29/14	0.00	60	0
Event 2	8/3/14 - 8/4/14	0.45	60	1.03
Event 3	8/12/14-8/13/ 14	0.38	60	1.29
Event 4	8/21/14	0.05	60	0.18
Event 5	9/2/14	0.71	60	1.60
Event 6	10/15/14 - 10/16/14	0.86	60	3.25

Example storm chasing hydrograph




Why jar testing?

- Simulates coagulation & flocculation very well
- Used to find most effective coagulant and flocculant
- Diagnose performance issues ... on the fly





Jar Testing

- Influent wet weather characterization



Jar Testing – CEPT

Coagulant/Flocculent Dosage						
		Background	Jar 1	Jar 2	Jar 3	Jar 4
Jar Name:			FE 35/4818	FE 35/4818	FE 35/4818	FE 35/4818
			0.5	1.0	1.5	2.0
FeCl ₃ [mg/L FeCl ₃]:			35.00	35.00	35.00	35.00
Al ₂ (SO ₄) ₃ [mg/L Al ₂ (SO ₄) ₃]:						
Kemira 4818(-) [mg/L Neat]:			0.50	1.00	1.50	2.00
Post-Flocculation Settling		Turbidity [NTU]				
Mode	Time [min]	Background	Jar 1	Jar 2	Jar 3	Jar 4
Raw Sample:	0.0	263	263	263	263	263
Settling Time 1:	2.0		15	8	9	11
Settling Time 2:	5.0		9	4	7	8
Post-Rip Settling Time 1:	2.0		19	5	7	12
Post-Rip Settling Time 2:						



Jar Testing – CEPT

- Optimal coagulants and flocculants

Coagulant	Optimal Dose
Ferric Chloride, mg FeCl ₃ /L	35 – 40
Alum, mg Al ₂ SO ₄ /L	20 – 30
PAX XL 1900, ug PAX/L	10 – 12
DeIPAC 2020, ug/DeIPac/L	12 – 15




Flocculant	Optimal Dose , mg/L active
Nalco 7766/7768	2
Ashland 3040	1.5 – 2
Kemira 4818/4518	1 – 1.5

- No issues with Alkalinity or pH





Disinfection – Jar test

- Results for Primary Effluent



Disinfection – Jar test


- Results for CEPT



Disinfection – Jar test

- Conclusions

- CEPT – target dose 6 mg/L achieves 200 instantaneous
- PE – target dose 10 mg/L achieves 200 instantaneous
- Target 10 min contact time
- Work with the regulatory agency on ultimate requirements





Schedule

Schedule

- WPCP Expansion Design – complete by 2016
- WPCP Construction – complete by 2021 per Consent Order

Acknowledgements



Steven Devan, P.E.

Commissioner

Oneida County, New York

Department of Water Quality and Water Pollution
Control



Amy Mowers



Lauren Pepe, Colin O'Brien




Questions?

Bullpen



Split Flow Concept



Schedule

Project Component	2013				2014				2015				2016				2017				2018				2019				2020				2021			
	1	2	3	4	1	2	3	4	1	2	3	4	1	2	3	4	1	2	3	4	1	2	3	4	1	2	3	4	1	2	3	4	1	2	3	4
SCPS and Forcemain Design		█	█	█	█	█	█	█	█	█	█	█																								
SCPS and Forcemain Construction													█	█	█	█	█	█	█	█																
WPCP Solids Handling Design	█	█	█	█	█	█																														
WPCP Solids Handling Construction									█	█	█	█	█	█	█	█																				
WPCP Process Upgrades Design					█	█	█	█	█	█	█	█	█	█	█	█	█	█	█	█																
WPCP Process Upgrades Construction																					█	█	█	█	█	█	█	█	█	█	█	█	█	█	█	█