

# Fine Tuning Your BNR Removal System without the Use of an External Carbon Source



**Presentation by:**  
**John Gallegos**

**Authors:**  
**John Gallegos**

Date: January 28, 2015

**NEWEA**  
**2015 Annual Conference**

**CDM**  
**Smith®**

# Presentation Overview

- SRTTP Background
- Process Adjustments and Monitoring
- Operational Performance and Results
- Lessons Learned
- Questions

# SRTTP BACKGROUND

# Southern Regional Tertiary Treatment Plant (SRTTP)

- Sequencing Batch Reactor (SBR) and tertiary filtration treatment facility serving Marine Corps Base Camp Pendleton, CA
- Constructed in 2006
- 5 MGD capacity
- Plant expansion in 2013 increased capacity to 7.5 MGD





## SRTTP Operational Objectives

- ◆ Replace outdated Sewage Treatment Plants (STPs)
- ◆ Provide increased treatment capacity to the southern portion of MCB Camp Pendleton
- ◆ Comply with strict master reclamation permit requirements
- ◆ Maximize delivery of reclaimed water

# Marine Corps Base Camp Pendleton

**STP-3 (decommissioned)**


**STP-13 (decommissioned)**

**STP-1 (decommissioned)**

**SRTTP**

**STP-2 (decommissioned)**

# SRTTP Site Layout (5 MGD)



# SRTTP Operational Challenges

- Deal with varying influent wastewater quality
- Maximize reclaimed water delivery
- Meet stringent reclaim water requirements

<b>Constituent</b>	<b>Reclaimed Water (Max Day)</b>	<b>Ocean Outfall (Avg Mth/Max Day)</b>
BOD <sub>5</sub> (mg/L)	10	30/45
TSS (mg/L)	10	30/45
TN (mg/L)	5	----

# SRTTP Operation Challenges Cont'd

- Master Reclamation Permit (MRP) changed reclaimed water quality requirements
- 2004 plant design basis for 5 mg/L average monthly TN
- 2009 Master Reclamation Permit issued as 5 mg/L daily maximum TN limit plus many other WQ limitations (e.g., boron, chloride, manganese, TDS, etc.)
  - TN limit will be lowered to 4.1 mg/L daily max in 2014

## Excerpt from Master Reclamation Permit (MRP)

5. The recycled water discharged from SRTTP to the Irrigation Areas shall not contain TDS in excess of 1,200 mg/L as a 12-month average<sup>2</sup> or 1,300 mg/L as a daily maximum. From **March 12, 2014** on, recycled water discharged from SRTTP to the Front Gate/Recreation Fields shall not contain **TDS** in excess of **800 mg/L as a daily maximum**.
6. The recycled water discharged from SRTTP to the Irrigation Areas shall not contain total nitrogen (as N) in excess of 5.0 mg/L as a daily maximum. From **March 12, 2014** on, recycled water discharged from SRTTP to the Front Gate/Recreation Fields shall not contain **total nitrogen (as N)** in excess of **4.1 mg/L as a daily maximum**.



# SRTTP Operational Challenges Cont'd

- Impact of 5 mg/L TN instantaneous maximum
  - Reduced reclamation potential
    - Continuous online monitoring shuts down RWPS if ammonia + nitrate > 3 mg-N/L
  - Increased total nitrogen removal
    - Requires longer anoxic cycle for increased denitrification
      - Aerobic cycle time is reduced, oxygen demand increases, blower flow increases
    - Potential for filamentous growth increases
      - Additional basin put in service, operational costs increase (electricity, maintenance, chemicals, lab testing)
    - Reduced operational flexibility

# SBR Design Criteria and Current Operations

Parameter	2004 Design Criteria	Current Operations	2011 Design Criteria
Average influent flow (MGD)	5	2.1	7.5
Operating SBR basins	4	3	6
Total Cycle Time (min)	288	288	288
Aerated time per cycle (min)	124 (43%)	70 (24%)	88 (31%)
Anoxic time per cycle (min)	65 (23%)	103 (35%)	104 (36%)
Cycles per day per basin	5	5	5
MLSS @ AWL (mg/L)	4,700	2,400	4,700

# PROCESS ADJUSTMENTS & MONITORING

# Process Control Adjustment


- Analyze operational and laboratory data weekly (sent to process control team prior to weekly phone in meeting)
- Conduct weekly process control meetings with key CDM Smith staff
  - Plant Manager
  - Senior Operator
  - Project Manager
  - Process Control Engineers
  - Key Process Control Operators

# Process Monitoring

- Detailed process monitoring and operational adjustments made to meet the new, more stringent, TN limit of 5 mg/L max day
- Online instrumentation and control
  - DO monitoring in SBRs to fine-tune aeration control
  - Ammonia and nitrate monitors in SBRs
  - Ammonia and nitrate monitors on disk filter effluent
    - Set point of 3 mg/L ammonia + nitrate for reclaiming
    - Otherwise, effluent to ocean discharge

# SBR Cycle Adjustments

- 272 minutes per cycle (5 cycles per day)
- No supplemental carbon




**Nitrification:** ammonia → nitrate (needs air)  
**Denitrification:** nitrate → nitrogen gas (no air)


TN = NH<sub>3</sub> + NO<sub>3</sub>/NO<sub>2</sub>+ Organic Nitrogen  
 TKN = NH<sub>3</sub> + Organic Nitrogen

# SBR Cycles – 3 Basin Operation

*Red box indicates which basin is being filled*




# Optimal DO Profile





# Actual SBR DO Profile – May 2, 2011



## SBR Trend

CURRENT USER  
**kempj**

11:27:27 AM  
6/6/2011

General Solids/Chemica Headworks Primary/Secondary Tertiary Reclaimed TAPS Trends Actions  
Trend-Historical Thursday, June 02, 2011 - Friday, June 03, 2011

Non-Isolated Graph Isolated Graph

30 Min. Span 1 Hr. Span

4 Hr. Span 8 Hr. Span

12 Hr. Span 24 Hr. Span

Trend Properties Print Chart

Display All Pens

PEN 1  ON  OFF

PEN 2  ON  OFF

PEN 3  ON  OFF

PEN 4  ON  OFF


PEN 5  ON  OFF

PEN 6  ON  OFF

PEN 7  ON  OFF

PEN 8  ON  OFF

PEN 9  ON  OFF




Caption	11: 7:20 AM	Min	Max	Units
03-AIT-216: SBR No.1 Dissolved Oxygen	6/2/2011	0.0	0.0	12.0 mg/L

ALARM SUMMARY	Time	Description	User	Date	Time
ALARM RESET	6/6/2011 9:25:25 AM	Area_03\SBR_No2\YA-226	kempj	6/6/2011	9:30:53 AM
	6/6/2011 6:51:15 AM	Area_03\SBR_No2\YA-226	kempj	6/6/2011	6:51:23 AM
	6/4/2011 10:41:46 PM	Area_03\SBR_No2\YA-226	girae	6/5/2011	3:25:09 AM
	6/2/2011 10:25:23 AM	Area_03\Hi Lvl Alarm	girae	6/2/2011	10:25:42 AM

Failed to add item 'Grit\_Chamber\_High\_Level' to Data Server 'RNA://\$Global/Pendleton\_P002:CP\_SRTTP\_HMI' on machine 'WS2' (result = 0xc0040007). Clear Clear All




# SBR Trend 1/21/15



# Filter Effluent Ammonia & Nitrate – June 7, 2011

Trend-Historical Tuesday, June 07, 2011 - Wednesday, June 08, 2011

1:11:57 AM



Caption	11:20:49 AM	Min	Max	Units
04-AIT-290: Disk Filter Effluent Ammonia Residual	0.6	0.0	5.0	mg/L
04-AIT-291: Disk Filter Effluent Nitrate Residual	1.7	0.0	5.0	mg/L
04-AIT-292: Disk Filter Effluent Conductivity	1,542.7	0.0	500.0	mg/L
04-AIT-360: RWPS1 Ammonia	-1.3	0.0	5.0	mg/L
04-AIT-361: RWPS1 Nitrate	-7.5	0.0	5.0	mg/L
04-AIT-341: Chlorine Contact Basin pH	6.8	0.0	15.0	pH
04-AIT-342: Chlorine Contact Basin Conductivity	2,158.9	0.0	3,000.0	uS/cm
AIT 290 And 291 Moving Average	1.9	0.0	5.0	mg/L
04-AIT-290B-1: Disk Filter Effluent Ammonia (WTW)	0.2	0.0	10.0	ppm
04-AIT-290B-2: Disk Filter Effluent Nitrate (WTW)	1.2	0.0	5.0	ppm

# Process optimization

- Operators noted “dead” zones in SBR during aeration stage.
  - Possible poor DO readings
- DO profile of the basin
  - DO probe relocated to a more optimum location
- This led to the reduction of air and carry over of DO during denitrification stage
  - Overall reduction of nitrates by 1.5 mg/L



### Disk Filter Ammonia & Nitrate


CURRENT USER: **Guest**  
 2:18:51 PM  
 1/21/2015

- General
- Solids/Chemical
- Headworks
- Primary/Secondary
- Tertiary
- Reclaimed
- TAPS
- Trends
- Actions

Trend-Historical Tuesday, January 01, 2013 - Thursday, January 01, 2015

- Non-Isolated Graph
- Isolated Graph
- 30 Min. Span
- 1 Hr. Span
- 4 Hr. Span
- 8 Hr. Span
- 12 Hr. Span
- 24 Hr. Span
- Trend Properties
- Print Chart

- Display All Pens
- PEN 1  ON  OFF
  - PEN 2  ON  OFF
  - PEN 3  ON  OFF
  - PEN 4  ON  OFF
  - PEN 5  ON  OFF
  - PEN 6  ON  OFF



04-AIT-291: Disk Filter Effluent Nitrate Residual 2:16:50 PM 1.3 0.0 5.0 mg/L

**ALARM SUMMARY**  
 ALARM RESET

Time	Area	Alarm Description	Authority	Time	Area	Alarm Description	Authority
1/21/2015 1:28:02 PM	00\Alarms\AH-600	OOOPS Level Alarm High	NT AUTHORITY\SYSTEM	1/12/2015 2:46:38 PM			
1/12/2015 2:44:40 PM	Area_T1\Alarms\YA-P-121-B	PUMP NO. 2 LEAK ALARM (PMP-121)	JohnsonB	12/23/2014 12:43:22 PM			
12/23/2014 12:39:10 PM	Area_06\Meth_sys\FSL-297	METHANOL CONTAINMENT AREA EYEWASH FHummeIND	piersonm	10/7/2014 11:34:31 AM			
10/7/2014 11:14:33 AM	Area_03\Hi_Lvl_Alarm	High Level alarm is detected at one of the SBI piersonm	piersonm	10/7/2014 11:34:31 AM			
10/7/2014 11:14:33 AM	Area_03\PLC2_Alarm_Exist	Active Alarms Exist at SBR PLC (PLC2)	piersonm				



# Disk Filter Ammonia & Nitrate

CURRENT USER: Guest  
2:25:46 PM  
1/21/2015

- General
- Solids/Chemical
- Headworks
- Primary/Secondary
- Tertiary
- Reclaimed
- TAPS
- Trends
- Actions

Non-Isolated Graph | Isolated Graph

30 Min. Span | 1 Hr. Span

4 Hr. Span | 8 Hr. Span

12 Hr. Span | 24 Hr. Span

Trend Properties | Print Chart

Display All Pens

PEN 1  ON  OFF


PEN 2  ON  OFF

PEN 3  ON  OFF

PEN 4  ON  OFF

PEN 5  ON  OFF

PEN 6  ON  OFF



ALARM SUMMARY

ALARM RESET

Time	Area	Alarm Description	Operator	Time
1/21/2015 1:28:02 PM	00\Alarms\AH-600	OOOPS Level Alarm High	NT AUTHORITY\SYSTEM	
1/12/2015 2:44:40 PM	Area_T1\Alarms\YA-P-121-B	PUMP NO. 2 LEAK ALARM [PMP-121]	JohnsonB	1/12/2015 2:46:38 PM
12/23/2014 12:39:10 PM	Area_06\Meth_sys\FSL-297	METHANOL CONTAINMENT AREA EYEWASH FHummeIND		12/23/2014 12:43:22 PM
10/7/2014 11:14:33 AM	Area_03\Hi_Lvl_Alarm	High Level alarm is detected at one of the SBI piersonm		10/7/2014 11:34:31 AM
10/7/2014 11:14:33 AM	Area_03\PLC2_Alarm_Exist	Active Alarms Exist at SBR PLC [PLC2]	piersonm	10/7/2014 11:34:31 AM

# OPERATIONAL PERFORMANCE & RESULTS


# 2014 Average SBR Operating Conditions

- Influent flow
  - Design flow = 5 MGD (average), 15 MGD (peak)
  - Current flow = 2.1 MGD
- Influent Concentrations
  - BOD = 202 mg/L, TSS = 189 mg/L
  - TKN = 53 mg/L, NH<sub>3</sub> = 37 mg/L, NO<sub>3</sub> = 0.1 mg/L
- Reclaimed Concentrations
  - BOD = 3 mg/L, TSS = 3 mg/L
  - TN = 1.5 mg/L, TKN = 0.5 mg/L, NH<sub>3</sub> = 0.05 mg/L, NO<sub>3</sub> = 1.0 mg/L
- Aerobic SRT = 10 days (all SBR's)
- MLSS = 2000 mg/L (all SBR's)
- SVI = 156 (all SBR's)







# Oceanside Outfall TN 1/13 thru 12/15



# Reclaimed Water TN 2/12 thru 1/13



# Reclaimed Water TN 1/13 Thru 1/15



# LESSONS LEARNED

# Process Control Lessons Learned

- Factors contributing to meeting 5 mg/L instantaneous total nitrogen limit
  - Detailed review of existing plant data
  - Review placement of in process analyzers
  - Operational adjustments
    - One adjustment at a time
    - Typical 'rule of thumb' that each adjustment is less than 10% of previous number
    - Wait after each adjustment to observe effect
  - Close monitoring of plant processes for continued performance
  - Perform weekly process control meetings with staff, communications!

# Operational Lessons Learned

- Conduct and assess staffing needs
- Audit laboratory equipment
- Audit and purchase process equipment
- Develop in depth round sheets (these are teaching aids, what should the operator expect?)
- Assign coverage areas (if not assigned, no one is responsible!)
- Daily check off sheet (If all else fails make sure this is accomplished...)
- Develop SOP's and MOPO's
- Implement laboratory analysis schedule

# QUESTIONS