

Secondary Effluent Reuse Mattabassett District WPCF

Presented by:

Brian W. Armet, PE

Executive Director – Mattabassett District

Christine E. Kurtz, PE

Project Manager – Wright-Pierce

Presentation Overview

- ✓ History of Mattabassett District
- ✓ History of water reuse proposals
- ✓ Planned comprehensive upgrade
- ✓ Accommodations for water reuse
 - ✓ Design considerations
 - ✓ Ownership considerations
 - ✓ Contractual relationships
- ✓ Ultimate design
- ✓ Questions/Answers



The Mattabassett District

Mattabassett Trunk Sewer

New Britain

Cromwell

Berlin

Middletown



The Mattabassett District Water Reuse History

New Britain

Cromwell

Berlin

Middletown



**NRG Energy
2009**



aso



**Pistol Creek Golf
Course 2010**



**Klean Energy
2006/2007**

District Comprehensive Upgrade

Wastewater Treatment



- Planned \$100 M upgrade
- Accommodate Middletown
 - Increase avg. flow to 35 MGD
 - Peak flows to 110 MGD
- Upgrade for nitrogen removal
 - Required effluent pump station
 - Needed at high river levels



District Comprehensive Upgrade Design


NRG Energy

- Met with NRG during design
- Demand for cooling water
 - 2.3 MGD average
 - 3.65 MGD peak flow
- 2,500 gpm pumps
- Turndown to 1,250 gpm min.
- Disinfection



Accommodations for Water Reuse

Pump Design & Control



- Sufficient submergence at WPCF low flows
- Control signal between power plant & WPCF
 - radio
 - fiber
- Turndown
- Redundancy
- Future increased capacity



Accommodations for Water Reuse

Pump Station Design Considerations



- Power plant construction vs. WPCF upgrade
 - Initial power plant was first
- Designed pump station with space for future reuse pumps
 - flow-through wet well design
 - ◆ water always available
 - Power consumption provided by power plant engineers
 - Standby power considerations



Accommodations for Water Reuse

Disinfection



- Effluent pump station ahead of chlorination point
- Seasonal disinfection
- Power plant requires year-round disinfection
- Chlorine residual control feedback
- Potential for UV disinfection for treated effluent



Accommodations for Water Reuse

O&M Costs



- Ownership of pumps
 - District vs. Power Company
- Operational costs
 - Power, chemical disinfection
- Maintenance costs
- Cost for water
 - Unit cost to accommodate all O&M costs?




Secondary Effluent Pump Station Design

SEPS

- Designed for District's needs
- Designed to accommodate future cooling water pumps
- Flow-through wet well design to ensure pump suction submergence
- 24-inch force main to property line
- Provisions for chlorination



Secondary Effluent Pump Station Design




District Effluent Pumps

Space to accommodate up to four 200-hp reuse water pumps in future



Secondary Effluent Pump Station Design



Space to accommodate up to four 200-hp reuse water pumps in future



Secondary Effluent Pump Station Design

Secondary Effluent Pump Station

24-inch Force Main for future reuse

Questions & Discussion



Thank you!