





Bowery Bay WWTP Master Facility Plan

NEWEA 2016 Annual Conference & Exhibit January 27, 2016

Agenda

Purpose & Background

Facility Benchmarking

Summary of Recent Work

State of Good Repair Needs

Regulatory and Programmatic Drivers

Optimization Evaluations

Emerging Technology

Summary



Regulatory requirements

State of good repair needs (SOGR)

- Plant optimization
- Flood resiliency

Objectives consistent with PlaNYC



Commissioned in 1939

5th largest of NYC's 14 WWTPs – 150 MGD DDWF

Serves ~850,000 residents in 23.8 mi² combined sewer drainage area

Part of NYC BNR program





KEY OBJECTIVES:

Review major expense and operating data

Compare Bowery Bay WWTP with other DEP WWTPs



				MAJOR EXPENSE CATEGORIES								
	Design Capacity	TOTAL EXPEN		Other Than	Personnel	Energy &	Energy & Chemicals		y & Solids	Chemicals & Solids		
WWTP	(MGD)	Rank	\$/MG	Rank	\$/MG	Rank	\$/MG	Rank	\$/MG	Rank	\$/MG	
NC	310	1	\$470	6	\$309	7	\$235	7	\$273	2	\$111	
BB	150	2	\$485	1	\$265	1	\$173	2	\$230	4	\$126	
WI	275	3	\$501	7	\$312	5	\$221	6	\$242	9	\$162	
ОН	120	4	\$506	5	\$302	4	\$212	1	\$226	10	\$166	
CI	110	5	\$523	2	\$281	2	\$188	4	\$238	5	\$136	
HP	200	6	\$524	3	\$291	6	\$223	3	\$237	3	\$123	
JA	100	7	\$532	4	\$297	3	\$204	5	\$240	8	\$151	
NR	170	8	\$662	11	\$404	11	\$314	10	\$321	12	\$173	
ТІ	80	9	\$704	8	\$348	8	\$250	9	\$307	7	\$138	
RH	60	10	\$881	9	\$351	9	\$265	8	\$300	6	\$138	
PR	60	11	\$894	10	\$401	10	\$306	11	\$329	11	\$167	
OB	40	12	\$1,041	13	\$492	12	\$366	13	\$433	13	\$187	
26	85	13	\$1,171	14	\$633	14	\$431	14	\$495	14	\$340	
RK	45	14	\$1,242	12	\$434	13	\$397	12	\$404	1	\$67	
Range	40-310	\$470	- \$1,242	\$264 -	\$633	\$173	- \$431	\$22	6 - \$495	\$67	- \$340	
Flow-Wei	ghted Average		\$591		\$333		\$242		\$274		\$149	
Bowery E	Зау		\$485		\$264		\$173		\$230		\$126	
Difference	Э		\$106		\$69		\$69		\$44		\$23	
% of Diff	erence		100%		65%		65%		41%		22%	



Second lowest operating cost:

- Primary treatment and gravity thickening performance
- Substantial aeration upgrades and automated DO control
- High-level interceptor low static lift
- Disinfection efficiency (hypo usage, TRC)
- Ferric chloride and polymer usage efficiency
- Observations could help drive future upgrades/ design features
- Insight into potential savings at other DEP WWTPs



Potential Annual Savings in Chemical Costs Using 2013 Bowery Bay WWTP Chemical Usage as Benchmark



- Ferric usage based on 40 lbs ferric / ton dry solids entering dewatering (dewatering plants only)
- Hypo savings based on BB gallons hypo / MG treated ~ 10 gal/MGD
- Polymer savings based on 28 lbs active polymer / ton dry solids entering dewatering
- * During benchmarking analysis, it was noted that 26th Ward WWTP is significantly under dosing ferric at about 25% of recommended dose

KEY OBJECTIVES:

Summarize major upgrades and capital investments

Review key findings from recent studies which may impact plant reliability or efficiency

Correlate findings to inform recommendations for future projects



WATER DEMAND MANAGEMENT PLAN





Mangamery Watan Engineer. of New York, P.C./Bares and Sonyer, P.C. A Food Vinture In American Web Monail and Edity of New York, Inc.

Hazen



2013 Advisory 100-Year Floodplain Projected 2020s 100-Year Floodplain Projected 2020s 100-Year Floodplain

Standard Operating Procedure on City and Effluent Water Use

- 1. Meters City Mater
- Recent water consumption on a weakly basis and compare to Automated Mater Recentry in logging onto "We DEP Account", if there are discrepancies or if the methylic appear to be mail/accidoring, cardiact John Section, Chief, Deergy Analysis & Recentag Boston.
 Leaks – City Water
- Lenns City Water

 Investigate induces or submit Work Request to Engineering
 Efficient Water Intainer Rystem
- Clean strainer backet once per day.
 Faydem is mafunctioning, most leaks in-house or submit Work Request to
- the efficient water pumps in accordance with the developed plans and schedules and larep an inventory of spares. 4. Pump Packing - Use of Mechanical Seals
- a. Peop Prockets One of mechanical treas Mechanical saids are only too suid on MIPs and efficient water pumps. They are only to be used in these type pumps if the application mesh all applicable manufactures is oriented. This applies to new pump pumbers and when transitioning from traditional packing to mechanical scale.
- 5. Use of Effuent Water' instead of City Water • Use effuent subs instead of city water in the applications listed below
- If an application could be sensitive to the use of effuent water instead of city water, contact the Energy Analysis & Planning Section for further evaluation.







NYC WASTEWATER RESILIENCY PLAN CLIMATE RISK ASSESSMENT AND ADAPTATION STUDY DECUTIVE SLAMARY









2013 Advisory 100-Year Floodplain Projected 2020s 100-Year Floodplain Projected 2050s 100-Year Floodplain Source: FEMA; CUNY Institute for Sustainable Cities

KEY OBJECTIVES:

Review asset assessment and risk scoring framework

Summarize 2009 and 2014 results

Develop candidate list of SOGR projects

Identify synergies with storm surge resiliency needs

Correlate findings with previous chapter to inform future capital projects



Asset condition assessment and risk scoring framework





KEY OBJECTIVES:

Determine impact of near-term and long-term regulations (speculation)

Assess programmatic drivers for more efficient processes

Determine buildable envelope

Including utilizing land in surrounding area

Code review of existing buildings

Determine regulatory and programmatic triggers

Technology		Limit of Te			
Iecnn	ology	mg/L	Limit Type		
Full-Step BNR w/ Carbon	2017	9-9.5	8,500	TMDL trigger limit	
	2040	9-9.5	10,000	TMDL trigger limit	
Battery E Effluent TN		6.5	7,000	Assumed numerical limit trigger	
Battery E w/ DN Filter or MBBR/DAF		3.5	3,500	Assumed numerical limit trigger	

Regulated Effluent	Current Limit	Proposed Limit	Compliance Alternatives	Next Steps
TRC	2.0 mg/L	0.19 mg/L	Chlor/dechlor UV disinfection Ozonation	Continue Integrated Planning Studies
Enterococcus	n/a	130 CFU/100 mL daily 35 CFU/100 mL monthly	Increased chlorination UV disinfection Ozonation	Continue Integrated Planning Studies
Cyanide	75 lb/d	13 lb/d	Application of water effect ratio to increase limit by a factor of 2.7	Collaboration and approval from DEC



Regulated Effluent	Current Limit	Compliance Alternatives
Class A or B Biosolids	n/a	PSRP or PFRP processes
Superfund	n/a	Increased CSO controls
Nitrous Oxide	n/a	Alternative SCT processes
Trace Organics	n/a	Filtration, activated carbon, and/or AOP
Phosphorus	n/a	Biological, Physical Chemical, Removals/Nutrient Recovery

RKERS ISLAND CHANNEL 12+00 N 12+00 N LIFT STATION USSTATION C (1533) - DILDRNE BUILDING 11+00 N 11+00 N RIDE & WEC ROOM (1545 NORTH C SOLT NORT 10+00 N TRL WALTY **CONTRO** LEGEND STUN BLDG & UNT SUBSTATION E (1535) ATRATION 30100 Regulatory or 9+00 N Capital Anticipated TANKS Symbol **Process Area** Programmatic 14445 [30:10:10] Project Term Trigger TANKS 8+00 N Battery E Aeration, Effluent TN Limit < Level of Mid UBSTATION & CISST Final Setting 6.2 mg/L Treatment BLDG 4 7+00 N (1548) Effluent TN Limit < MBBR and Tertiary 4.5 mg/L; reduced Long DAF Treatment DAF effluent NH₃ limit 6+00 N MBBR. OR1 Inclusion of RUDING coliphage as UV Disinfection indicator Long 5+00 N Disinfection organism; trouble Δ SCRVICE 340 meeting TRC limit BOUTH I RUTURE RESOLALS -RIDG 7 MOD ROOM (1858) - DVBON 4+00 N Gravity Belt Solids Handling PROMINEY Thickeners Class B biosolids Mid and ADDATION SCITLAG (GBT) Dewatering 271.00 TANKS. 3+00 N ELECTRICA WING TRN#5 (1 10 9) Power Implementation of Distribution and Main GBTs and/or UV Mid-Long W. Sow FUEL PAG Substation Emergency disinfection 2+00 N Generation BUDDE BURDING WORK AREA (THP) sis. BUE DIVO 1+00 N 14:00 N PLANT SUB-STATION GUARD SCHEM SOLLINGS 0+00 0+00 8 8 1ž 8 - DALKGONCY GENERATOR - DISTING HIGH LİLVEL INTERCEPTOR DISTING LOW LEVEL

Bowery Bay WWTP Long-Term Site Plan (in Response to Regulatory and Programmatic Drivers)

Optimization Evaluations

Optimization Evaluations

KEY OBJECTIVES:

Identify opportunities to improve performance or efficiency

Evaluate using process and energy modeling

Select optimization concepts that are sufficiently beneficial to implement

Optimization Evaluations

Relocate BB sludge to WI for dewatering

Sidestream treatment with ANAMMOX processes

- Ammonia-based DO control
- Incorporate baffle walls in final settling tanks
- Gravity belt thickeners (GBTs) for WAS thickening
- Chemically enhanced primary treatment (CEPT)
- Sidestream returns

Hydraulic balancing of flow (hydraulic model development)

Optimization Evaluations (Courtesy BWT)

Spare centrifuge capacity at WI

• 2016: from 2.3 MGD to 4.3 MGD¹

BB sludge flow: 0.53 MGD²

Opportunity for cost savings

Notes:

1. 12 out of 16 centrifuges in operation at WI for a 4.3 MGD hydraulic treatment capacity.
 2. 0.53 MGD based on data from 7/1/2012 to 4/30/2013.

Proposed:

- Shutdown BB dewatering
- Transship sludge to WI WWTP
- Consider advanced treatment for centrate

Analysis:

- 1. Impact on BNR and TMDL OK
- 2. Chemical usage **REDUCED**
- 3. Dewatering capacity at WI SUFFICIENT
- 4. Sludge Storage Capacity at WI and BB SUFFICIENT
- 5. Sludge Marine Vessel availability– SUFFICIENT (SOME SCENARIOS)
- 6. ANITA-Mox Requirements OVERALL SAVINGS



Optimization Evaluations (Courtesy BWT)

BB dewatering shut down + sludge/centrate to WI with ANITA-Mox:

Item	Capital	O&M
Barge (fuel & crew)	\$0	(\$1.2 M)
Energy for dewatering (elect, fuel oil, gas)	\$0	\$0.3 M
Energy for new ANITA-Mox pumps/mixer	\$0	(\$0.1)
Chemicals (polymer, glycerol, alkalinity)	\$0	\$4.7 M
Maintenance of BB dewatering Facility	\$0	\$0.3 M
Energy for Aeration	\$0	\$0.3
Planned Capital investments and Repair	\$24.5 M	\$0 M
Resiliency	\$4.0 M	\$0.08 M
ANITA-Mox Facilities	(\$21 M)	\$0 M
Subtotal Savings	\$7.5 M	\$4.4 M

Annualized Projected Savings (over 20 years)* = \$3.7 million per year

*Note: For 20-Year NPV Cost Analysis use 3% interest rate

Emerging Technology

Emerging Technology

KEY OBJECTIVES:

Summarize the key emerging and innovative technologies applicable to the Bowery Bay WWTP

Provide insights into creating a resource recovery facility of the future at the Bowery Bay WWTP



Emerging Technology

Nitrogen

Mainstream Nitritation and Denitritation

Mainstream deammonification

Aerobic granular sludge

Disinfection

UV (Disinfection)

 $UV-H_2O_2$ (AOP)

Ozonation (AOP)

Biological activated carbon

Resource Recovery

Nutrient Recovery - Struvite harvesting

Energy Recovery – Boilers

Energy Recovery - Internal Combustion Engine

Energy Recovery- Combustion gas turbine/ Microturbine

Wet Weather

DensaDeg[™] (Ballasted flocculation)

Actiflo[™] (Ballasted flocculation)

CoMag[™] (Ballasted flocculation)

Microscreens

Class A/B Biosolids

Co-digestion of high-strength, organic wastes

Enhanced municipal solids lysis - Thermal hydrolysis

Enhanced municipal solids lysis – Chemical, mechanical, electrical WAS lysis

Emerging Technology



New York City Plant of the Future

Moving forward, it is recommended that a conceptual level planning estimate and business case evaluations be performed to help prioritize which of these emerging technologies are suited for application at Bowery Bay.

Drivers for Emerging Technology Upgrades

- Chemically Enhanced Primary Treatment to meet future wet weather capacity.
- Mainstream Deammonification/SND to meet lower TN limits and reduce energy & chemical costs (OneNYC).
- 3) UV AOP to remove CECs and inactivate coliphage.
- WAS Mechanical Thickening to reduce sludge production and increase digester capacity to produce Class B biosolids.
- Enhanced WAS Lysis to reduce sludge production and increase biogas/energy production and help meet OneNYC goals
- Co-digestion of source separated organic waste to increase biogas/energy and help meet OneNYC goals.
- CHP use of high efficiency, low emissions engines to help attain energy neutral operations and meet OneNYC goals.
- Struvite Recovery to reduce O&M costs related to nuisance struvite control/removal and help meet OneNYC goals.
- SCT Deammonification reduce energy and chemicals costs of current SCT and help meet OneNYC goals.(* Not included at plants without dewatering).



KEY OBJECTIVES:

Summarize and synthesize the insights

- Provide a list of needs to assist NYCDEP decision makers
- Present order-of-magnitude capital costs



	Completed and Ongoing		Completed and Ongoing Existing Plan			Recommended Plan								
Process Area	Prior 10 Years Compilted Investments (SM)	Active Work (Orgoing) (SM)	Total Completed and Ongoing (SIM)	Existing 10-yr CIP (SM)	Backtogged Work Orders (SM)	Total Existing 10-yt CIP and Backlogged Work Orders (SM)	Shot Term (2015 - 2020) (SW)	In collection of the UT	Mid-Term (2020 - 2025) (SMI)	in animatic of kit s.c.	Total Revised 10- yr CIP (SM)	Long-Term (2025 - 2040) (549)	In continuents (FLE) / E	Total Revised 25-yr CIP (SM)
Aeration	\$239 M	\$15 M	\$254 M	S0 M	\$0.2 M	\$0.2 M	(1) Process air improvements for leaking pping and I&C error	\$0.2 M	(1) Replace membrane diffusers (further study needed; resulting in seported energy savings of \$0.25 Miyr (1.3% of annual expense total (FY13))	\$6.5 M	\$6.9 M	 Ammonia-based DO control (O&M savings of So.06 M/yr (0.3% of annual expense total (Fri12()) MBBR and DAF 	\$102 M	\$109 M
Main Building	\$116 M	\$0.1 M	\$116 M	\$3.9 M	\$0.2 M	\$4.1 M	 Storm surge resilency needs. Work orders for broken windows, and egress and monitoring improvements. 	\$1.8 M	(1) Lab and door repairs (2) Defer 88-226 (Pump and Blower Building) to teng-term.	\$0.03 M	\$2.0 M	(1) BB-226 (Pump and Blower Building)	\$3.94 M	\$5.9 M
Sludge Handling and Dewatering	\$64 M	\$13 M	\$77 M	\$30 M	\$30 M	\$60 M	11) Ort Big stam surge realiancy needs (2) SOOR needs to year value pumps, basement condensate system; and HVAC repairs (3) Decommession Desatining Statistical Statistics (3) Big (45% of amulai operametistic (713)) (4) Decommission Devalency Statisty one Will and HP anothogue oppositions and statisty on every, internasi, SWV, and personnel Sanistiga in every, internasi, SWV, and personnel Sanistiga in terry, internasi, SWV, and personnel Sanistiga in terry.	\$2 M	(1) Implement GBTs under BB-218, resulting in SMV swinigs of 50.48 Myr (2.1% of annual express total (7/13) (2) Eliminate BB-223	\$30 M - \$3 M	\$89 M	 Scietbaam refam monitoring. CHP (further study neodod) (O&M savings of 82.2 Mpr; (11.3% of annual expense total (*17.3)); (3) Phosphorus recovery. Codgening of high-strength waste (further study, neodod; (3) Enhanced WAS lyss. 	\$174 M	\$263 M
Power Distribution and Emergency Generation	\$46 M	\$0.0 M	\$46 M	\$65 M	\$0.1 M	\$65 M	(1) Born surge resiliency needs. (3) Vanous electrical improvements (MCC 1554A, USB 1534, Datlery vanager für 1530 DC System) (3) Generatur ansa region (4) Acquire lando in dead and potion of Barrien Bird to accommodate Subure electrical work.	\$7.5 M	(1) Defer 86-220 E-gen work to long-term and contine with potential substitute work due to future regulatory drivers	- \$30 M	\$43 M	(1) 80-220 (2) Solar panells (3) New main substation	\$67 M	\$110 M
Plant Facilities	\$39 M	\$1.2 M	\$40 M	\$5.7 M	\$0.8 M	\$6.5 M	(†) Storm surge mellenny needs (†) Service and Adrin Stidy improvements (†) Sea wall and stock voch states (†) Meo geheres and MVAC work orders (†) Weo eite upgrades	\$38.3 M	(1) Defer 86-221 for exterior lighting to long-term (2) Remaining PVr5 capital investment for 88-205 (50.7 M) considered completed	- \$5.7 M	\$39 M	(1) 88-221	\$5 M	\$44 M
Final Settling	\$30 M	\$0.6 M	\$31 M	\$5.9 M	\$0.9 M	\$6.8 M	(1) FST gates and scum and WAS pumps (2) Weens in aerator effuent channel	\$1.1 M			\$7.9 M	(1) PST baffle improvements (additional O&M of \$0.05 Myr (0.3% of annual expense total (FY13))	\$3.8 M	\$12 M
Headworks	\$29 M	\$50 M	\$79 M	\$59 M	\$0.5 M	\$60 M	 Borth surge realiency needs MSP trolley and HVAC repairs Scienti and series 	\$2.1 M	(1) Remaining FY15 capital investment for BB-209 (50.6 W) considered completed	- \$0.6 M	\$61 M			\$61 M
Primary Treatment	\$25 M	\$0.0 M	\$25 M	\$20 M	\$1.4 M	\$21 M	(1) PST needs (2) Secondary bypass upgrade	\$1.8 M			\$23 M	(1) Woroscreen filters for increased capacity	\$41 M	\$64 M
Disinfection	\$0 M	\$0 M	\$0 M	\$0 M	\$0.1 M	\$0.1 M	(1) Storm surge resiliency needs (2) Outfall inspection and regain (3) OCT deviatering system	\$0.5 M	(1) Chlor / Dechlor improvements	\$18 M	\$19 M	 UV devretection (provisions for AOP) Increased wet-weather capacity (further study needed) 	\$150 M	\$169 M
Total	\$587 M	\$80 M	\$667 M	\$190 M	\$34 M	\$224 M	\$55.3 M	\$55.3 M		\$11.3 M \$29		\$547 M		\$838 M

Acknowledgments

DEP-BWT

Jim Mueller Anthony Maracic Mike Kalliangas Frank Kulscar Enam Haque Hazen and Sawyer Paul Saurer Ben Levin Anni Luck Tom McEnerney **Rob Sharp Bob Frost** Sarah Galst Ron Latimer Paul Pitt Wendell Khunjar









Enterococcus

	BAV - daily average	BAV - monthly average
Federal Standard	110-130 CFU/100 mL	N/A
Anticipated Bowery Bay Limit	~130 CFU/100 mL	35 CFU/100 mL

*BAV = Beach Action Value

Couple with TRC: dechlor or UV/ozone

Optimization Evaluations

HEET Model:



Optimization Evaluations





















2. 20	Completed and Ongoing				
Dranage Area	Prior 10 Years Completed Investments (\$M)	Active Work (Ongoing) (\$M)	Total Completed and Ongoing (\$M)		
Process Area	A	В	C=A+B		
Aeration	\$239 M	\$15 M	\$254 M		
Main Building	\$116 M	\$0.1 M	\$116 M		
Sludge Handling and Dewatering	\$64 M	\$13 M	\$77 M		
Power Distribution and Emergency Generation	\$46 M	\$0.0 M	\$46 M		
Plant Facilities	\$39 M	\$1.2 M	\$40 M		
Final Settling	\$30 M	\$0.6 M	\$31 M		
Headworks	\$29 M	\$50 M	\$79 M		
Primary Treatment	\$25 M	\$0.0 M	\$25 M		
Disinfection	\$0 M	\$0 M	\$0 M		
Total	\$587 M	\$80 M	\$667 M		

	Existing Plan						
	Existing 10-yr CIP (\$M)	Backlogged Work Orders (\$M)	Total Existing 10-yr CIP and Backlogged Work Orders (\$M)				
Process Area	D	E	F=D+E				
Aeration	\$0 M	\$0.2 M	\$0.2 M				
Main Building	\$3.9 M	\$0.2 M	\$4.1 M				
Sludge Handling and Dewatering	\$30 M	\$30 M	\$60 M				
Power Distribution and Emergency Generation	\$65 M	\$0.1 M	\$65 M				
Plant Facilities	\$5.7 M	\$0.8 M	\$6.5 M				
Final Settling	\$5.9 M	\$0.9 M	\$6.8 M				
Headworks	\$59 M	\$0.5 M	\$60 M				
Primary Treatment	\$20 M	\$1.4 M	\$21 M				
Disinfection	\$0 M	\$0.1 M	\$0.1 M				
Total	\$190 M	\$34 M	\$224 M				

	Recommended Plan										
	Short-Term (2015 - 2020) (SM)		Mid-Term (2020 - 2025) (\$M)		Total Revised 10- yr CIP (SM)	Long-Term (2025 - 2040)		Total Revised			
Process Area	Description of Investments	Investments (\$M) (G)	Description of Investments	Investments (SM) (H)	I=F+G+H	Description of Investments	Investments (SM) (J)	K=I+J			
Aeration	(1) Process air improvements for leaking piping and I&C error	\$0.2 M	(1) Replace membrane diffusers (further study needed), resulting in expected energy savings of \$0.25 Miyr (1.3% of annual expense total (FY13))	\$6.5 M	\$6.9 M	(1) Ammonia-based DO control (O&M savings of S0.06 M/yr (0.3% of annual expense total (FY13))) (2) MBBR and DAF	\$77 M	\$8.9 M			
Main Building	 Storm surge resiliency needs Work orders for broken windows, and egress and monitoring improvements 	\$1.8 M	(1) Lab and door repairs (2) Defer BB-226 (Pump and Blower Building) to long-term	\$0.03 M - \$3.9 M	\$2.0 M	(1) BB-226 (Pump and Blower Building)	\$3.94 M	\$5.9 M			
Sludge Handling and Dewatering	(1) Grit Bidg storm surge resiliency needs (2) SOGR needs for seal water pumps, basement condensate system, and HVAC repairs (3) Decommission Dewatering Bidg (0&M savings of S.9 Myr (4.6% of annual expense total (FY13))) (4) Decommission Dewatering facility once WI and HP centrifuge upgrades complete, resulting in energy, chemical, SMV, and personnel savings of \$0.9 Myr (4.6% of annual expense total (FY13))	\$2 M	(1) Implement GBTs under BB-218, resulting in SMV savings of \$0.45 Miyr (2.1% of annual expense total (FY13)) (2) Eliminate BB-223	\$30 M - \$3 M	\$89 M	(1) Sidestream return monitoring (2) CHP (further study needed) (O&M savings of \$2.2 Miyr (11.3% of annual expense total (FY13))) (3) Phosphorus recovery (4) Codigesting of high-strength waste (further study needed) (5) Enhanced WAS lysis	\$174 M	\$263 M			
Power Distribution and Emergency Generation	 Storm surge resiliency needs Various electrical improvements (MCC 1554A, USS 1534, battery charger for 130V DC system) Generator area repairs Acquire land on dead end portion of Berrien Bivd to accommodate future electrical work 	\$7.5 M	(1) Defer BB-220 E-gen work to long-term and combine with potential substation work due to future regulatory drivers	- \$30 M	\$43 M	(1) BB-220 (2) Solar panels (3) New main substation	\$67 M	\$110 M			
Plant Facilities	(1) Storm surge resiliency needs (2) Service and Admin Bidg improvements (3) Sea wall and dock work orders (4) Misc galleries and HVAC work orders (5) Misc site upgrades	\$38.3 M	(1) Defer BB-221 for exterior lighting to long-term (2) Remaining FY15 capital investment for BB- 205 (\$0.7 M) considered completed	- \$5.7 M	\$39 M	(1) 88-221	\$5 M	\$44 M			
Final Settling	(1) FST gates and scum and WAS pumps (2) Mixers in aerator effluent channel	\$1.1 M			\$7.9 M	(1) FST baffle improvements (additional O&M of \$0.05 M/yr (0.3% of annual expense total (FY13)))	\$3.8 M	\$12 M			
Headworks	(1) Storm surge resiliency needs (2) MSP trolley and HVAC repairs (3) Screen area needs	\$2.1 M	(1) Remaining FY15 capital investment for BB- 209 (\$0.6 M) considered completed	- \$0.6 M	\$61 M	(1) increased wet-weather capacity	\$240 M	\$301 M			
Primary Treatment	(1) PST needs (2) Secondary bypass upgrade	\$1.8 M			\$23 M	(1) Microscreen filters for increased capacity	\$41 M	\$64 M			
Disinfection	(1) Storm surge resiliency needs (2) Outfall inspection and repair (3) CCT dewatering system	\$0.5 M	(1) Chlor / Dechlor improvements	\$18 M	\$19 M	 UV disinfection (provisions for AOP) increased wet-weather capacity (further study needed) 	\$150 M	\$169 M			
Total	(3) CCT dewatering system \$55.3 M		\$11.3 M		\$291 M	\$761 M		\$977 M			