

Adventures in
Phosphorus
Removal



NEWEA 2016 Annual Conference
January 26, 2016
Boston, Massachusetts



- 2010 permit expired
- Talk of Phosphorous limit in new permit
- Early 2012, Superintendent and myself attended 8hr phos. Seminar
- Manual exp chemical precipitation with ferric & alum
- 4 examples of Bio P with diagrams
- We had already decided on alum past issues ferric and UV
- Started design of temp Alum and permeant alum system
- Looking into possibility of running Bio P

ORIGINAL DESIGN LOADING

Design Flow Million Gallons Per Day


Minimum daily	3.66
Average daily	8.0
Maximum daily	16.50

The Wallingford WWTP was designed to provide treatment for the following parameters listed.

Parameter	Quantity (lb./day)	
	Design Influent	Design Effluent
Suspended Solids	13,352	2,002
BOD5	13,218	668
Ammonia-N	1,335	133
Ultimate Oxygen Demand	25,968	1,914

- Wallingford 8 MGD RBC plant
- Nite/Denite UV disinfection
- Discharges Quinnipiac River
- RBC not designed carry solids or return solids
- Sec clarifiers shallow 8ft deep
- Waste pumps are undersized


WALLINGFORD WWTP




- 2005 Nitrification/Denitrification was added
- 0.6 MGD storm tank was covered and converted to anoxic tank

16 MGD Pump station was added to pump RBC eff and Pri eff to anoxic tank


- Started carrying solids in secondary to build MLSS needed for Nite/Denite
- This required carrying 2 ft blankets in 8 ft deep secondary clarifiers
- Converting waste pumps to RAS pumps
- All 6 needed to run to achieve necessary return rate for Nite/Denite






- Early 2012 look at ways of running Bio P
- Had 2 empty Primaries taken off line
low summer flow 4 mgd
- 1 row RBC taken off line when nite/
denite was started
- Never came up to run bio p utilizing
these empty tanks

- Out came manual received at phos seminar
- Found diagram of MLE and Phordox process
 - Shows anaerobic zone with RAS
 - Anoxic zone with nitrate return
 - Followed by aerobic zone
 - We could fit this in our plant



- We have anoxic zone with nitrate return
- We have aerobic zone RBC
- We need anaerobic zone with return in front of these process we have that ability



Utilizing primary tanks



We redirected RAS to head of primary tank

WASTE PUMPS




- Waste Pumps repurposed to Return Activated Sludge Pump for denitrification
- WAS Pump
- RAS Pumps
- Run all six pumps – 250 gpm
- RBC Plant not designed to carry solids

PRIMARY PUMP CHAMBER – DRAIN/
MIXING PUMP



Turned drain pump on for mixing

- Built MLSS 4000 to 5000 in primaries
- Waited to see if it would go anaerobic and release phos
- Bio P requires organisms to release phos in anaerobic zone and they will take up more phos then released in Anoxic/aerobic zones.
- Inf phos 4-6 MG/L
- Started taking DO and Ortho reading twice a day
- In a week had Ortho leaving primaries of 10 to 12 MG/L
- Produced a plant EFF of approx. 1 MG/L
- We knew we could achieve some Bio p and shut it down in OCT



- March 2013 we started Bio p back up
- Temp alum system installed by plant maint

ALUM FEED SYSTEM PUMP SKID



- Built in-house
- Duplex System
- Each Pump Capacity
- 2- 92 gph
- Basement Secondary Pump Chamber, below storage tanks



Went out to bid for permanent alum tank installation

- May 2013 our new permit was issued
- .7 MG/L two month rolling avg for month April thru OCT till 2022
- Goes to 8.95 pounds

TABLE 1

Phosphate, Ortho	mg/l	NA	---	NA	---	NA	---	NA	---	NA	---	NA	---	NA	---	NA	---	NA	---	
Phosphorus (A) Total ¹ See Remark (C)	mg/l	---	NA	---	NA	---	NA	---	NA	---	NA	---	NA	---	NA	---	NA	---	NA	---
April 1 st through October 31 st	mg/l	---	NA	---	NA	---	NA	---	NA	---	NA	---	NA	---	NA	---	NA	---	NA	---
November 1 st through March 31 st	mg/l	---	NA	---	NA	---	NA	---	NA	---	NA	---	NA	---	NA	---	NA	---	NA	---
Phosphorus (B) Total ² April 1 st through October 31 st	mg/l	0.02	0.02	NA	---	NA	---	NA	---	NA	---	NA	---	NA	---	NA	---	NA	---	NA
November 1 st through March 31 st	mg/l	---	NA	---	NA	---	NA	---	NA	---	NA	---	NA	---	NA	---	NA	---	NA	---
Phosphorus Total April 1 st through October 31 st	lbs/day	---	NA	---	NA	---	NA	---	NA	---	NA	---	NA	---	NA	---	NA	---	NA	---
November 1 st through March 31 st	lbs/day	---	NA	---	NA	---	NA	---	NA	---	NA	---	NA	---	NA	---	NA	---	NA	---
Phosphorus (C) Total Average Seasonal Load Cap ³	lbs/day	8.95	NA	---	NA	---	NA	---	NA	---	NA	---	NA	---	NA	---	NA	---	NA	---
September 20th	lbs/day	---	NA	---	NA	---	NA	---	NA	---	NA	---	NA	---	NA	---	NA	---	NA	---

Footnote:
¹ For the Permit beginning April 1st through and including October 31st in no two consecutive months shall the average monthly Phosphate concentration exceed 0.7 mg/l.
² For the season beginning April 1st through and including October 31st the seasonal average shall not exceed 0.7 mg/l. The seasonal average shall be calculated by determining the average monthly discharge of total phosphorus for each month of the season (April through and including October) adding the average monthly discharges together and dividing by 7.
³ This limit shall be effective beginning April 1, 2022.
 This limit shall be effective beginning April 20th, 2022. The Average Seasonal Load Cap will be calculated as follows: The permittee's discharge shall not exceed the total phosphorus Average Seasonal Load Cap of 8.95 lbs/day of total phosphorus per day for any two consecutive calendar years or any two of three consecutive calendar years.
 Remarks:
 (C) The limits for Total Phosphorus (A) in Footnote 5 and 6 are separate and independent requirements each enforceable independent of the other.

2014 completed permanent installation
of Alum tanks

ALUM FEED SYSTEM



- (2) Large Tank 5,000 gal
- Day Tank 1,000 gal
- Double Walled
- Seasonal Use

The image shows a photograph of the alum feed system at a water treatment facility. It features two large, white, cylindrical tanks and a smaller day tank, all situated on a concrete pad. The tanks are surrounded by a grassy area and a paved walkway. The background shows other industrial structures and trees under a clear sky.

With avg 89%
removal

TOTAL PHOSPHOROUS


2013		Total Phosphorus						
Month	Flow MGD	Influent		Effluent		Pounds Removed	Percent Removal	
		mg/L	lbs/day	mg/L	lbs/day			
April	5.22	4.35	189	0.56	16	174	91.7	
May	4.44	3.95	220	0.59	14	205	95.4	
June	7.5	4.01	251	0.6	20	215	85	
July	5.18	5.53	236	0.54	20	215	90.2	
August	4.52	6.25	224	0.56	21	204	90.7	
September	5.0	6.96	292	0.46	15	187	91.6	
October	5.55	7.66	227	0.49	15	212	92.6	
Monthly Averages	4.9	5.72	222	0.49	20	201	91.1	
2014		Total Phosphorus						
Month	Flow MGD	Influent		Effluent		Avg Pounds Removed	Percent Removal	
		mg/L	lbs/day	mg/L	lbs/day			
April	9.66	2.88	206	0.64	52	157	75.2	
May	6.89	3.15	161	0.42	24	157	86.7	
June	4.76	4.66	199	0.4	16	179	91.6	
July	5.99	4.96	166	0.42	14	191	91.5	
August	5.59	6.65	206	0.52	16	190	92.4	
September	5.43	6.27	179	0.44	15	167	93	
October	5.61	6.25	186	0.56	17	170	90.7	
Monthly Averages	5.3	4.99	189	0.49	22	167	86.5	
Two Year 2013-14 Average		5	5.56	206	0.49	21	164.25	89.91
2015		Total Phosphorus						
Month	Flow MGD	Influent		Effluent		Avg Pounds Removed	Percent Removal	
		mg/L	lbs/day	mg/L	lbs/day			
April	7.9	4.45	195	0.69	45	250	84.6	
May	5.11	4.46	191	0.59	17	174	91.5	
June	4.9	5.55	226	0.5	20	206	91	
July	4.26	5.3	189	0.45	16	175	91.5	
August	5.75	5.54	172	0.57	16	155	89.7	
September	5.62	6.25	186	0.61	24	164	87	
October	5.72	6.9	214	0.58	12	202	94.5	
Monthly Averages	4.8	5.49	211	0.54	22	169	89.9	

WWTP LABORATORY



**Provides data, feedback
and graphical analysis**

**Maintains a State of CT
Certification as an
Environmental Public Health
Lab**



STAND BY YOUR MAN



What went wrong March 2015

Started bio P

And alum up at 50 gallons per million gals

based on the previous 2 years feed rate

Took PH and Ortho readings twice a day

Avg .4 eff ortho meant .6 to .7 total phos

Everything going along smooth until

May ammonia started to increase

Figured do to bio p and Alum

Next week ammonia conversion was non
existent

Started to investigate lab ran residual
alum in plant it was 1000 MG/L


This shouldn't be with .4 ortho should still
have a demand

Turned out ortho reading was plant eff
not RBC as in past 2 years

Ran ortho on RBC eff it was .1 meant
there was no demand

ALUM TOXICITY

* Alum was used for precipitating phosphates and aluminum phosphates



* Aluminum coagulants can adversely affect the microbial population in activated sludge at dosage rates higher than 150 mg/l

- Alum at 150 MG/L toxic to nitrifiers
- Shut alum off
- It took 2 months for Nite/denite to recover
- There was no negative impact to TSS or BOD

LESSONS LEARNED 1

- * Use RBC effluent orthophosphate measurements in the future to determine the correct alum feed rate
- * Aluminum residual in WWTP not to exceed 100 mg/l in effluent
- * Purchase ORP meter to measure polyphosphate release at RBC Effluent Channel
- * Evaluate the use of wall mixers for keeping solids in suspension (primary settling tank)
- * If drain/mixing pump located in the Primary Pump Chamber trips or is off a long period of time, a greater release of phosphorous is observed

Why .4 eff ortho when RBC eff .1 detention time in sec to long getting rerelease in sec take one off line.

- Volatility of sludge decreased seen 60%
- Dt time with drain pump RAS pump and plant flow less then 1hr

LESSONS LEARNED 2

- * When flows decrease the extended detention time in the secondary tank may cause a rerelease of phosphorous so tanks may need to be taken offline
- * Add polymers at the head of the secondary tank to reduce pin floc in the effluent
- * Be innovative and willing to make operational adjustments
- * Develop a standard operating protocol to account for seasonal and yearly flow variations

ADVICE

- * Keep DEEP in the loop
- * Research biological removal of phosphorous
- * Network with other operators
- * Don't be afraid to experiment!

THANK YOU

- * Terry Smith, Superintendent Wallingford WPCF
- * Kim Maloney, Lab Director Wallingford Water & Sewer
- * Brain Hickey, Engineer CDM
- * Seth Lentz, Engineer Wallingford Water & Sewer
- * Plant staff, Wallingford WPCF

