

Mystic Completes Year One Operating the BioMag Process

Megan B. Moody,
P.E.


January 26, 2015



**CDM
Smith**

Mystic WPCF Background


- Located in the coastal Town of Stonington, Connecticut
- Permitted capacity of 3.0 ML/d (0.80 mgd)
- Secondary treatment upgrade for nutrient removal (TN)
- Constrained site
- Minimal site modifications
- Existing Process:
 - Influent grinding
 - Primary clarifiers
 - Aeration basins (cyclic aeration)
 - Secondary clarifiers
 - Disinfection (NaOCl)
 - Solids diversion



Mystic WPCF Project Development


- 2007 Facilities Plan
 - Identified plant upgrade was required
 - Age and condition
 - Projected flow and load increase
 - Increased nitrogen removal
- 2009 Biological Process Evaluation
 - Evaluation of various treatment technologies
 - BioMag was identified to meet the project requirements
- 2010 Successful Full-Scale Demonstration
 - Effluent total nitrogen < 5 mg/L
- 2014 Permanent System Constructed

BioMag - Evoqua Water Technologies




Biological Design Criteria


Process	Conventional activated sludge in 4-stage Bardenpho configuration; can be operated as MLE
Process Loads (30-day max.) <ul style="list-style-type: none"> - BOD₅ - TSS - TKN 	530 kg/day (1160 lbs/day) 340 kg/day (740 lbs/day) 90 kg/day (200 lbs/day)
Design Parameters <ul style="list-style-type: none"> - Design temp. (30-day min) - Aerobic SRT - MLSS concentration - Total Nitrogen 	11 deg. C 9.9 days 8,800 mg/L (biological mass only) 6.4 mg/L (2014), 5.2 mg/L (2030)
Aeration basins <ul style="list-style-type: none"> - Number - Dimensions - 1st-stage anoxic volume - 1st-stage aerobic volume - 2nd-stage anoxic volume - Reaeration volume - Total volume 	2 6 m x 6.4 m x 4.04 m deep (52 ft x 21 ft x 13.25 deep) 0.180 ML (0.0475 million gallons) 0.416 ML (0.110 million gallons) 0.180 ML (0.0475 million gallons) 0.049 ML (0.013 million gallons) 0.825 ML (0.218 million gallons)
Final Settling Tanks <ul style="list-style-type: none"> - Number - Dimensions - Total clarifier surface area 	2 16 m x 4.0 m x 2.50 (52 ft x 13 ft x 8.2 ft deep) 124.6 m ² (1,352 ft ²)



MLSS Performance




SLR Performance



SVI Performance



Effluent Nitrogen Performance




Aeration Tank Foam

- Foam Mitigation Measures - Design
 - Surface cut outs in baffle walls
 - Foam spray nozzles
 - Skimmer trough in effluent channel for surface wasting




Aeration Tank Foam

- Foam Mitigation Measures – Field Implementation
 - Defoamer agent
 - Surface wasting wells in bioreactors
 - Process optimization



Magnetic Drum Biological Capture Efficiency

- 95% magnetite recovery
- 70% biological solids capture
- Unintended WAS to bioreactor
- Thinner WAS to sludge thickening




Solids Deposition

- RAS and WAS wet wells required mixing
- Recycle systems included in design
- Settling experienced after startup
- Creates unbalanced solids inventory
- Impacts sludge thickening
- Further mixing implemented in field

Clarification and Disinfection


- Final settling tank performance issues
 - Polymer dosage
 - Foam carryover
 - Solids carryover to disinfection
 - Below TSS permit concentration of 30 mg/L
 - Above typical TSS concentration of 10 mg/L
 - Poor UV disinfection performance
 - Enterococci limit of 35 MPN/100mL
 - Potential shading/shielding
 - Partical size distribution



Loge et al., 1996

March 2015 Secondary Effluent Analysis

TSS Particle Size Distribution



Collimated Beam Testing

Dose (mJ/cm ²)	Log Inactivation	Enterococci (count/100ml)
0	0.000	904
10.14	0.850	128
20.27	1.394	37
30.41	1.696	18
40.54	1.628	21
50.68	1.698	18

Secondary Effluent Filtration Pilot

- Disk filter pilot to determine ability to meet disinfection permit requirement
- Filter secondary effluent to reduce TSS to less than 10 mg/L
- Preliminary results indicate that UV disinfection was effective on the filtered sample



Collimated Beam Testing

Filter Influent		
Dose (mJ/cm ²)	Log inactivation	Enterococci (count/100mL)
0	0	7088
10	1.419	270
20	1.492	228
30	1.572	190
40	1.653	204
50	1.623	169
Filter Effluent		
Dose (mJ/cm ²)	Log inactivation	Enterococci (count/100mL)
0	0	5930
10	2.511	18
20	3.773	0
30	3.773	0
40	3.773	0
50	3.773	0

Design and Operation Considerations

- Foam Mitigation Measures
 - Foam Spray
 - Defoamer Agent
 - Surface wasting directly from bioreactors
- Account for biological solids capture efficiency
- Track solids inventory
- Prevent solids deposition through process
- Continual process optimization
- Consider particle size distribution for UV disinfection of enterococci

Treatment Performance Summary

- UV disinfection has been problematic
- Particle size distribution and potential shielding may be contributors
- BioMag process successfully reduces total nitrogen
- Ballasted mixed liquor enhances settling and decreases SVI
- *Facility operates at a high MLSS concentration without any increase in tankage providing a high level of treatment in a small footprint*

Acknowledgements

