

Challenges in Selecting New Biosolids Treatment and Disposal Equipment for the Mattabassett WPCF

Presented by:
Prashanth Emmanuel, Wright-Pierce

WRIGHT-PIERCE 
Engineering a Better Environment

The Mattabassett District

- Regional WPCF

- Serves 4 member communities:
 1. New Britain,
 2. Berlin,
 3. Middletown,
 4. Cromwell &
 5. Portions of Farmington, Rocky Hill & Newington, CT

- Initial Operation – 1965


- Secondary Treatment Upgrade – 1989

- Nutrient Removal & Capacity Expansion – 2015


Annual Average Flow – 35 MGD

Maximum Monthly Flow – 55 MGD

CEPT – 55 – 110 MGD



Overview of the Treatment Plant



Equipment Conditions Prior to Upgrade

- Multiple Hearth Incinerator – Installed in 1960's
- Fluidized Bed Incinerator – Installed in 1980's
- Belt Filter Presses/ Sludge Pumps - Installed in 1980's
- Polymer System - Installed in 1980's




Goals

Sludge Dewatering Upgrade

- Incinerating onsite vs disposing sludge offsite
- Autogenous Incinerator Operation
 - Minimize supplementary fuel required
 - 24% to 28% cake dryness
- Ability to handle varying sludge conditions



Sludge Process



Recommendations

Facilities Plan 2004


- Dewatering Alternatives Recommended
 1. Belt Filter Press Dewatering
 2. Centrifuge Dewatering
 3. Rotary Press Dewatering



Alternative 1

Belt Filter Press

- Replace with three new 1.5 M belt filter presses (2 duty, 1 backup)
- BFP capacity was calculated at an average influent feed loading concentration of 2.8%
- If co-thickening is eliminated thickening of the WAS will be needed using a gravity belt thickener



Alternative 1

Belt Filter Press


- Advantages
 - Equipment can be started and shut down quickly
 - Less noise associated to other equipment
 - Most maintenance work can be done by plant staff except for belt replacement
- Disadvantages
 - Odors not easily contained
 - Requires high pressure/volume wash water for cleaning
 - Greasy sludge can blind belts
 - Requires more cleanup and can be time consuming

Alternative 2

Centrifuges

- Replace with 3 new centrifuges (2 duty and 1 back up)
- Centrifuge can handle influent loading concentration of 2.3%
- If co-thickening is eliminated, thickening of the WAS will be needed using a gravity belt thickener

Centrifuge



Alternative 2

Centrifuges



- Advantages
 - Ability to control cake dryness
 - High throughput in small footprint
 - Fully enclosed for minimal odors
 - Minimal wash water requirements
- Disadvantages
 - Highest energy requirements
 - High operating noise level
 - Maintenance requirements higher than other technologies

Alternative 3

Rotary Press

- Replace with 3, six channel rotary drum press
- Sizing is a function of solids loading rate and not hydraulic loading rate
- If co-thickening is eliminated, thickening of the WAS will not be needed using a gravity belt thickener

Rotary Press



Alternative 3


Rotary Press

- Advantages
 - Compact
 - Moderate capital costs
 - Relatively enclosed for odor control
 - Can be automated for minimal operational needs
- Disadvantages (2004 Facilities Plan)
 - Limited operating history
 - Only one manufacturer, making equipment proprietary

2004 Pilot Test Rotary Press

THE MATTABASSETT DISTRICT Plant location: Cromwell, CT *CAKE DRYNESS VS THROUGHPUT* *(MIXED SLUDGE)*

April 26 to 29, 2004




CV CHANNEL 2" X 10"

2008 Pilot Results

Rotary Press

Production vs Dryness (separated by day)



2009 Pilot Test Centrifuges

Model CS18-4 Skid Mounted System




2009 Pilot Test Centrifuges

FLOW RATES, Gpm	CAKE SOLIDS, % w/w ts	POLYMER DOSAGE, #/ton db (active)	Recovery, % w/w ss.
72	26.9 - 31.9	14.6 – 17.7 [Poly B]	83.7 - 94.3
75	23.7 - 29.2	10.6 – 12.7 [Poly A]	95.4 - 96.7

- Polymer A - Mannich Polymer
- Polymer B - Emulsion Polymer

2009 Pilot Test Centrifuge Results - Polymer

Figure 1. Viscotherm CVC Control of Cake Solids



Summary

- District further evaluated – Visited several installation locations
- Centrifuge Chosen
 - 3 Units – 0.75 tons/hr. per unit each
- Enclosed – Better Odor Control
- Ability to handle a variety of sludge characteristics




**Centrifuges: Westfalia
\$ 1,060,000**

General Contractor: CH Nickerson



Current Operating Results - Westfalia






**Incinerator Feed Pump:
Putzmeister Twin-Cylinder
Reciprocating Piston Pump
\$640,000**



**Stored Sludge Pump:
Carter Triplex Plunger
Pumps
\$200,000**



**Mattabasset , CT WPCF
Fluidized Bed Incinerator
(Manufacturer -Preselected)
\$ 21,000,000**



Infilco Degremont Inc.

Questions

