

Beyond the ECM Pro-active Energy/GHG Reduction Measures

Robert Pape, AECOM

Gabrielle Moore, AECOM

Tami Lin, NYCDEP

Anthony Fiore, NYCDEP


Jane Atkinson, AECOM

GOAL

Ensure that the energy and GHG emissions implications of all [construction] projects are fully considered and factored into the overall decision-making process from conceptual design to operations.

GOALS AND EXPECTATIONS

Continued Sustainability



Typical Design Evaluations

- Reliability
- Vendor/Manufacturer Reliability
- Operation Complexity
- Maintenance Requirements
- Durability
- Expense (including lifecycle)

Energy Considerations Added

- GHG Emissions vs. Lifecycle Costs
- Level of GHG emissions
- Energy Consumption vs. Lifecycle Costs
- Criteria Pollutants

SOP and Policy Development

- Develop Energy Conservation and GHG reduction SOPs for all construction projects



- Develop Energy Operations and Design Policies: Design kick-off meetings, BODR, 30%/90% deliverable milestones, and RFP

Design Phase

- Require Energy Analysis during BODR and design to show:
 - Current energy use and GHG emissions
 - Design alternatives analysis of energy/GHG changes
 - Economic Analysis of energy for alternatives

Construction to Operations

- Continue Energy Priority through Construction (i.e. Change Orders)
- Maintain Energy Optimization/GHG reduction in Operations through O&M manual and staff training

ITS NOT JUST MORE EFFICIENT MOTORS AND PUMPS

Policy Objectives

- Energy/GHG reductions from electro-mechanical processes
- Facility Layout (i.e. minimize pumping distances, blowers near discharge, etc.)
- Maximize ADG production and use
- Control/Operational Strategies (pumping, DO control)
- Energy Source Conversion (heat recovery, preheating sludge with digester effluent)
- Process emissions and energy (side stream treatment)

Evaluation Metrics

- Capital Cost per unit Energy Saved and metric ton of CO₂(e) avoided
- Annual energy savings
- Percent change in energy consumption and GHG emissions
- Simple payback
- Lifecycle Costs (incl. O&M, escalation, and useful life)
- Net Present Value
- Cash Flow Evaluation



Design Services Goals

- Develop design options that consider energy
- Generate an energy profile report
 - Baseline current condition energy consumption and GHG emissions
 - Using direct measurements
 - Modeling
 - Predicted Future energy conditions via modeling
 - Perform an economic analysis for each option

Process Systems Design

- Baseline energy best determined with direct measurements. Absent that, modeling will be required.
- Modeling requires use of standards:
 - Manufactures pump/blower curves
 - Most recent electrical and steam GHG emission factors (i.e. LGOP, IPCC, etc.)
 - Acceptable and typical engineering formulas
 - Standard variables and constants (Moody's, kinetic constants, etc.)
 - Report findings in standard units like MMBtu or KWH/d



Building Systems Design

- **Baseline energy best determined with direct measurements. Absent that, modeling will be required.**
- **All designs must follow applicable codes**
- **Follow energy and emission guidelines outlined in Envision**
- **Modeling requires use of standards:**
 - **ASHRAE Standard 90.1-2010 Appendix G**
 - **DEP Energy Guidelines**
 - **Models (i.e. DOE-2, BLAST, eQUEST, DEP approved equal, etc.)**

Construction Phase

- Mindful of change orders
 - Identify modification that will affect energy/GHG emissions
 - Existing analysis
 - New additions not previously investigated
 - Increases in energy or GHG emissions should be 0 unless otherwise justified



Meeting Design Intent Operationally

- **Identify the design intent with respects to energy and GHG emissions:**
 - **Process (i.e. thickener operations or DO control strategies)**
 - **Target operational set point**
 - **Maintenance requirements to keep efficiencies high**
 - **Operational requirements: Energy and systems monitoring**

Score the Options

| Category | Subcategory | Scoring (5 - 1, unless otherwise specified) NOTE: Results that are similar (within 5% of each other) shall be scored equally. | Weight | Design Option 1 | | Design Option 2 | | Design Option 3 | |
|----------------------------|---|---|--------|-----------------|----------------|-----------------|----------------|-----------------|----------------|
| | | | | Score | Weighted Total | Score | Weighted Total | Score | Weighted Total |
| Technology | Potential Reliability | Common Technology Used in NYC=5; Common Technology Not Used in NYC=4; Fairly Common Technology=3; Uncommon Technology but Gaining Popularity (at least 5 years old)=2; Cutting Edge Technology=1 | | | | | | | |
| | Vendor/Manufacturer Procurement | Rate the Vendor/Manufacturer based on contact/availability, product workmanship, and estimated company security (1 to 5) | | | | | | | |
| Operations and Maintenance | Complexity | Rate operating the technology from very complex=1 to not complex=5 | | | | | | | |
| | Maintenance Level | Less maintenance than current or typical design/equipment used = 5 to More maintenance than current or typical design/equipment used =1 | | | | | | | |
| | Durability | The system/equipment can withstand the operating environment (e.g. wear by grit, corrosive atmosphere, etc.) = 5 to The system/equipment will frequently fail in its operating environment=1 | | | | | | | |
| Economics | Capital | Rank least expensive 5, next least expensive 4, and so on until zero | | | | | | | |
| | Lifecycle | Rank lowest lifecycle cost 5, next lowest 4, and so on until zero | | | | | | | |
| Environment | GHG Emission/Lifecycle cost | Rank highest 5, next lowest 4, and so on until zero | | | | | | | |
| | GHG Emission Reduction from Current* | Rank >50% reduction = 5; 25% - 50% reduction = 4; 5% - 25% = 3; 0.1% - 5% = 2; 0%=1; an increase = 0 | | | | | | | |
| | Reduction in Energy Consumption/lifecycle cost* | Rank highest 5, next lowest 4, and so on until zero | | | | | | | |
| | Criteria Pollutants | Rank 5 - Decrease in criteria pollutant emissions, Rank 3 - Increase in criteria pollutant emissions but facility remains in current air permitting category, Rank 1 - Increase in criteria pollutant emissions causing facility to be recategorized. | | | | | | | |
| Other (e.g. Footprint) | | | | | | | | | |
| | | | | | | | | | |
| TOTALS | | | | | | | | | |

Design Guidelines

| | |
|---|---|
| Location | <i>BWT Facilities</i> |
| Unit Process | <i>RAS Pump Controls – Energy Consideration</i> |
| Date Issued | <i>08/30/2013</i> |
| Design Evolution: | |
| Energy conservation and greenhouse gas (GHG) reductions are a New York City-wide initiative. The following design guidelines have been prepared in efforts to achieve these goals through the use of variable speed drives and system monitoring. | |
| Lessons Learned: | |
| This is the initial issuance of this design guideline and no City-specific experience with this specific design guideline exists at this time. | |
| Overall Design Philosophy: | |
| RAS pump controls shall be constructed to monitor energy consumption and minimize energy use. | |
| Constructability Issue for Design Consideration: | |
| None at this time. | |
| Operational Issues for Design Consideration: | |
| In many instances, two or more RAS pumps will be operated simultaneously. The total speed or flow rate for all pumps shall be set based on wet well operating targets; however, the operational speed or flow for each individual pump shall be set to consume the least amount of energy in total. | |

Design Guidelines

| | |
|---------------------------------|--|
| Approved Manufacturers: | |
| Not Applicable | |
| Detailed Design Criteria | |
| Component: | System Control |
| Criteria: | System control shall be variable speed |
| | |
| Component: | System Monitoring |
| Criteria: | <p>The RAS pump control system shall monitor the following at a minimum:</p> <ul style="list-style-type: none"> • Instantaneous energy/or power draw (KWH) • Totalized energy draw (KWH/d) • Run time • Instantaneous flow (gpm) • Totalized flow (gpd) |
| | |
| Component: | Programming |
| Criteria: | The control program shall include energy set points/goals that sets the pumps total flow rate based on incoming flow (i.e. maintaining wet well elevations) while setting each individual pumps speed at a point that will minimize energy consumption for all pumps in total. |
| | |
| Component: | Archive |
| Criteria: | All control data collected shall be retained for at least three years and must be archivable. |

Design Consideration: Example 1

Design: 200 ft pipe run with 15 ft lift at 400 gpm

Consideration: 4" vs. 4.5" pipe – same pump

| | 4" | 4.5" |
|--------------------------|--------------|--------------|
| Pipe Cost | \$16,890 | \$18,540 |
| Energy Cost (\$0.11/kwh) | \$2,813/year | \$2,200/year |

Savings: Over \$600/year
Simple Pay Back: Under 4 years

Design Consideration: Example 2

Upgrade Thickening: Centrifuge vs. Gravity Belt Thickening

Centrifuges consumes more energy than gravity (i.e GBT), but...

- Lower maintenance requirements
- Potentially thicker sludge
 - Decrease in heating demand
 - Increase in digester HRT → more digester gas production
- Potentially better centrate quality
- Lower polymer requirements

What are the underlying needs.

Case Study


Rehabilitate an old Stormwater Pump Station
Initial construction in 1950's – 9.8 MGD



Case Study

Work:

- Replace three axial flow pumps with submersible pumps
- Improve lighting (LED)
- Install electrical room
- Improve pump station access



Case Study

| Storm Return Period | Future | | | Current | | | Change | | |
|---------------------|-------------------|---------------|----------|-------------------|---------------|----------|-------------------|---------------|----------|
| | Electric Consumed | GHG Emissions | Cost | Electric Consumed | GHG Emissions | Cost | Electric Consumed | GHG Emissions | Cost |
| Year | kwh/event | lb CO2e | \$/event | kwh/event | lb CO2e | \$/event | kwh/event | lb CO2e | \$/event |
| 1 | 43 | 28 | \$ 7.78 | 29 | 19 | \$ 5.31 | 14 | 9 | \$ 2.48 |
| 2 | 52 | 34 | \$ 9.34 | 35 | 23 | \$ 6.37 | 17 | 11 | \$ 2.97 |
| 10 | 69 | 46 | \$ 12.45 | 47 | 31 | \$ 8.49 | 22 | 14 | \$ 3.96 |
| 25 | 86 | 57 | \$ 15.57 | 59 | 39 | \$ 10.61 | 28 | 18 | \$ 4.95 |
| 50 | 104 | 68 | \$ 18.68 | 71 | 47 | \$ 12.74 | 33 | 22 | \$ 5.95 |
| 100 | 121 | 80 | \$ 21.80 | 83 | 54 | \$ 14.86 | 39 | 25 | \$ 6.94 |

Future - Current (+ is increase/- is decrease)

| Asset | Future | | | Current | | | Change | | |
|-------------------|--------|----------------|----------|---------|----------------|----------|--------|----------------|---------|
| | Power | GHG Emmission | Cost | Power | GHG Emmission | Cost | Power | GHG Emmission | Cost |
| | kwh/yr | tons CO2e/year | \$/yr | kwh/yr | tons CO2e/year | \$/yr | kwh/yr | tons CO2e/year | \$/yr |
| Fan | 13,065 | 4 | \$2,352 | 8,165 | 3 | \$1,470 | 4,899 | 1.6 | \$882 |
| Unit Heaters | 86,880 | 29 | \$15,638 | 76,020 | 25 | \$13,684 | 10,860 | 3.6 | \$1,955 |
| Total HVAC System | 99,945 | 33 | \$17,990 | 84,185 | 28 | \$15,153 | 15,759 | 5.2 | \$2,837 |

Future - Current (+ is increase/- is decrease)

Case Study

The design needs in this case justified an increase in energy costs. Due to the need to improve climate conditions particularly for the electrical components: A less efficient submersible pump as opposed to a centrifugal pump was needed to facilitate footprint.

| Change from Current Operations to FSD | |
|---|------------------|
| Estimated Annual Electrical Consumption | 16,035 KWH/year |
| Estimated Annual GHG Emissions | 5 tons CO2e/year |
| Estimated Annual Operating Costs | \$2,886/year |
| Future - Current (+ is increase/ - is decrease) | |

QUESTIONS?

THANK YOU