

The Town of Groton, CT Looks to the Future: Upgrades to the WPCF Effluent Pump Station and WPCF Resiliency

Presented by:

Virgil Lloyd, PE, Fuss & O'Neill, Inc.

Chris Lund, Town of Groton, CT


June 7, 2016

Agenda

- Facility overview
- Original discharge to Fort Hill Brook & WQ Concerns
- Effluent Pump Station & Relocated NPDES Discharge
- Current EPS Upgrades
- WPCF Hardening & Resiliency Measures



Town of Groton, Connecticut



Groton, CT

City of Groton
Water Pollution
Control Facility
(today's tour)



Thames
River

Town of Groton
Water Pollution
Control Facility

WPCF Pre-Upgrade



Post-Upgrade - 2010



Fort Hill Brook & Mumford Cove

- Original facility NPDES discharge to Fort Hill Brook
- Drains to Mumford Cove
- Water quality concerns with mixing and dilution in Mumford Cove
- 1985 CTDEP orders Town to relocate discharge to Thames River




Fort Hill Brook & Mumford Cove



Force Main & Gravity Sewer Installed 1986



Effluent Force Main Profile



MAP REFERENCES:
 1. "CONSTRUCTION CONTRACT 18, WATER POLLUTION CONTROL FACILITY, OUTFALL 'SERIES', BY HAYDON/MEDIAN CONSULTING ENGINEERS, AUGUST 1988, 'AS BUILT' RECORD SET DATED MAY 1988
 2. PRICE BROTHERS LAYING SCHEDULE, PROJECT # 173.000A, 11-12-86 THROUGH 2-9-87
 3. "FINAL REPORT FOR FUSS & O'NEILL, INC., TOWN OF GROTON, CT EFFLUENT FORCE MAIN", ADVANTICA TECHNOLOGIES, NOVEMBER 21, 2001
 4. "FINAL REPORT FOR FUSS & O'NEILL, INC., TOWN OF GROTON, CT EFFLUENT FORCE MAIN", BY ADVANTICA TECHNOLOGIES, JANUARY 15, 2003

LEGEND
 AV 5 EXISTING VALUES
 NEW AV 5 NEW VALUES FOR "WORST CASE" (NOV. 2003)
 NEW AV 7 NEW VALUES FOR "TYPICAL OPERATION" (JAN. 2003)

Effluent Pump Station

- Constructed 1986
- 6 vertical turbine pumps
- Pumping Capacity
8,400 gpm (12.2 MGD)
- Electrical feed from “A”
Service only
- Controls using Local
Bubbler System and
water levels in clearwell



Effluent Pump Station



Existing Pump Room


- 3 levels, located over twin wet wells




Pumping Improvements

Improvements Include:

- Increase Capacity -10,420 gpm - 15 MGD
 - 4 - 350 HP Vertical Turbine Pumps**
 - Plus low flow jockey pump**
- Piping Gallery improvements
 - Gate Valves, Check Valves**
 - Flowmeter, Flanged Fittings**
 - Expansion Joints**
 - Plant Water Piping Improvements**
 - Piping Supports and Thrust Blocks**
 - New Air Release Valve for Transient Flows**
- Valve improvements in Wetwell
 - Isolation Valve for Wetwells**
 - Electrically Actuated Sluice Gates**
- Controls improvement
 - Connect to Overall SCADA System**
 - Level Sensors**
 - Backup floats**





Pump Manifold & Access Improvements



Issues with Existing Pipe Gallery

- Difficult to isolate pumps for removal or maintenance
- Unable to isolate one side of Clearwell
- Need to Re-direct Flow to temporary discharge to Fort Hill Brook

Pump Manifold & Access Improvements




Manifold Upgrade

- Open floor around pumps for access
- Structural modifications to pump floor
- Addition of Valves on discharge to isolate pumps
- Able to keep wetwell in operation

Exterior Improvements

New Valve Vault for Mumford Cove FM

- Provide Access for Valve Maintenance
- Provide Operational Reliability - Routine Exercising
- Provide Operational Flexibility for maintenance or repair




New Valve Vault for EPS Force Main

- Provide Access for Valve Maintenance
- Provide Operational Reliability - Routine Exercising
- Provide Flexibility if Need to Take EPS FM Offline



Flooding Risk



- The majority of the WPCF site is outside of the 1% chance flood
- Portion of site is designated “Other Flood Area”
- Risk assessment notes concern with increased storm severity & occurrence

WPCF Tunnel System




- Lowest portions of existing tunnel system at risk for flooding
 - Fort Hill Brook
 - Internal sources



Hardening & Resiliency Measures

- Tunnel Entry Blocking – Various openings will have flood proof doors or barrier walls
- Tunnel Flood Alarm System - A “flood alarm” system in tunnels, including simple floats in the sump pits
- Tunnel Dewatering - Installation of flood sumps (with pumps)
- Stormwater sumps – standpipes and portable generator connection/control panel to allow for portable pump connection



Hardening & Resiliency Measures

- Tunnel Entry Blocking
 - Flood proof doors
 - Batter boards



Hardening & Resiliency Measures

- Tunnel Entry Blocking - Zone 5 and EPS stair towers will have Flood proof doors or barrier walls



Hardening & Resiliency Measures

- Tunnel Flood Alarm System - A “flood alarm” system in tunnels in existing and one new sump




Relocate 'A' Service Entrance



- Facility has 2 electrical services ('A' and 'B')
- 'A' Service entrance is located in tunnel
- Distribution panel
- Automatic transfer switch

At risk if tunnels flood


Existing Operations & Control Center



- 1970's vintage annunciator wall panel – functions as oversized “junction box”
- Antiquated relays, wiring and signals for existing controls & SCADA
- Existing fiber optic loop system: many connections due to growth over time

Reliability issues with overall facility control

Operations & Control Center Upgrade



New Operations & Control Room

- Extend building footprint
- New power transformer for "A" Service
- Wall mounted displays with SCADA control screens
- Additional Meeting Area


Repurpose Existing Control Room

- Relocate 'A' Service entrance
- Main distribution panel for "A" Service
- New ATS for "A" Service generator
- Distribution panel for Lighting, HVAC
- Controls Junction Boxes



Electrical/HVAC Improvements

- Pumps Equipped with VFD's
- New Lighting for Area
- Power split between Two Services
 - 1,200 Amp Service from "A" Service
 - 1,200 Amp Service from "B" Service
- New PLC Control Panel for Pump Station
- Redundancy/Reliability for Backup Power
 - Manual Transfer Switch - 1,200 Amp "A" Service
 - Manual Transfer Switch - 1,200 Amp "B" Service
 - Portable Generator Conn. - "A" Service
 - Portable Generator Conn. "B" Service
- Unit Heaters connected to Hot Water and Existing System
- HVAC Equipment w/ Dehumidification
 - New Interior Duct System
 - Wetwell Exhaust Fan



Acknowledgments

- Chris Lund, Assistant Director of Public Works, Town of Groton
- Greg Hanover, P.E., Town Engineer, Town of Groton
- Kevin Flood, P.E., Senior Project Manager, Fuss & O'Neill, Inc.