

# Somerset Raritan Valley Sewerage Authority

## SSO Abatement and Storm Control Treatment Facility



Michael Sanders, P.E., Kleinfelder  
Collection Systems Specialty Conference  
NEWEA  
September 12, 2016



# Presentation Outline


- Collection System Overview
- SSO Problem Definition
- Monitoring and Modeling
- Alternatives Analysis
- Proposed Solution

# Somerset Raritan Valley Sewerage Authority System Overview


- 23 MGD Advanced Wastewater Treatment Facility (permitted for 24.3 MGD) in Bridgewater, New Jersey
- Discharges to Raritan River
- Serves 9 municipalities (Population ~ 127,000)
- 4.5 miles of sewer interceptor



# SRVSA Service Area and Interceptor

 Meter Chamber 4


 SRVSA Interceptor

 SRVSA WWTP

## Sewer Service Area

-  BRANCHBURG TWP
-  BRIDGEWATER TWP
-  HILLSBOROUGH TWP
-  MANVILLE BORO
-  MILLSTONE BORO \*\*
-  RARITAN BORO
-  SOMERVILLE BORO
-  WARREN TWP \*

2014 ESRI Roads Basemap  
2014 NJDEP Sewer Service Areas



\*Includes discharges in Bernards Twp. and Green Brook Twp.

\*\*Millstone Boro added in adopted WMP Sewer Service Area Map but not yet serviced.




# Timeline on Interceptor Surcharging

- **1958: SRVSA constructs Interceptor Sewer, including “bypass outlet” at Meter Chamber No. 4 that discharged directly to Raritan River**
- **1965: SRVSA constructs original Storm Control Pumping Station, which pumped flow out of interceptor and through screening/chlorination facility which discharges directly to Raritan River**
- **1970: SRVSA constructs two-mile long forcemain connecting the Storm Control Pumping Station directly to the head of the treatment plant with station capacity of approx. 18 MGD**
- **1988: SRVSA expands Storm Control Pumping Station capacity to approx. 30 MGD and removes bypass.**
- **1998: New metering systems installed that are able to measure under surcharge conditions and reverse flows.**


# Timeline on Interceptor Surcharging

- **1998 – 2012:**
  - **Rehabilitation and modifications to main treatment facility**
  - **Construction of 30” relief interceptor**
- **2009: Somerville secures leaking manhole at Meter Chamber No. 4.**
- **2010: Investigation of flooding of little league field leads to new understanding of extent of problem.**
- **2011: Began preliminary investigation of options to address problem.**

# Meter Chamber No. 4 Area




# Profile of Somerville 27" Trunk Sewer





# Profile of Somerville 27" Trunk Sewer



# SSO Problem Definition

During excessive wet weather conditions, wastewater from the Borough of Somerville is escaping the sanitary sewer system upstream of Meter Chamber No. 4.



This occurs because:

- the SRVSA interceptor becomes surcharged due to the excessive I/I from the member municipalities, and
- the low elevation of the Somerville 27" trunk sewer relative to the interceptor.

# Overview of Sanitary Sewer Overflow



Central Ave on March 30, 2014



Central Ave on March 31, 2014



# Central Ave. During March 2014 Storm





# Largest Overflow Observed – SV07

(March 2014 during SRVSA Plant Upset))






# Little League Field from Southside Avenue Showing Ponded Sewage Discharge





# Basement Elevations are Key





# Extensive Monitoring and Modeling Studies

- **Hydraulic Model** of SRVSA interceptor and lower Somerville system
  - Utilized existing SRVSA meter data supplemented with 12 additional meters
  - Used to determine design criteria
- **Wasteload Allocation Study** to predict impact of SSO treatment plant on Raritan River
  - Water quality monitoring during six storms
    - Data collected during overflow conditions from Peter's Brook, Raritan River, and SSO
  - Flow and water quality models developed for Raritan River / Peters Brook
  - Model used demonstrate water quality benefit and establish effluent limits
- **Alternatives Analysis** to evaluate SSO solution alternatives
  - Four alternatives evaluated using three criteria: environmental considerations, feasibility, and costs






# Hydraulic Model


- Developed GIS of interceptor and lower Somerville sewer system (manhole and pipe elevations and locations; pipe lengths; valve locations; pipe materials, etc.) and hyperlinked original plan sets.
- Developed SewerGEMS model of SRVSA Interceptor and lower Somerville sewer system.
- Model simulates flow and hydraulic grade line.
- Meter chamber flow meter data used as input to model.
- Model used to simulate proposed improvements and evaluate best means to stop overflows.

# Hydraulic Model




# MC4 Results – November 2013 Storm

## Flow Assessment and SRVSA Data Comparison



# Meter Chamber #4 Issue








# Metering/Sampling Program Summary


- Temporary Flow Metering Program
  - 15 meter chambers at municipal connections to interceptor
  - June 2013 – July 2014
  - 4 storms with overflows:
    - June 7-8, 2013 – 4.2 inches rain (substantial, but unmeasured overflow volume)
    - November 26-27, 2013 – 3.3 inches rain (10,000 gallon overflow)
    - March 29-30, 2014 – 3.0 inches rain (9,000,000 gallon overflow)\*
    - April 29-30, 2014 – 4.6 inches rain (750,000 gallon overflow + upstream)
- Water Quality Sampling Program
  - 7 storm events; 5 stream locations and 1 sewer system location
  - Parameters: BOD<sub>5</sub>, TSS, TKN, NH<sub>3</sub>-N, NO<sub>3</sub>-N, TP, metals, and E. Coli
- Interceptor I/I Investigation

\*Overflow exaggerated due to plant upset.


# Temporary Flow Meters



# Quantifying Sewer Overflows



# Flood influence on Sewer Overflows








# Solution Alternatives

- No Action
- Pump Station, Force Main, & SRVSA WWTP Expansion
- I&I Reduction
- Storage
- Auxiliary Treatment Facility (named “Storm Control Treatment Facility”)



# Solution Alternatives

1. Reduce Infiltration/Inflow
    - Impractical
    - Cost Prohibitive
    - Results not guaranteed
    - Multiple decade implementation timeframe
  2. Pump, Convey, and Treat at SRVSA WWTP
    - Land Use permitting issues
    - Availability of land for SRVSA WWTP expansion
    - Inefficiency in designing expanded plant for few large storms
    - Cost prohibitive
  3. Storage
    - Huge volume required
    - What happens when tank full?
  4. Construct plant for SSO treatment
    - Eliminates discharge of untreated overflow
    - Relieves flow sent to SRVSA during wet weather
    - Cost effective
- 



# No Action

- Positive Attributes
  - No Costs Incurred
- Negative Attributes
  - Overflows will continue during large storm events
  - Water quality will continue to be degraded
  - Continued public health risk







# Pump Station, Force Main, & WWTP Expansion

- 14 mgd peak flow pump station, 2 mile long 24-inch force main, and WWTP expansion to handle additional 14 mgd peak wet weather flow
- Positive Attributes
  - All treatment occurs in one place
  - Would address future expansion requirements
- Negative Attributes
  - Secondary impacts along pipeline to WWTP
  - Expanded capacity will sit unused most of the time
  - Operational challenge to keep biology alive
  - Requires land acquisition
  - Provides additional capacity for unplanned development
  - Requires WMP amendment
  - Cost estimated at \$49 million

# Pump Station and Force Main



# Treatment Plant Expansion





# Inflow and Infiltration Reduction

- To stop SSO in Somerville, would need to remove 11 mgd (27% reduction) in peak flow from municipal systems
- Positive Attributes
  - Direct solution to problem
  - No treatment system required
  - Would not require land acquisition
- Negative Attributes
  - Municipal systems not within SRVSA's jurisdiction
  - Overflows will continue over the decades required to implement
  - Not guaranteed to remove sufficient I&I
  - Not guaranteed to eliminate SSOs
  - Cost estimated at \$54 million






# Storage

- Need 20 million gallon tank to safely store 2 days of Somerville flow.
- Positive Attributes
  - Only minor treatment needed
- Negative Attributes
  - Extended storms may exceed tank capacity and cause SSOs
  - Size of Tank (300' x 170' x 53')
    - eyesore to community
    - large surface area: large odor control volume
  - Cost estimated at \$64 million
  - Will require additional land acquisition
  - Remote facility to operate and maintain

# Storage Alternative



AERIAL  
SCALE: 1" = 200'



TANK DETAIL  
SCALE: NTS




# Storm Control Treatment Facility (SCTF)


- Auxiliary treatment facility with 14 mgd peak flow and 9 mgd average flow treatment capacity
- Positive Attributes
  - Maximizes ability to remove SSOs caused by interceptor surcharge
  - Takes pressure off existing WWTP during high flows
  - Minimum cost of alternatives - \$18 million
- Negative Attributes
  - Requires auxiliary treatment facility and discharge
    - Remote treatment facility to operate and maintain
    - Land acquisition required



# Storm Control Treatment Facility Process Schematic



## Estimated Costs for Each Alternative (Includes Capital and O&M Costs)



## Alternative Rating Results\*

Evaluation Criterion	I&I Reduction	Storage Tank	Pump & Expand	SCTF
Cost	1.0	1.0	1.0	2.0
Feasibility	1.0	2.0	2.0	3.0
Environmental Impact	0.0	1.0	1.0	2.0
Total (w/o weighting)	2.0	4.0	4.0	7.0

\* 0 = worst; 3 = best



# Project Status

- NJDEP has approved the SCTF alternative
- NJDEP has issued draft NJPDES discharge permit for SCTF
- Engineering design is 60% complete
- Working on Land Use permits and Land Acquisition
- Anticipated Schedule (subject to change based on approvals):
  - Submit Final Design to NJEIT – September 2016
  - Receive All Required Permits and Approvals – April 2017
  - Construction Start – June 2017
  - SCTF In Operation – January 2019





# Questions?

Contact Information:  
Michael Sanders, P.E.  
Kleinfelder  
617-498-4638  
[MSanders@Kleinfelder.com](mailto:MSanders@Kleinfelder.com)