


Facility Tour and Technical Presentation

City of Dover, New Hampshire Phase I Upgrade and MLE Conversion Pilot Program

NEWEA Specialty Conference in Dover, NH
August 24, 2016



Presented by:
Timothy R. Vadney, PE
Project Manager

WRIGHT-PIERCE 
Engineering a Better Environment

Presentation Overview


- Why Remove Nitrogen
- Nitrogen Removal Basics
- Facility Planning and Phase I Upgrade
- Modified Ludzack-Ettinger Pilot Program
 - § Pilot Program Background
 - § Nitrogen Removal
 - § Construction
 - § Preliminary Results
- Questions

Why are nutrients an issue in the environment?


- Stimulates algae and plant growth
- Creates dissolved oxygen issues
- P – limiting fresh water nutrient
- N – limiting marine water nutrient



Effects of Nutrients in Receiving Waters



Effects of Nutrients in Receiving Waters



How Much Estuary Nitrogen is Too Much?

- Typical threshold nitrogen concentration
~ **0.2 to 0.5 ppm**
- Governed by:
 - dissolved oxygen
 - Eelgrass
 - habitat protection
 - hydrodynamics



Algal Impact on Water Clarity



Algal Impact On Water Clarity



PART I

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

1. During the period beginning on the effective date and lasting through the expiration date, the permittee is authorized to discharge from Outfall Serial Number 001 treated domestic, commercial, and industrial wastewater effluent to the Piscataqua River. Such discharges shall be limited and monitored by the permittee as specified below. Samples taken in compliance with the monitoring requirements specified below shall be taken at end of all processes, including disinfection, or at an alternative representative location approved by the EPA and NHDES-WD.

Effluent Parameter	Effluent Limit			Monitoring Requirement	
	Average Monthly	Average Weekly	Maximum Daily	Frequency	Sample Type
Flow, MGD	Report	---	Report	Continuous	Recorder ¹
BOD ₅ ; mg/l (lb/d)	30 (1136)	45 (1764)	50 (1960)	2/Week ²	24 Hour Composite
TSS; mg/l (lb/d)	Total Ammonia Nitrogen⁹; mg/l Total Kjeldahl Nitrogen⁹; mg/l Total Nitrate/Nitrite Nitrogen⁹; mg/l Total Nitrogen⁹; mg/l (lb/d) (Applicable April 1 through October 31)			Report	24 Hour Composite
pH Range ³ ; Standard U				Report	Grab
Fecal Coliform ^{3,4,7} ; color				Report	Grab
Enterococci Bacteria ^{3,4,8}				Report	Grab
Total Residual Chlorine				3.0 (118)	Grab
Total Ammonia Nitrogen	Total Ammonia Nitrogen⁹; mg/l Total Kjeldahl Nitrogen⁹; mg/l Total Nitrate/Nitrite Nitrogen⁹; mg/l Total Nitrogen⁹; mg/l (lb/d) (Applicable April 1 through October 31)			Report	24 Hour Composite
Total Kjeldahl Nitrogen				Report	24 Hour Composite
Total Nitrate/Nitrite Nit				Report	24 Hour Composite
Total Nitrogen ⁹ ; mg/l (lb				Report	24 Hour Composite
(Applicable April 1 thro				Report	24 Hour Composite
Total Ammonia Nitrogen	Total Ammonia Nitrogen⁹; mg/l Total Kjeldahl Nitrogen⁹; mg/l Total Nitrate/Nitrite Nitrogen⁹; mg/l Total Nitrogen⁹; mg/l (lb/d) (Applicable November 1 through March 31)			Report	24 Hour Composite
Total Kjeldahl Nitrogen				Report	24 Hour Composite
Total Nitrate/Nitrite Nit				Report	24 Hour Composite
Total Nitrogen ⁹ ; mg/l (lb/d)				Report	24 Hour Composite
(Applicable November 1 through March 31)				Report	24 Hour Composite
Whole Effluent Toxicity					
LC50 ^{10,11,12} ; Percent Effluent	---	---	100	1/Year	24 Hour Composite
Total Recoverable Aluminum ¹³ ; mg/l	---	---	Report	1/Year	24 Hour Composite
Total Recoverable Cadmium ¹³ ; mg/l	---	---	Report	1/Year	24 Hour Composite
Total Recoverable Chromium ¹³ ; mg/l	---	---	Report	1/Year	24 Hour Composite
Total Recoverable Copper ¹³ ; mg/l	---	---	Report	1/Year	24 Hour Composite
Total Recoverable Lead ¹³ ; mg/l	---	---	Report	1/Year	24 Hour Composite
Total Recoverable Nickel ¹³ ; mg/l	---	---	Report	1/Year	24 Hour Composite
Total Recoverable Zinc ¹³ ; mg/l	---	---	Report	1/Year	24 Hour Composite

DRAFT

Forms of Nitrogen

- Ammonia-N
§ NH_3 , NH_4^+
- Organic Nitrogen
- Nitrite (NO_2)
- Nitrate (NO_3)

Forms of Nitrogen

Total Kjeldahl Nitrogen (TKN)

- Ammonia-N
§ NH_3 , NH_4^+
- Organic Nitrogen
- Nitrite (NO_2)
- Nitrate (NO_3)

Forms of Nitrogen

Total Nitrogen (TN)

- Ammonia-N
§ NH_3 , NH_4^+
- Organic Nitrogen
- Nitrite (NO_2)
- Nitrate (NO_3)

Forms of Nitrogen


Total Inorganic Nitrogen (TIN)

- Ammonia-N
§ NH_3 , NH_4^+
- Nitrite (NO_2)
- Nitrate (NO_3)
- Organic Nitrogen


Typical Nitrogen Wastewater Concentration

		% removal
Typical influent sewage	40 ppm	
Typical secondary effluent	32 ppm	20%
Level 1-N removal	8 ppm	80%
Level 2-N removal	5 ppm	87.5%
Level 3-N removal	3 ppm	92.5%

Conventional Activated Sludge




How to Upgrade for Ammonia Removal




How to Upgrade for Ammonia Removal

$\text{NH}_3 \rightarrow \text{NO}_2 \rightarrow \text{NO}_3$




How to Upgrade for TN Removal MLE Process




How to Upgrade for TN Removal MLE Process

$\text{NH}_3 \rightarrow \text{NO}_2 \rightarrow \text{NO}_3 \rightarrow \text{N}_2 + \text{O}_2$




How to Upgrade for Higher TN Removal (3 to 5 mg/1TN)

Four-Stage Bardenpho Process



Alternative Approach to TN Limits (3 to 5 mg/1 Range)


MLE Process Coupled with Denitrification Filter



Nitrogen Removal


3-Step Process:

- Ammonification:
 - § urea & organic N \rightarrow $\text{NH}_4\text{-N}$
- Nitrification (aerobic)
 - § $\text{NH}_4\text{-N} + \text{O}_2 \rightarrow \text{NO}_3\text{-N}$
 - § *Autotrophic bacteria*
 - § -4.57 mg/L O_2 (consumption)
 - § -7.14 mg/L Alk (consumption)
- Denitrification (anoxic)
 - § $\text{NO}_3\text{-N} \rightarrow \text{N}_2$
 - § *facultative bacteria*
 - § +3.57 mg/L Alk (gain)
 - § +2.86 mg/L O_2 (credit)



SRT/Nitrification

Impact on O_2 Demand



Nitrification Requirements

Parameter	BOD Removal	Nitrification
MCRT (days)	0.5 – 1.0	4 – 15
DO (mg/L)	> 0.5	> 2.0 (optimal)
Temperature (°C)	> 0	25 (optimal)
pH	5 – 9	6.5 – 8 (optimal) More alkalinity

Requirements for Denitrification

- Need nitrate to be formed
 - § Nitrate is formed during nitrification
 - § As long as system is nitrifying, this criterion is met
- Need “denit” or anoxic zone in system:
 - § Nitrate
 - § Bacteria
 - § Substrate (Food/BOD)
 - § No oxygen, but mixing to retain biomass in suspension

Conditions in the Anoxic Zone

- DO less than 0.3 mg/l
 - § No aeration
 - § Low aeration
 - § Cyclical aeration
- Carbon source
 - § Primary effluent
 - § Endogenous
 - § Methanol or other chemicals
- Mixing
 - § Pulsed or cycled air
 - § Submersible mixers
 - § Vertical mixers

City of Dover


- Great Bay Issues
- Pending TN Limit
- Facility Planning Efforts




Project Overview

- Wastewater Facilities Plan
 - § Equipment Assessment
 - § Building System Assessment
 - § Alternatives for removing TN
- Prioritized Improvements
 - § Phase I Upgrade
 - § Pilot Program to lower effluent TN

Phase I Upgrade



Primary Sedimentation Basins/ Primary Gallery




Project Overview

Primary Sedimentation Basins/ Primary Gallery

- H_2S resistant coatings
- Chain + Flight mechanisms
- Primary sludge pumps, grinder, actuated valves
- Channel air blowers



Septage/ Scum Tanks




Project Overview

Septage/ Scum Tanks

- Septage pumps
- Septage blowers
- Radar level instruments
- H₂S resistant coatings
- New hatches



Aeration Basins/ Aeration, Electrical, and Control Building



Project Overview

Aeration Basins/ Aeration, Electrical, and Control Building



Secondary Distribution Structure




Project Overview

Secondary Distribution Structure



Secondary Clarifiers




Project Overview

Secondary Clarifiers

- SS suction header mechanisms
- Full radius skimmer arm
- Walkway, platform
- Algae sweeps
- Density current baffles
- Concrete coating of launders



Process Building



Project Overview

Process Building


- RAS pumps
- WAS pumps
- Valves, flow meters
- Polymer system
- Hypochlorite system
- Potassium permanganate pumps



[illegible]

Project Overview

Odor Control Systems



Project Overview

Yard Waste Pump Station




Project Overview

Yard Waste Pump Station



Project Overview

Administration Building



Project Overview

Administration Building



- Boilers
- HVAC
- Roofs
- Floors
- Ceilings
- Laboratory
- SCADA



Modified Ludzack-Ettinger Pilot Program Background


- Pending effluent total nitrogen limits
- Influent sampling program and Biowin modeling
- Reviewed / analyzed BNR processes and technologies
- Selected Modified Ludzack-Ettinger process
- Goal: seasonal average effluent Total Nitrogen < 8 mg/L

Modified Ludzack-Ettinger Nitrogen Removal





Modified Ludzack-Ettinger Construction







—x— Total Nitrogen - - - Flow returned to AT3/4 Effluent Total Nitrogen Goal, 8 mg/L


Modified Ludzack-Ettinger Nitrogen Removal – Preliminary Results

- Goal: effluent Total Nitrogen < 8 mg/L

Conventional		MLE Process	
Sample Date	Total Nitrogen (mg/L)	Sample Date	Total Nitrogen (mg/L)
August 13, 2014	25	August 12, 2015	< 4.0*
September 10, 2014	26	September 9, 2015	< 4.0*
October 8, 2014	27	October 15, 2015	< 4.0*
November 12, 2014	27	November 10, 2015	< 4.0*

* Result below reporting limit

Questions



Thank you!