



Elizabeth Taglieri, P.E.
Alexandra T. Doody, P.E.

January 25, 2017

Breathing New Life into Existing Assets

Full-Scale Performance Results for Cloth Media Filters to Meet 0.1 mg/L TP



**CDM
Smith.**

NEWEA – 2017 Annual Conference & Exhibit



Overview


- Background
 - Charles River Pollution Control District (CRPCD)
 - WWTF Overview
 - Effluent Permit History
- Phase C Improvements Project
 - Phosphorus Removal Study/Design
 - Liquid Process Flow Diagram
 - Filter Retrofits
- Filter System Performance Testing
 - Performance Guarantee
 - Test Set-Up
 - Test Results





Background


Charles River Pollution Control District (CRPCD)



- Serves over 40,000 people in Franklin, Medway, Millis, Bellingham
- 13 miles of interceptor and 1 pumping station
- WWTF discharges to upper reach of Charles River in Medway

WWTF Overview

- Design ADF: 5.7 MGD
- Current ADF: 4.5 MGD
- Built in 1978-1980
- Upgraded 1998-2000
- Upgraded again 2011-2016, including facilities highlighted



NPDES Effluent Permit History for Phosphorus and Metals



Parameter	2002 Permit	2014 Permit
Notes	Issued in 2000; Modified in 2002	TMDL Finalized in 2011 Draft Issued in 2012; Final in 2014
Apr-Oct Total P	0.2 mg/L monthly average	0.1 mg/L monthly average
Nov-Mar Total P	Report 1x/month	0.3 mg/L monthly average
Total Aluminum	Report 1x/month	Eliminated from permit
Total Copper	10 µg/L monthly average	13 µg/L monthly average



WWTF Improvements – Phase C

Phosphorus Removal Study and Design

- **AquaDisk pilot study (May 2011):**
 1. 5 micron cloth can meet 0.1 mg/L
 2. Dedicated rapid mix/flocculation tankage not required

→ **Retrofit of existing filters was most cost-effective tertiary treatment alternative**

- **Facilities planning, BioWin modeling, and final design (2012-2013):**
 1. Chemical savings of A/O process, particularly in winter
 2. Able to operate in A/O year-round for at least 10 years


→ **Retrofit aeration tanks into A/O process with anaerobic/aerobic swing zones**



A/O Process Design:

- Bioselector = anaerobic
- First stage each tank = anaerobic swing zone
- Total anaerobic = 31-36% of total volume

Liquid Treatment Process Flow Diagram



Filter System Retrofits: Key Design Features

- **Filters equipped with 5 micron polyester pile cloth (chlorine-resistant)**
 - 1 AquaDiamond filter conversion
 - 4 AquaDisk filters rehabilitated
- **Cleaning/housekeeping features:**
 - Algae sweeps added to secondary clarifiers
 - Density current baffles in secondary clarifiers
 - Sodium hypochlorite for cleaning organic foulants, including algae
 - Sodium hydrosulfite batch cleaning of Fe³⁺ solids
 - Dehumidification for filter buildings

- **New instruments**


- Vacuum alarm on AquaDiamond filter
- Ultralow range phosphate analyzer in secondary effluent
- Turbidimeter in tertiary effluent



Source:
*Aqua-Aerobic
Systems
Bench-Scale
Evaluation of
Used AquaDisk
Filter Media for
CRPCD
(May 2011)*

Filter System Retrofits: AquaDiamond Filter

- 1 of 2 traveling bridge sand filters converted to AquaDiamond cloth filter
- Design data:
 - 60 ft long laterals
 - 1,920 sf filtration area
 - 3.25 gpm/sf = 9 mgd rated average
 - 6.5 gpm/sf = 18 mgd rated peak



Filter System Retrofits: AquaDisk Filters

- 4 disk filters
- Design data, each filter:
 - 12 disks
 - 646 sf filtration area
 - 3.25 gpm/sf = 3 mgd rated average
 - 6.5 gpm/sf = 6 mgd rated peak
- Each filter was inspected and mechanical components repaired by manufacturer
- New submersible pressure transducers






Filter System Performance Testing

Performance Guarantee and Performance Testing

- **Performance guarantee to meet 0.1 mg/L TP contingent on District providing secondary effluent of certain quality:**
 - < 0.30 mg/L TP
 - < 0.03 mg/L sNRP
 - Low PO₄-P (generally < 0.06 mg/L)
- **Manufacturer guaranteed:**
 - Average effluent < 0.10 mg/L TP
 - Suitable performance with peak hydraulic loading rates
 - Backwash rate < 5% of forward flow
- **Objectives of 30-day filter performance test:**
 1. Verify each filter type individually and operating together can meet the effluent quality guaranteed
 2. Provide manufacturer time on-site operating system before turning system over to District


Performance Test Sample Locations and Analytes



Analytes Sampled:

- TSS
- Total P
- Dissolved P
- PO₄-P

Soluble Non-Reactive Phosphorus (sNRP)



* Note: fractions shown are typical for Raw Wastewater

For the CRPCD Filter Performance test:

Final Effluent sNRP = (Filtered TP) – (Filtered PO₄-P)

Performance Test Scenarios




Five of eight diamond laterals at influent end of tank

Duration	Test Condition	GPM/SF
Days 1-7	AquaDiamond (no blankoff) + 1 AquaDisk	1.4 – 2.1
Days 8-10	AquaDisk (2 in service)	2.4 – 3.6
Days 11-13	AquaDiamond (with blankoff) + 1 AquaDisk	3.0 – 4.3
Days 14-16	AquaDiamond only (with blankoff)	4.2 – 5.4
Days 17-29	AquaDiamond (with blankoff) + 1 AquaDisk	2.1 – 4.3
Day 30	AquaDisk only (1-2 in service)	5.0 – 6.2

Note: Hydraulic stress test loading rates shown in pink


Effluent Phosphorus Results: All Data

**30-day average TP =
0.085 – 0.090 mg/L**



Effluent Phosphorus Results: Graded Results Only


30-day average TP =
0.067 – 0.075 mg/L



Backwash as % of Forward Flow

Filter System	Average During Days 1-7 (Typical Hydraulic Loading)	Maximum During 30-Day Test
AquaDiamond	0.4%	1.5% (with blankoff plates)
AquaDisk	0.2%	0.4%

Final Effluent Before vs. After Phase C Improvements: Monthly Average Performance



Final Effluent TSS :

- Historical average = 4-6 mg/L
- 2016 average = 1.4 mg/L

Conclusions

1. CRPCD achieving 0.10 mg/L monthly average TP limit using cloth filters equipped with 5 micron cloth

- Without dedicated rapid mix/flocculation
- With proper cleaning to maintain hydraulic throughput
- Backwashing frequency has not increased substantially
- Maximized available assets by using existing tankage and no intermediate pumping
- Performance is robust and handles moderate process disruptions, including elevated hydraulic loading, occasional sNRP of 0.03-0.05 mg/L, and brief loss of ferric chloride

2. A/O upgrade has provided chemical savings in spite of more stringent TP limits:

- **Apr-Oct:** Ferric usage to meet 0.1 mg/L is similar to prior years when required to meet 0.2 mg/L
- **Nov-Mar:** Ferric usage may not be required to meet 0.3 mg/L, whereas in prior years without ferric effluent exceeded 0.3 mg/L

Acknowledgements

■ Key Project Participants

- CRPCD
Cheri Cousens (GLSD), Bob McRae
- CDM Smith
Jane Madden
Elena Proakis (City of Melrose)
- Aqua-Aerobic Systems
Paul Klebs, Daniel Lockhart
- Daniel O'Connells Sons
Greg Waugh



■ Co-Authors

Kristen Mucciarone
CRPCD Engineer/IPP Coordinator

Maureen Neville
CDM Smith Principal Engineer/Process Lead

Contact us!




Alexandra Doody

CDM Smith

617-452-6641

DoodyAT@cdmsmith.com

Find more insights through
our water partnership
at cdmsmith.com/water and
[@CDMSmith](https://twitter.com/CDMSmith)



Liz Taglieri

Charles River Pollution
Control District

LTaglieri.crpdc@verizon.net