The Main Interceptor Project: An Engineered Approach to Innovative Pipeline Rehabilitation

Springfield Water and Sewer Commission Springfield, Massachusetts

Jason Lavoie, P.E. (RI) – Kleinfelder Jonnas Jacques, P.E. – Kleinfelder Eric Morse, P.E. – MWH/Stantec





NEWEA Annual Conference January 25, 2017

Outline


- Project Planning (Jason)
 - Brief history, condition assessments and project development
- Project Design (Jonnas)
 - Rehab alternative analysis, DWF gravity bypass design
- Project Construction (*Eric*)
 - Gravity bypass construction and operation, pipeline rehabilitation
- Summary and Questions
- Project Photos

History of the Springfield Water and Sewer

- The Springfield Water and Sewer Commission was established in July 1996 to administer, operate and maintain the water and wastewater systems
- SWSC Wastewater Collection System:
 - 37,200+ Customers
 - 151 miles of Combined sewer (33%)
 - 310 miles of Separated sewer (66%)
 - 11,000 Manholes
 - 23 Combined Sewer Overflows (CSOs)
 - 33 Pump Stations



Background on Main Intercepting Sewer



Main Intercepting Sewer

- Built in the 1970s
- 7.5 miles of RCP
- 1 of 2 CT River Crossings to SRWTF
- SRWTF treats 40+ MGD
 - Designed for up to 67 MGD
 - MIS Conveys 60% of flows to SRWTF
 - Avg. DWF 25 MGD
 - 1-Year Peak 150 MGD

Condition Assessment


2009 and 2014 Multi-Sensor Inspections:

- Laser to identify deformation & corrosion above flow line
- Sonar to detect deposition & debris below flow line





Condition Assessment



a 60" pipe that was ±8" thick)

Observation Report

499.6ft General Observation - Corrosion to 0.7"

Pipeline and Manhole Condition Assessment


Exposed wire mesh cage from removed section of 60" RCP




Corrosion/Deterioration experienced throughout MIS pipeline MHs as well




Risk Evaluation – Project Prioritization




Main Interceptor Project Development



Existing Main Interceptor Flows



Replacement and Rehabilitation Methods



Trenchless Rehabilitation Design Criteria

Performance

- 50 Year Design Life
- Standalone Pipe
- Corrosion Protection
- Scour Protection


Constructability

- Overall Cost
- Work Production
- Access Requirements
- Flow Bypass Needs

	No.	Criterion	Weight (%, Totaling 100)	
Performance and other General Criteria	1	Bypass of Flow Requirements	4	
	2	Adaptability for Emergency/Wet Weather Flows	6	
	3 4 5	Durability Against Scour and High Velocities	7	
		Durability Against Corrosion	11	
		Hydraulic Performance	8	
	6	Product Pressure Rating	4	
	7 8 9	Standalone Pipe Structure	5	÷
		Host Pipe Preparation Requirements	2	Fotal Weight 55 of 100
		Permitting & Easement Impacts	3	Total We 55 of 100
	10	Previous Use of Technology in SWSC Network	5	Tota 55 c
Constructability	11	Cost	16	
	12	Constructability	12	÷
	13	Production Rate	8	eigh <u>0</u>
	14	Impact to Sewer Network Setup	3	Total Weight 45 of 100
	15	Site Impacts	6	Tota 45 c

Trenchless Alternatives Analysis

Spiral Wound Pipe (with PVC or HDPE)



Sliplining (with FRP or HDPE)



Trenchless Alternatives Analysis

Centrifugally Cast Concrete Pipe (CCCP)

Cured in Place Pipe (CIPP)






Trenchless Rehabilitation Selection

		Weighted Score (out of 1000)			
		FRP SLIP	CIPP	СССР	SPR
	P1F13	662	670	622	651
> 5	P193B	436	594	563	343
Total Constructability nd Performance Score	P213A	555	639	602	536
	P215E	618	648	622	651
Total Constructa and Performance	P217C	618	640	622	651
orn	P219B	618	648	622	651
erf C	P21B8	648	654	622	651
Tota nd F	PS16941	563	627	614	584
ar _	PS16942	560	627	619	648
	PS16943	560	627	619	648

CIPP resulted in consistently high scores in performance and constructability for every segment designated for rehabilitation


Gravity Bypass Concept Development



Gravity Bypass Field Investigations



Gravity Bypass Field Investigations




"High Point" 69-in Brick Deformation


- Laser Inspection
- Vertical change: 69" down to 51"
- Excess vertical loading
- Rock Profile may have restrained deformation
- Unsafe for manned entry

Approx. Rock Profile

Gravity Bypass Concept Development




Gravity Bypass Capacity Modeling



- Modeled Capacity: 3 Month Storm
- Flow Speed: 7-8 ft/s
- 42-in FRP Pipe at "High Point"

- Depth of Water in Pipe: 5-6 ft
- Depth to Water at Locust Overflow: 4ft
- Dickinson Catchment LOS Issues

Manhole/Structure Rehabilitation




SECTION


MANHOLE TYPE A

Design Criteria

- Structural Rehab
- Cementitious Liner
- 9000+ psi
- H₂S Admixture Protection
- Compatible with CIPP Lining
- 3 Types of MHs
 5-yr Bonded Warranty




Construction Schedule/Sequencing Requirements




•

Note: The NOAA QPF data used is valid 1AM ET (STD) on Saturday 1/21/17 thru 7AM ET (STD) on Saturday 1/21/17


Gravity Bypass Construction Issues



Gravity Bypass Construction Issues



Gravity Bypass Construction Issues



Gravity Bypass Construction Lessons Learned

- May want to perform test pits to confirm records
- Pipes CIPP lined from within open excavations should be restrained
- Take care excavating around existing brick; be prepared to chase the pipe

- Verify alignments and section lengths for sliplining operations
- Evaluate support of excavation limits
- Again, know your limits and test pit when in doubt

Gravity Bypass Diversion Structures



Locust Structure

 Whipps Stainless Steel Sluice Gates

Gravity Bypass Operations Testing and Inspection

Chester/Rifle

Overflow

- Crew of certified gate operators
- Lockout/Tagout work procedures
- Only permitted to convey DWF
- Emergency Overflows
- Gravity Bypass inspected after activations to ensure integrity



CIPP Liner Installations

Limited Inversion Length

- up to ±400 ft for a 60" pipe due to weight
- Longer inversions were possible with composite liners

Required Equipment

- Machine used to hoist liner
- Newer steam trucks
- Large staging footprints
 created impacts to traffic



CIPP Liner Installations

MH Access Constraints

- Removal of MH cones
- Possible damage to risers due to inversion pressures





MH Install/Modifications

- Installed new "doghouse" MHs to facilitate CIPP installation
- Vault structure roof slab
 modifications

CIPP Testing and Inspection

Testing of Liner

- Restrained samples preferred but difficult in larger diameters
- 20% reduction towards Flat Plate sample flexural modulus results

Inspection of Liner

- Confirm resin used, liner size, length and thickness
- Verify thickness of liner at MHs and from lateral coupons
- Obtain manufacturers
 recommendations and post installation reports



Manhole Rehabilitations



- Up to 2" of punky concrete removed
- Rebar exposed and wash of corrosion
- MH rehab scheduled around CIPP installations

Surface Prep for MH Structure Rehab

Summary

- Condition assessment identified a need for improvement
- Capitalize on the reuse or repurposing of existing infrastructure
- There will always be changes between planning, design and construction



Questions???

Thank You!

Acknowledgements

C Springfield Water and Sewer Commission:

○ Joshua Schimmel, Bill Fuqua, Bob Stoops, David Szymczakiewicz, Ryan Wingerter

C Kleinfelder:


 ○ Thomas Ritchie, Jason Lavoie, John Struzziery, Mark Chamberlain


O MWH/Stantec:

 $\ensuremath{\mathbb{C}}$ Matthew Travers, Matthew Wilson, Eric Morse














CIPP Inversion Pit



