

Increasing the Coastal Resilience of Vulnerable Wastewater Infrastructure on the Massachusetts Coast and Islands – Two Case Studies

Anastasia Rudenko | GHD

Marc Drainville | GHD

Guy Campinha | Town of Wareham, MA

July 2017



Overview


- Background
- Two Case Studies
 1. Town of Wareham
 2. Town of Oak Bluffs
- Questions




Background

Vulnerability to Coastal Storms


- Financial damages
 - FEMA: 8 out of the top 10 costliest natural disasters in the United States were caused by coastal storms
- Change in frequency and intensity of storms
 - Global sea level rise
 - Updated FEMA FIRM Maps
- Existing infrastructure not protected to newly defined flood elevations
 - Changing design standards
- Loss of service for critical infrastructure




FEMA coastal flood hazard zones/base flood elevation



Changing Storm Frequency and Intensity




- 1983 FEMA Firm Map
- Zone A10 = 15 ft MSL
- Zone B = Area between 100 yr and 500 yr flood
- Zone C = Areas outside 500 yr flood



- 2012 FEMA Firm Map
- AE Zones = 16, 17
- VE Zones = 17, 21, 22

Sea level rise projections

- NOAA sea level change projections
- 20 year projection used for all proposed mechanical improvements
- 50 year projection used for all proposed structural improvements



NOAA = National Oceanic and Atmospheric Administration

Freeboard Requirements

Previous design standard

- Design to 100 year flood elevation
- No required minimum freeboard

Updated design standards

- More stringent minimum freeboard requirements
- TR-16
 - Critical equipment = 3 ft
 - Non-critical equipment = 2 ft
- ASCE 24-14 – Flood Resistant Design and Construction, 2014
 - Referenced in Massachusetts draft 9th Building Code
 - Specifies minimum freeboard requirements based on criticality of infrastructure

Freeboard Requirements

ASCE 24-14

- **4 Flood Design Classes**

- **Flood Design Class 3 Structures**

Buildings and structures that pose a high risk to the public and a significant disruption to the community if they are unable to perform their intended function due to flooding. **ASCE 24-14 specifically includes water and sewage treatment in this category.**

- **Flood Design Class 4 Structures**

Buildings and structures that contain essential facilities and services necessary for emergency response and recovery and **ancillary structures that allow continuous functioning of a Flood Design Class 4 facility after an emergency.**

Condition		ASCE 24-14 Minimum Freeboard Requirement	
		Flood Design Class 3	Flood Design Class 4
Minimum elevation of dry flood-proofing of non-residential portions of mixed-use buildings	Zone AE	BFE + 1 foot or DFE, whichever is higher	BFE + 2 feet or DFE, or 500 year flood elevation, whichever is higher.
	Zone VE and Coastal Zone AE	Not permitted.	Not permitted.
Minimum elevation of wet flood-proofing	Zone AE, Zone VE and Coastal Zone AE	BFE + 1 foot or DFE, whichever is higher.	BFE + 2 feet or DFE, or 500 year flood elevation, whoever is higher


Source: ASCE 24-14: Flood Resistant Design and Construction

Notes:

(1) The DFE is obtained from a community adopted flood hazard map if a community has adopted a flood hazard map that depicts flood hazard areas in addition to the SFHA's shown on FEMA's FIRM maps.

Design approach – determine design flood elevation

Design Flood Elevation (DFE) =
Base Flood Elevation (BFE) + Sea Level Rise + Freeboard



Coastal Resilience Strategies



Dry Flood Proofing

- Preventing flood water from entering structure (make structure watertight)
- Reinforce structure to withstand forces of a hydrostatic flood load

Coastal Resilience Strategies




Wet Flood Proofing

- Allow flood waters to infiltration the structure
- Protect contents of building from water damage (elevate or floodproof)

Two Case Studies

Case Study 1 | Town of Wareham

- **54** miles of coastline
- **43** pump stations and **1** wastewater treatment plant
- **29** pump stations in **100** year flood zone




Town of Wareham




9

14

6






Approach

- Town needed methodology to prioritize pump station retrofits
- Risk and Vulnerability Assessment
- Assessed annual flood risk for each vulnerable station

Risk and Vulnerability Assessment

- 1 Determine Design Flood Elevations
- 2 Determine which components will be damage/ruined in 1% storm (100 year) and replacement costs
- 3 Determine estimated monetary total loss:
FEMA Benefit Cost Analysis (BCA) Software
- 4 Flood Risk (\$) = (Threat of Likelihood) x (Total Loss)





Risk and Vulnerability | Example 1

Onset Pier

- 6 pump stations dependent on Onset Pier
- Large structural load on building
- Potential erosion risk
- All equipment will be inundated in 1% storm
- Electrical eq, generator, mechanical equipment

Total Losses

- Structure
- All mechanical equipment
- Impact on upstream pump stations



Risk and Vulnerability | Example 2

Leonard Street

- No dependent pumping stations
- Minimal equipment damage
- Submersible pumps
- No ASCE 24-14 Flood Design Class 4 Infrastructure (hospitals, fire dept, police dept etc) in sewershed


Total Losses

- Minimal equipment damage



Coastal Resilience Design Phase

- **Three high priority wet pit/dry pit stations**
 - Narrows Pump Station
 - Hynes Field Pump Station
 - Cohasset Narrows Pump Station
- **All three stations serve:**
 - Multiple dependent pump stations
 - Critical Infrastructure



Priority Pump Stations




Narrows



Hynes Field





Cohasset Narrows



Priority Pump Stations

- Existing equipment not waterproof
 - Equipment damage
 - Electrical damage
- Potential structure collapse
- Dry flood proofing



Flood Proof Doors





Pedestrian Flood Door (Single)




Pedestrian Flood Door (Paired)


Flood Planks




Sealing Potential Entry Points



Waterproof Epoxy Spray System



Structural Reinforcement



Maintaining Power

- Provide enough generator fuel for:
 - 48 hours under peak flow, or
 - 96 hours under average flow
- Install 160 gal additional fuel:
 - Narrows
 - Hynes Field




Next Steps

Apply for funding for:

- Final design of priority pump stations
- Construction of emergency bypass

Case Study 2 | Town of Oak Bluffs


- Northern part of Martha's Vineyard
- **3** pump stations in vulnerable locations and **1** wastewater treatment plant



Town of Oak Bluffs



Location of existing pump stations



FEMA flood map

(location of existing pump stations)



Duke's County Avenue Pump Station

Area served by this pump station

- Largest pump station in Oak Bluffs
- Serves nearly the entire sewer population

Problems

- Codes prohibit generator to be indoors



Duke's County Avenue Pump Station

Mitigation (this project)

- Wet flood proof
- New diesel generator
 - Outdoors adjacent to the pump station building
 - On steel platform on concrete pad



Lake Avenue Pump Station

Area Served by this pump station

- Main business/commercial district in Oak Bluffs

Problems


- Generator connection point inaccessible during flood (Town has portable generator)



Lake Avenue Pump Station

Mitigation (this project)

- Wet-flood proof
- Install power conduit from Duke's County Avenue Pump Station to Lake Avenue Pump Station
 - Nearly 1000 linear feet of electrical ductbank



Next steps

Seek funding to address the long term mitigation solutions for three vulnerable pump stations

- 1 Our Market Pump Station**
Watertight hatch in submersible pump station
Install controls in an immersible enclosure (NEMA 6P)
- 2 Lake Avenue Pump Station**
Watertight hatch in submersible pump station
Mount new control panel in Duke's County Ave Pump Station
- 3 Duke's County Avenue Pump Station**
Wooden building in vulnerable location putting electrical equipment at risk



Questions?

Thank you!

anastasia.rudenko@ghd.com



marc.drainville@ghd.com



Coastal Resilience Measures


Dry Flood Proof Stations

- Structurally reinforce walls
- Flood proof doors
- Install barriers on penetrations below DFE
- Block up windows below DFE
- Apply waterproof coating to outside of building
- Emergency egress





Structural Reinforcement

- Cohasset Narrows
 - Reinforced masonry walls
 - Carbon Reinforcing Strips



Returning to Operation if Station Goes Down



Emergency Bypass Connection

