

Testing Add-On Phosphorus Removal Processes at Upper Blackstone to Balance Low-Level Phosphorus *and* Metals Permit Limits

Alexandra Bowen, P.E.
Maureen Neville, P.E.
Karla Sangrey, P.E.
Erik Grotton, P.E.

January 23, 2018



**CDM
Smith**



NEWEA – 2018 Annual Conference & Exhibit



Upper Blackstone Wastewater Treatment Facility



- Serves 250,000 people in central Massachusetts, including the City of Worcester
- Discharges into the Blackstone River which ultimately flows to the Narragansett Bay
- Designed for 45 mgd ADF and 160 mgd peak hour; 30 mgd current ADF
- Regional biosolids facility

Upper Blackstone's NPDES Permit Limits


Constituent	2012 Permit
Total Nitrogen (mg/L) – Monthly average	5.0
Total Phosphorus (mg/L) –60-day rolling average	
April-October	0.10
November-March	1.0
Aluminum (µg/L)	87
Cadmium (µg/L)	
Average Monthly	0.2
Maximum Day	1.5
Copper (µg/L)	
Average Monthly	7.2
Max Day	10.2
Zinc (µg/L)	91.3
Lead and Nickel (µg/L)	Report

Narragansett Bay


Blackstone River

- Currently operating under interim limits:
 - TN of 6 mg/L
 - TP of 0.45 mg/L
- Typically achieve:
 - TN of ≈ 4.8 mg/L
 - TP of ≈ 0.25 mg/L
- Meet metals limits but not TP limit

Current Anaerobic/Anoxic/Oxic (A²/O) Process Configuration:




Proposed Process Configuration to Achieve TP Compliance:



Which coagulant?

Which add-on process?

Steps Toward Achieving 2012 TP Permit Limit




Coagulants Bench-Tested:

Aluminum-Based	Alum (Aluminum Sulfate) Al^{3+} $\approx 4.4\% \text{ Al}$
	PACl (Polyaluminum Chloride) Al^{3+} $\approx 5.6\% \text{ Al}$
	ACH (Aluminum Chloride Hydrate) Al^{3+} $\approx 12.4\% \text{ Al}$
Iron-Based	Ferric Chloride Fe^{3+} $\approx 13.5\% \text{ Fe}$
	Ferric Sulfate Fe^{3+} $\approx 13.1\% \text{ Fe}$
Rare Earth	RE-100 (Cerium Chloride) Ce^{3+} $\approx 17.9\% \text{ Ce}$

Polymer Bench-Tested:

MetClear™ 2405
(Sulfide-Based Polymer)
Anionic Polymer



Chemicals Tested on the Pilot-Scale:

Alum (Aluminum Sulfate)
 Al^{3+}
 $\approx 4.4\% \text{ Al}$

Ferric Chloride
 Fe^{3+}
 $\approx 13.5\% \text{ Fe}$

RE-100 (Cerium Chloride)
 Ce^{3+}
 $\approx 17.9\% \text{ Ce}$

MetClear 2405
(Sulfide-Based Polymer)
Anionic Polymer

Key Bench-Scale Conclusions

- No pH adjustment required with alum, ferric chloride, and RE-100
- MetClear™ 2405 was able to reduce heavy metal concentrations
 - Copper by >50%
 - Cadmium by 30%

Alum

- Most effective at pH <7
- Molar Ratio- 5:1 (9 mg/L)
- \$34,000/year
 - Least expensive coagulant
- Increases Al concentrations


Ferric Chloride

- Little impact of pH
- Molar Ratio- 5:1 (5 mg/L)
- \$49,000/year
 - Second least expensive coagulant
- Increases Cu concentrations

RE-100

- Molar Ratio- 2:1 (3 mg/L)
- \$286,000/year
 - Higher cost could be offset by savings attributed to low residuals/solids handling
- No impact on metals

Steps Toward Achieving 2012 TP Permit Limit




Phosphorus Removal Technologies Piloted



ACTIFLO® - *Ballasted Flocculation with Microsand, by Kruger Inc.*



CoMag® - *Ballasted Flocculation with Magnetite, by Evoqua Water Technologies*




Aqua MegaDisk® - *Rotating Cloth Filters, by Aqua-Aerobic Systems, Inc.*

Experimental Approach

August 16 to October 29, 2016

Pilot Influent Condition	Description	Effluent TP Target	
		0.10 mg/L	0.05 mg/L
1.00 mg/L TP	Design max month and day	Trials 1 & 3	Trial 2
0.30 mg/L TP	Average secondary effluent 2013-2015 ¹	Trial 4	Trial 5
30 mg/L TSS	Potential clarifier upset condition/BNR upset condition	Trial 6	Trial 7
1.00 mg/L TP	Metclear™ polymer addition for metals removal	Trial 8	
0.1-0.2 mg/L TP	Hydraulic loading (20 MGD to 120 MGD)	Trial 9	
0.1-0.2 mg/L TP	Existing secondary effluent	Trial 10	
0.3 mg/L TP	Additional tests for individual manufacturers	Trial 11	

1. The 95% confidence interval on the mean was selected to represent the average TP into the tertiary system. The actual average of secondary effluent from 2013-2015 was 0.22 mg/L.




Pilot-Scale Metals Removal Performance:


- No statistically significant difference of metals removal between technologies
- **Coagulant** used did have an impact

Metal (µg/L)	NPDES Limit	Mean ± standard deviation (min – max)		
		Alum [n=25]	Ferric Chloride [n=34]	RE-100 [n=32]
Aluminum	87 µg/L	164 ± 1 (66 – 381)	8 ± 5 (ND {1.69} – 26)	17 ± 26 (7 – 155)
Cadmium	0.2 µg/L	0.24 ± 0.10 (0.07 – 0.43)	0.27 ± 0.09 (0.10 – 0.45)	0.27 ± 0.07 (0.16 – 0.46)
Copper	7.2 µg/L	2.5 ± 0.5 (1.6 – 3.7)	5.7 ± 1.3 (2.6 – 8.1)	2.9 ± 1.0 (1.6 – 7.3)
Lead	None (report)	0.31 ± 0.05 (0.22 – 0.35)	0.34 ± 0.05 (0.24 – 0.45)	0.34 ± 0.08 (0.13 – 0.55)
Nickel	None (report)	3.6 ± 0.77 (2.3 – 5.2)	6.2 ± 2.2 (3.4 – 12)	3.5 ± 0.87 (1.9 – 5.8)
Zinc	91.3 µg/L	35 ± 9 (18 – 54)	38 ± 9 (25 – 55)	37 ± 8 (28 – 64)

Coagulant vs. Coagulant: Pilot Scale Resultant Aluminum Concentrations




Coagulant vs. Coagulant: Resultant **Copper** Concentrations



Ferric was considered to be a viable coagulant for Upper Blackstone.

Effectiveness of Sulfide-Based Polymer (MetClear™ 2405)


Results from all 3 Pilot Technologies



Phosphorus Removal Performance:

Effluent Goal=0.10 mg/L TP

Influent TP Concentrations:
Trial 3: 1.0 mg/L TP
Trial 4: 0.3 mg/L TP
Trial 10: 0.1-0.2 mg/L TP




Chemical Dosage Summary:

Effluent Goal=0.10 mg/L TP

Bolded= Influent 0.30 mg/L TP
(Italics Range)=Min-Max


System	Coagulant Dose (mg/L)	Polymer Dose (mg/L)	Effluent TP Achieved (mg/L)
Ferric Chloride			
ACTIFLO	10.4 <i>(7.71-24.0)</i>	0.30 <i>(0.25-0.45)</i>	0.056 <i>(0.037-0.058)</i>
CoMag	10.9 <i>(4.92-20.3)</i>	0.79 <i>(0.80-0.99)</i>	0.057 <i>(0.048-0.058)</i>
MegaDisk	6.87 <i>(1.91-20.3)</i>	0.90 <i>(0.79-0.90)</i>	0.056 <i>(0.044-0.058)</i>
RE-100			
ACTIFLO	11.0 <i>(8.89-19.9)</i>	0.40 <i>(0.40-0.51)</i>	0.058 <i>(0.048-0.058)</i>
CoMag	5.66 <i>(4.98-12.0)</i>	0.80 <i>(0.81-1.39)</i>	0.061 <i>(0.064-0.70)</i>
MegaDisk	3.59 <i>(1.01-10.9)</i>	0.90 <i>(0.75-1.0)</i>	0.048 <i>(0.030-0.050)</i>



Phosphorus Removal Performance:

Effluent Goal=0.05 mg/L TP

Influent TP Concentrations:
Trial 2: 1.0 mg/L TP
Trial 5: 0.3 mg/L TP




Chemical Dosage Summary:

Effluent Goal=0.05 mg/L TP

Bolded= Influent 0.30 mg/L TP

System	Coagulant Dose (mg/L)	Polymer dose (mg/L)	Effluent TP Achieved (mg/L)
Ferric Chloride			
ACTIFLO	19.9 (up to 53.0)	0.29 (up to 0.33)	0.04 (0.02)
CoMag	19.2 (up to 48.5)	0.79 (up to 0.80)	0.03 (0.03)
MegaDisk	8.9	0.89	0.03
RE-100			
ACTIFLO	20.4 (up to 53.7)	0.80 (up to 0.91)	0.045 (0.031-0.056)
CoMag	24.6 (up to 33.7)	1.32 (up to 0.79)	0.033 (0.043)
MegaDisk	4.9 (up to 15.4)	0.90 (up to 1.60)	0.031 (0.039)




Phosphorus Removal Evaluation: Preferred Coagulant

- Each system performs better with one coagulant over the other
 - Lower chemical doses
 - Decreased maintenance
 - Less sludge production
- Preferred coagulant based on pilot performance is:
 - ACTIFLO: ferric chloride;
 - CoMag: ferric chloride;
 - MegaDisk: RE-100

Phosphorus Removal Full-Scale Evaluation: Economic Evaluation

	Add-On Systems for Tertiary Phosphorus Removal		
	ACTIFLO + Ferric Chloride	CoMag + Ferric Chloride	MegaDisk + RE-100
Estimated Relative Capital Costs	\$47,000,000	\$45,000,000	\$33,000,000
Estimated Annual O&M Costs	\$800,000	\$800,000	\$1,000,000
Present Worth of 20-Year Life Cycle Costs	\$57,000,000	\$52,000,000	\$50,000,000

Non-Economic Criteria ACTIFLO

A blue hexagon with a thin white border, containing the text 'Numerous large (>30 mgd) installations' in black.

Numerous
large
(>30 mgd)
installations

**Success at
Other
installations**

Key Pilot Conclusions

- All systems were capable of achieving the 0.10 and 0.05 mg/L effluent TP objective
- Dosing alum resulted in effluent aluminum exceedances
- Sulfide-based polymer effective in removing Cu, Cd, & Ni (not Al)
- Each technologies achieved the TP goals & with metals limits while dosing FeCl_3 and RE-100
 - FeCl_3 dose must be controlled to avoid elevated Cu
- Ballasted flocculation processes required higher RE-100 doses than cloth filters (absence of hydroxide floc!)
- Non-economic factors were the primary differentiator between systems
 - ACTIFLO with ferric chloride received the highest non-economic score, mainly due to its success at other similarly sized installations

Acknowledgements



Karla Sangrey, P.E. *Engineer Director/Treasurer*
Engineering: **Mark Johnson, P.E. & Randy Komssi**
Plant Operations: **Mike Foisy & Joe Nowak**

Erik Grotton, P.E.
George Swedberg
& Fred Lusky

Blueleaf Incorporated

Pilot Testing for Water and Wastewater Treatment



Maureen Neville, P.E.
William Dana Green, P.E.





Contact us!



Water
Partnership
with **CDM
Smith**

Alexandra Bowen

BowenAB@cdmsmith.com

Maureen Neville

NevilleMD@cdmsmith.com

Find more insights through our water partnership
at cdmsmith.com/water and @CDMSmith



Contact us!



Water
Partnership
with **CDM
Smith**

Joe Smith

555-555-5555

email@cdmsmith.com

@TwitterAccount

Find more insights through our water partnership
at cdmsmith.com/water and @CDMSmith

Contact us!



Joe Smith
CDM Smith
555-555-5555
email@cdmsmith.com
@TwitterAccount


Mary Smith
City of _____
555-555-5555
email@city.ma.us
@TwitterAccount

Find more insights through our water partnership
at cdmsmith.com/water and @CDMSmith

Response Surface Testing Approach:


Evaluates the effect of two independent variables on a dependent variable, when two independent variables interact

pH x Coagulant Dose





Alum

(Aluminum Sulfate)



- Achieved TP objective at all molar ratios
 - 9-28 mg/L as Alum
- Most effective at pH < 7.0
 - Can be mitigated by higher alum doses
- Molar Ratio=5:1


Ferric Chloride



- Achieved TP objective at all molar ratios tested
 - 5-15 mg/L as Ferric Chloride
- Little effect from pH
- Molar Ratio=5:1
 - Similar to Alum

RE-100

(Cerium Chloride)



- Achieved TP objective at molar ratios >2:1
 - 3 mg/L RE-100
- Molar Ratio=2:1
 - The lowest molar ratio of all coagulants

Summary of Tertiary “Solids” Analyses

- Evaluate impact on existing solids handling facilities of chemical “sludge” produced from the tertiary systems
 - Quantity and quality of residuals
- Komline-Sanderson Engineering Corporation
 - Thickened sludge for thickening evaluation
 - Kompress® Belt Filter Press
 - Simulate full-scale Kompress® G-GRSLX Series III
 - Gravity belt drainage and pressure belt drainage
- Alfa Laval Incorporated
 - Unthickened sludge for dewatering evaluation
 - Thickened sludge for thickening evaluation
 - Centrifuge
 - 3 Belt Klampress
 - Extended Klampress



Summary of Tertiary “Solids” Analyses

Influent TP=0.3 mg/L TP (~secondary effluent)

System	Waste Rate (% of Forward Flow)	TSS of Unthickened Samples (mg/L) ¹	TS of Pre-Thickened Samples		Cake Solids Range (%)	
			Alfa Laval	Komline	Alfa Laval	Komline
Ferric Chloride						
ACTIFLO	3.8%	NA ²	0.83	0.77	17-20	15-16
CoMag	1.0%	770	1.4	0.81	20-23	21-22
MegaDisk	8.8%	58	0.43	0.63	18-22	11-14
RE-100						
ACTIFLO	4.4%	338	1.76	2.88	36-39	26-33
CoMag	0.8%	860	1.49	1.22	24-27	21-23
MegaDisk	9.3%	60	NA ³	NA ³	NA ³	NA ³

Notes:

1. Minimum solids concentration for testing for thickening and dewatering was 0.3% (3,000 mg/L).
2. Sample did not survive transport, no TSS analysis was completed.
3. Not enough solids generated to collect the required sample volume (4 L).