

CSO Plan Optimization Using SWMM

Paul Ferland
Nancy Beaton, PE, BCEE
Eilish Corey, PE, ENV SP


January 23, 2018



**CDM
Smith**

Background

- Federal Court Order – CSO Control
- EPA Administrative Order – CMOM and SSO Control
- \$190M+ on CSO controls to date
 - WWTF wet-weather upgrade
 - CSO Storage Tunnel
 - Two CSO screening and disinfection facilities
 - Two pumping station upgrades
 - Quequechan Interceptor



What Needs to be Done?

- 75% CSO reduction, but more control required in some areas
 - Address uncontrolled CSO Discharges (Alton Street/City Pier)
 - Additional CSO control (tunnel to shoreline)
- Accommodate potential future sanitary flows
- Address street flooding, SSOs, general infrastructure condition

Annual Average Overflow Statistics – Typical Year

CSO Outfall	1994 ⁽¹⁾		2017	
	Number of Events	CSO Volume (MG)	Number of Events	CSO Volume (MG)
North System (Taunton River)				
Alton Street	39	118	44	48
Cove Street (untreated)	43	136	4	16
President Avenue (untreated)	51	87	2	5
City Pier	53	93	53	94
Central System (Quequechan River)				
Quequechan Street	6	2	2	7
Lowell Street	28	29	2	17
Plymouth Avenue North	43	59	2	6
Plymouth Avenue South	blocked	0	sealed	0
Third Street	58	95	1	0.1
Central Street	32	24	4	0.6
Heritage Park	blocked	0	blocked	0
South System (Mt. Hope Bay)				
Canal Street	48	67	35	8
Ferry Street	84	261	49	34
William Street	4	1	2	2
Middle Street	67	53	15	14
Riverview Street	38	155	23	15
Birch Street	25	62	53	31
Charles Street	20	9	2	2
Mt. Hope Avenue	23	44	31	18
Total	662	1294	324	318

⁽¹⁾ from Combined Sewer Overflow Abatement Program Final Environmental Impact Report (CH2MHill/PBG&S Team, 1994)


CSO Facilities Plan – Goals

- Control 3-month storm CSOs to meet federal court order requirements
- Incorporate Integrated Master Plan recommendations
 - CSO Control
 - Infrastructure Renewal (CMOM/SSO)
- Optimize recommended improvements to minimize costs
- Create shovel-ready implementation plan




Goal Implementation

- Data Collection
 - CDM Smith's Water Analytics
 - Flow monitoring
 - Detailed aerial survey
 - GIS/Asset Inventory
 - Workshops with City
- Updating SWMM Model
 - Confirming record drawing information
 - Calibration with flow monitoring and other data
- Alternatives Development and Assessment



SWMM Model

- **Model Verification**
 - Confirm configuration with record drawings
 - Data from CDM Smith's Water Analytics and other sources
 - Compare model vs. real-time data
- **Calibration Results**
 - Good correlation with real-time statistics
 - Interceptor and pumping stations control in North System
 - CSO Tunnel provides required level of control for Central and upstream portions of South System
 - Limited additional control required for downstream portion of the South System



SWMM Model

- Use in alternatives development
 - Quickly assess impacts and benefits
 - Provides global system overview
- Lower-cost improvements
 - Cleaning Interceptor of debris
 - Raising regulator weirs
 - Limited infrastructure upgrades
- Infiltration removal ineffective
- Sewer Separation
- Additional Controls
 - Wet-weather Storage
 - Wet-weather/relief sewers
 - Additional pumping capacity
 - Increased pipe capacity

CSO Outfall	Lower-cost Improvements	Infiltration Removal	Sewer Separation	Storage	Wet-weather/ Relief Sewers	Additional Pumping	Increased Pipe Capacity
North System (Taunton River)							
Alton Street	P	X	P	P	P	P	P
Cove Street	*** TREATED ***						
President Avenue	*** TREATED ***						
City Pier	X	X	P	P	P	P	P
South System (Mt. Hope Bay)							
Ferry Street	✓	X					
William Street	✓	X					
Middle Street	✓	X					
Riverview Street	✓	X					
Birch Street	P	X	P	P	P		P
Charles Street	✓	X					
Mt. Hope Avenue	✓	X					

Legend



Yes




No



Partial


South System

- Modeled Conditions
 - Interceptor cleaning
- Improvements Needed
 - Raise weirs at Mt. Hope Ave., Birch St. and Columbia St. regulators to optimize interceptor HGL
 - Larger interceptor connection or minimal sewer separation at Birch St.
 - Sewer separation at Middle St. to address existing flooding issue
- Anticipated Benefits
 - Minimal capital improvements to meet 3-month storm control
 - Increase in Interceptor storage capacity




South System


- Minimal work needed



Before




After




South System, continued

- Interceptor cleaning
- Minimal additional work needed



66" Interceptor
(7-8" sediment)

60" Interceptor
(8-23" sediment)




66" Interceptor (cleaned)

60" Interceptor (cleaned)

North System


- Trickier to address!
- Overflows related to interceptor HGL
 - Downstream pump station (tailwater)
 - Interceptor pipe capacity issues in areas
 - Tidal influences
- Less expensive options have limited results
 - Interceptor cleaning, infiltration removal = minimal impacts
 - Raising regulator weirs = negative impacts



North System




- Tailwater from Central Street pumping station controls interceptor HGL
- Street flooding in low lying areas in larger storms



North System




- Tailwater from Cove Street pumping station/CSO facility controls interceptor HGL
- Interceptor restriction upstream of Cove Street pumping station/CSO facility




North System

- Sewer Separation
 - Expensive
 - Not enough for CSO control >> requires additional infrastructure
 - Difficult to disconnect private inflow (downspouts/sump pumps)
- Green Infrastructure
 - Limited space/steep slopes/bedrock

City Pier – Existing Conditions



City Pier – Sewer Separation




- Start looking at other options
 - Storage (off line/in line)
 - Pump Station (New or Upgrade)
 - Parallel Relief Sewers

- Start looking at other options
 - Storage (off line/in line)
 - Pump Station (New or Upgrade)
 - Parallel Relief Sewers


North System – City Pier

- Storage
 - 5.0 MG Storage Only
 - 0.4 MG Full Separation
- Pumping Station Upgrades
 - Upgrade pumping capacity from 15 MGD to 28 MGD
 - Additional Interceptor upgrades still needed

City Pier – Storage




City Pier – Pumping Station Upgrades




North System – Alton St.

- Storage
 - 1.4 MG Storage Only
 - 0.8 MG Full Sewer Separation
- Pumping Station Upgrades
 - Auxiliary pumping station capacity of 7 MGD
 - Upgrade Interceptor capacity
 - Raise weir 0.5 feet

Alton Street – Storage



Alton Street – Pumping Station Upgrades



What's Next?

- Use of the SWMM model to:
 - Refine alternatives
 - Look at larger storm impacts
 - Look additional needs (phasing) to address future flows
- Evaluate effectiveness to solve non-CSO issues
 - SSOs/street flooding
 - Infrastructure renewal (I/I removal, tidal influences)
- Find cost-effective balance of multiple CSO controls



Collection System

- Surcharged
- Not Surcharged

Manholes

- Flooding
- Surcharged - HGL within 1 foot of Grade
- Surcharged - HGL within 6 feet of Grade
- Surcharged - HGL > 6 feet Below Grade
- Flow Remains in Pipe


Questions?



Paul Ferland
City of Fall River
508-324-2322
PFerland@fallriverma.org

Nancy Beaton & Eilish Corey
CDM Smith
401-751-5360
BeatonNK@cdmsmith.com
CoreyE@cdmsmith.com

SWMM Model Development Timeline



Alternatives Evaluation

- Only evaluate feasible alternatives
- Evaluation Process
 - Combination of Qualitative and Quantitative Criteria
 - Higher priority criteria given higher weighting
 - Scores range from 2 to -2 for each criteria
- Cumulative score places emphasis on cost-effective alternatives

Environmental

- Water Quality
- Adaptability
- Flooding/SSOs

Social

- Public Health and Recreation
- Neighborhood Improvements/ Economic Development
- Post-Construction Impacts

Economical

- Life Cycle Costs
- Cost per Gallon of CSO Captured
- Infrastructure Renewal

Institutional

- Administration Considerations
- Phasing Flexibility
- Permitting Complexity

Construction Impacts

- Traffic, Noise, Dust, & Odors
- Constructability
- Short-term Environmental Impacts

Contact us!

Paul Ferland

City of Fall River

508-324-2322

PFerland@fallriverma.org

Nancy Beaton & Eilish Corey

CDM Smith

401-751-5360

BeatonNK@cdmsmith.com

CoreyE@cdmsmith.com



Find more insights through our water partnership
at cdmsmith.com/water and [@CDMSmith](https://twitter.com/CDMSmith)

SCADA

GIS/Asset Data

Rainfall and Groundwater Data

Flow Monitoring

Regulator Investigations

City CSO Overflow Data

Record Drawings

Record Boring information

Aerial Photography/Topography

Future Development

Recent Development

Agenda

- Background
- CSO Facilities Plan
- Model Summary and Updates
 - Development Timeline
 - Data Collection
- CSO Optimization
 - SWMM Model
 - Evaluation Criteria Assessments
 - Cost/Benefit Evaluation
- Plan Preparation