

Flue gas CO₂ recycling at Upper Blackstone Water District



January 24, 2018



Objectives




Background

Setup &
Process



Results

Conclusions



Acknowledgements

Massachusetts Clean Energy Center: Wastewater Treatment Plants - Innovative Technology Pilots (2017)

Michael Murphy and Katte Dobbins

Upper Blackstone Water District

Karla Sangrey, Mark Johnson, Randy Komssi

Ohio University

Dr. David Bayless

Independent

Kerry Muenchow




Background

Growing interest in the use of algal technology to achieve phosphorus recovery

CO₂ consumption represents the highest consumable product

Full scale commercial installations in progress



Objective

To demonstrate if CO₂ produced on-site (sludge incineration, anaerobic digester off-gas, etc...) can be used to support the use of algal based technologies as a component to resource recovery and nutrient management:

- The impact on ***growth*** performance
- The impact on ***biomass quality***

Test Site

Upper Blackstone (Milbury, MA)

- *Serves greater Worcester, MA area*
- *Designed for 45MGD, Peak flow 160MGD*
- *Currently incinerates sludge*



Site of extended pilot to demonstrate algal based performance for TP reduction

9 month demonstration


Feed: 0.254mg/L (Avg)

Permeate: 0.015mg/L (Avg)

CO₂ Source

Source gas

- ~75F
- ~10% CO₂ by volume
- NH₃



Advanced Biological Nutrient Recovery®

Blackstone testing summarized at annual NEWEA conferences 2015 and 2016

Feed

Median: 1.54mg/L


97.7%: 7.71mg/L

Permeate

Median: 0.02mg/L

97.7%: 0.10mg/L

ABNR Total Phosphorus pilot results (n=255)



Projected CO₂ costs

	Units	38MGD
Algal growth demand	Tons/day	31.5
Net from flue gas	Tons/day	28.4
Purchased cost – Low (\$0.04/lb)	\$/ton	80
Purchased cost – High (\$0.12/lb)	\$/ton	240
Cost - low	\$/year	\$829,280
Cost - high	\$/year	\$2,487,840
Cost - low – 20 year PW	\$ total	\$10,334,662
Cost - high – 20 year PW	\$ total	\$31,003,985

Based on reducing TP from 1.0mg/L to <0.1mg/L





Control Reactor

Test Reactor



RTO Source




Gas compression




Gas bubbling stones

Test Protocol

Parameter	Control Reactor	Test Reactor
<i>Baseline</i>		
-Duration		21 days
-CO ₂ source		Bottled
-Orthophosphate load		4.0mg/L
- Density (TSS)		750mg/L
<i>After baseline established</i>		
CO ₂ source	Bottled	Flue gas
Target Orthophosphate	4.0+/- 0.2mg/L	
Target Density (TSS)	750 mg/L	
Duration	75 days	
Harvest	Daily to maintain density	
Nutrient source	Girard f/2 media (Part A and B)	
Makeup water	Plant process water	




Box-Whisker Plot Comparison



No statistically significant difference


Arsenic

Control PBR #2




Ammonia

Control PBR #2




Note: No media samples for Pb or Hg available until late July


Biomass Pb concentration



Biomass Arsenic concentration



Biomass Mercury concentration





Control



Flue Gas

Conclusions

The use of flue gas, similar in quality to that at Blackstone, as a source of CO₂ to support algal production has no negative impact on growth density or recovery (in case of biological upset)

The impact on biomass composition (and components) must be considered

- All levels measured are below US EPA 503 guidelines

Recommendations

1. Additional longer-term testing to study impact on growth, components and biomass composition should be undertaken before fully adopted
2. Of particular potential is the use of gas produced through anaerobic digestion co-generation as it would be expected to be a “cleaner” gas

Questions

