



2018 NEWEA Annual Conference


Improving Nutrient Removal of Existing Wastewater Facilities Using Cyclical Aeration and Chemical Addition

Presented by:
Rachel Schnabel and Stephanie Baldino


January 23, 2018

Presentation Outline






Connecticut



Town of Plainfield

- **Area: 43 Square Miles**
- **Population: 15,400**
- **Villages:**
 - Plainfield
 - Moosup
 - Wauregan
 - Central Village




Village Plant




Design Flow = 0.71 MGD

Village Plant

1. Headworks
2. Aeration Tanks
3. Secondary Clarifiers
4. Disinfection Facility
5. Rapid Infiltration Sand Beds
6. Receiving Water
(Mill Brook)



Village Plant



North Plant



Design Flow = 1.08 MGD

North Plant



North Plant



1. Headworks
2. Primary Clarifiers
3. Aeration Tanks
4. Secondary Clarifiers
5. Disinfection Facility
6. Receiving Water
(*Moosup River*)

New Regulations – Village Plant

Permittee:
Town of Plainfield
Town Hall
8 Community Avenue
Plainfield, Connecticut 06374

Location Address:
Town of Plainfield WPCF
Birch St.
Plainfield, Connecticut 06374

Facility ID: 109-001 **Permit ID:** CT0100439 **Permit Expires:** August 9, 2017

Receiving Stream: Mill Brook **Design Flow Rate:** 0.707 MGD

SECTION 9: COMPLIANCE SCHEDULES

- (C) The permittee shall achieve the final water quality-based effluent limits for phosphorus for DSN 001-1 established in Section 5 of this permit, in accordance with the following:
- (3) Unless another deadline is specified in writing by the Commissioner, on or before 210 days after approval of the engineering report, the permittee shall (1) submit for the Commissioner's review and written approval, contract plans and specifications for the approved remedial actions, a revised list of all permits and approvals required for such actions and a revised schedule for applying for and obtaining such permits and approvals; and (2) submit applications for all permits and approvals required under Sections 22a-430 and 22a-416 of the CGS. The permittee shall obtain all required permits and approvals.

Approval Letter dated March 4, 2014

Submittal Deadline is Friday, September 30, 2014

New Regulations – Village Plant

Effective August 10, 2015

	Influent Average 2009-2013	Effluent Average 2009-2013	New Regulation
Phosphorus	19 lbs/day	8.6 lbs/day	2.51 lbs/day
Nitrogen	41 mg/L	11 mg/L	6 mg/L


New Regulations – North Plant

Effective June 1, 2019


	Influent Average 2009-2014	Effluent Average 2009-2014	New Regulation
Phosphorus	27.1 lbs/day	16.8 lbs/day	3.86 lbs/day
Nitrogen	37.7 mg/L	15.1 mg/L	7.5 mg/L


Cost Effective Solution

- *Draft Facilities Plan Update, February 2011*
 - **Combine Treatment Facilities**
 - **\$45 Million**
- *Engineering Report to Achieve Phosphorus Compliance, May 2013*




Cost Effective Solution





Phosphorus Removal

- **New Mechanical Screen**
- **Anaerobic Zone**
 - Phosphorus Accumulating Organisms (PAOs)
- **Chemical Addition**
 - Precipitate dissolved phosphorus




Nitrogen Removal Alternative Processes




- 1. Ballasted (BioMag)**
- 2. Biological Nutrient Removal (MLE)**
- 3. Cyclical Aeration**


Ballasted (BioMag™)



Biological Nutrient Removal (MLE)




Cyclical Aeration



Cyclical Aeration






New Influent Fine Screening



Aeration Tank Demo Work




New Anaerobic Zone



New Anaerobic Zone



New Anaerobic Zone



New Diffused Aeration & Anoxic Mixers



New Diffused Aeration & Anoxic Mixers



New Diffused Aeration & Anoxic Mixers



New Blowers for Aeration System



New Control System

DO



Nitrate



pH




ORP



- New pH, DO, and Nitrate/ORP sensors provide feedback to control panel.
- The control system is programmed to prevent the anoxic mixers and blowers from running simultaneously.






Village Plant Mechanical Aeration (Before)




Village Plant Cyclical Aeration (After)



Village Plant Effluent Phosphorus Load



Village Plant Effluent Nitrogen Concentration



North Plant Mechanical Aeration (Before)




Cyclical Aeration (After)




Cyclical Aeration (After)



North Plant Effluent Phosphorus Load



North Plant Effluent Nitrogen Concentration



Operations

Village Plant

	Summer	Winter
PAC Addition	17 gal/day	12 gal/day
Blower Cycle Times	30 min. on 30 min. off	20 min. on 40 min. off

North Plant

	Summer	Winter
PAC Addition	12-25 gal/day*	30 gal/day
Blower Cycle Times	160 min. on 60 min. off	60 min. on 70 min. off

**Will switch to 30 gal/day next summer.*

Conclusion

Upgrading equipment and treatment processes can be a cost-effective way to achieve nutrient reduction



Contact Information

Rachel Schnabel, EIT

Fuss & O'Neill

Project Engineer

rschnabel@fando.com

Stephanie Baldino

Town of Plainfield

Chief Operator

wpcaplainfield@plainfieldct.org