

MAXIMIZING RESOURCE RECOVERY THROUGH SOLIDS AND ENERGY FLOW MODELING


Catherine Moskos, Arcadis

April 12, 2018




Why Do We Model?

- Difficult to measure
- Underlying math is complicated
- Too many permutations
 - 5 processes with 2 options each = $2^5 = 32$
 - 5 processes with 3 options each = $3^5 = 243$






Everything at a WWTP is interconnected.





Everything at a WWTP is interconnected.



A dynamic and quantitative tool is required!



Case Studies

Sidestream Nutrient Management at the Wards Island WWTF - NYCDEP





Biosolids and Energy Optimization Study at the East and West Evansville Plants - EWSU








Wards Island Nutrient Management

- Average Influent Flow = 275 MGD
- Central Dewatering Facility
- Solids Handling = 260 dtpd
- SHARON for Side Stream
 Nutrient Removal








© Arcadis 2018

•






- Increase centrate treatment capacity while maintaining current air/power draw
- Eliminate ferric, caustic, and glycerol



Cascading Effects/Benefits






Modeling to Capture Cascading Effects

				Induced Struvite Rea			Chemical Add	dition		To Cent				Cake Off Load		
Sludge Scenario	4	Flow by	ON	Power, HP	64		erric dose, gal/MG	0		Flow gpd	2,200,000	_	%TS		27.5%	
Design	4	Gravity		MgOH2 lbs/day			erric gal/day	-		%TS	2.00%		lbs/day soli			
		OFF	4	gal MgOH2/day	1003	Cau	austic, gal/day	-		lbs/day solids	366,000		wtpd		653	
				J			Chemical Sludge	- Produced		lbs NH3-N/day	12,349		Disposal Co	Cost \$ 25,728,0	,000	
				J	_	lbs	bs/day	-		lbs PO4-P/day	183			†		
			<u> </u>	J						Polymer, Ibs/day	-					
				J			'			Polymer, gal/day	1,704	_				
Sludge Bo							′			, , , , , , , , , , , , , , , , , , ,	¹					
Flow gpd	1,100,000	F				\rightarrow	·	▲		r	¹					
%TS	2.0%										¹					
lbs/day solids	183,000	· · · · · · · · · · · · · · · · · · ·		I		WF	wetwell			1/17	777-				Centrate to Aer	
Temp (F)	81		2												Flow gpd	190,000
lbs NH3-N/day	7,339		•				,			N					Temp (F)	
lbs PO4-P/day	1,835						Sludge to Wet	et Well		Ň	× '		Centrate		lbs NH3-N/day	1,067
				Sludge Storage	ge Pumps	Flo	ow gpd	2,200,000	Centrifuge Feed	1		Flow(gpd)	d) 2,040,0	000,L	lbs PO4-P/day	
				Power, HP	78	%TS	،s	2.00%	Pumps			lbs NH3-N	4 17	1,451	Power, HP	206
Native Slu	udge	×	/	Grinder	ers	lbs'	s/day solids	367,000	Power, HP 15	15		lbs PO4-P	×	170	kWh/lb N	3.47
Flow gpd	1,100,000			Power, HP	0	Ter	emp (F)	84	Grinders	,						
%TS	2.00%					lbs '	s NH3-N/day	12,349	Power, HP (0	¥	- <u>-</u>		AEP	ERATION BASINS	
lbs/day solids	183,000					lbs '	s PO4-P/day	183		,	J					
Temp (F)	86		í							,]		Ļ			
lbs NH3-N/day	7,339		1	j						,	J					
Ibs PO4-P/day	1,835		1	Ţ						Total Nitrogen Trea	∠atment			SHARON	Flow gpd	1,850,000
			í	j.						lbs NH3-N/day	11,451		SHARON	ON	Temp (F)	-
										Power, HP	1,296				lbs NH3-N/day	10,385
Total NH3-N In	14,678 lbs/da	\$8,000,000			2,500	\top				kWh/lb N	2.03				Power, HP	1,089
Total PO4-P In	3,670 lbs/da	\$7,000,000			2,000					Glycerol		1 gal/day			kWh/lb N	1.88
		\$6,000,000	\$5,035,	35.000	2,000						1 . ,	8			scfm	13,335
	1	\$5,000,000		,000	1,500						+					
1	1	\$4,000,000			- -						+				Flow gpd	-
		\$3,000,000			1,000	· +					,	r r		ANAMMOX	Temp (F)	1
		\$2,000,000			- -		461						ANAMMOX	OFF	lbs NH3-N/day	-
	1	\$1,000,000			500	+					1	-		Blowers	Power, HP	+
		\$1,000,000 \$-			- L 0						+			Existing	kWh/lb N	#DIV/0!
		' -دِ	Annualize	(zed Cost	- ·		GHG Reduction [MT e			· · · · · · · · · · · · · · · · · · ·	+				scfm	
	(20 0030		-	JUO VEGGGGGG [1				+



Model Results




Scenario	Annualized Capital Cost [\$]	O&M Cost [\$]	Annualized Cost [\$]	GHG Reduction [MT CO2e/yr]	Power Draw, kW
1. Refurbished SHARON at Design Loadings	\$202,000	\$5,626,000	\$5,828,000	-	1,255
2. Add Induced Struvite Precipitation (ISP)	\$2,715,000	\$2,320,000	\$5,035,000	461	1,083
3. Add Deammonification	\$1,626,000	\$2,978,000	\$4,604,000	893	922
4. Add ISP and Deammonification	\$4,139,000	\$89,000	\$4,228,000	1,217	801



Evansville Optimization Study


- Average Influent Flow = 30 MGD for both the East and West Plants
- Intraplant Transfer
- Solids Handling = 10 dtpd
- Combined Heat and Power Engines





Project Drivers

- Maximizing digester gas energy
- Optimizing imports of organic wastes to digesters
- Examine other potential technologies
- Phase 1
 - Assess existing operations
 - Optimization without capital expenditure
- Phase 2
 - Assess other optimization technologies





Model Scenarios

0: No CHP or FOG/Septage

1a: Average Baseline (Pre-October 2017)

1b: HWR and Electrical Fix, NG to CHP

1c: Average Baseline (Post-October 2017)

2: Maximize Biogas to CHP

3a: Add FOG to Theoretical Maximum Digester Capacity

3b: Add FOG to Run Both CHP Engines on Biogas


4: Automate East Plant GBTs

5: HSW at West Plant

6: Self-Hauling Cake to Landfill




Evansville Phase 1 Model





Model Results





Conclusions

- Sludge has traditionally been viewed as a waste product for disposal.
- Mounting disposal and energy costs have shifted this view. Sludge is now being viewed as a valuable resource!
- Plants are looking to recover this resource, beneficially utilize digester gas, and optimize their operations.
- The Flow Model tool is user-friendly and allows plants to quantitatively investigate resource recovery options.
- We're moving towards sustainability, energy neutrality, and comprehensive strategies for biosolids and energy management.



Solids and Energy Flow Modeling

Sidestream Nutrient Management at the Wards Island WWTF - NYCDEP






Biosolids and Energy Optimization Study at the East and West Evansville Plants - EWSU












West Plant Phase 1 Model





EWSU Process Flow

