



Pump Station Upgrade for Improved Performance, Operations and Aesthetics




Lafayette Road Pump Station
Portsmouth NH



NEWEA
WORKING FOR WATER QUALITY


COMMITMENT & INTEGRITY DRIVE RESULTS

Outline



- Background
- City's Vision
- Design for Performance and O&M
- Structural and Architectural Design
- Lessons Learned
- Costs
- Questions

City of Portsmouth



- NH Seacoast city of 22,000
- 100 miles of sewer
- 6 major pump stations
- 14 smaller pump stations



Existing Conditions

- 4.4 mgd pump station
- Built c1962
- Upgraded 1981, 2001
- Aging equipment
- Poor wet well access
- Commercial area sensitive to aesthetic and odor impacts



Existing Conditions

- Extended shaft pumps
- Defunct grinder
- Difficult wet well access
- Outdated electrical & controls
- Indoor generator




City's Vision

- **High-Performance**
 - Capacity to handle peak & typical flows
 - Minimize ragging issues
 - Resilient and reliable
- **Simple to Operate & Maintain**
 - Easier wet well cleaning
 - Pump removal
 - Permanent bypass
 - Full SCADA monitoring
 - Outdoor generator
 - Lighting & ventilation
- **Aesthetically Appealing**
 - Architectural upgrade
 - Odor treatment
 - Pad-mounted transformer



Capacity for Peak & Typical Flows




Capacity for Peak & Typical Flows



- Consider a small “jockey” pump for typical flows.
- Reduced energy cost
- Less wear & tear on impeller and bearings
- Reduced chance of ragging
- You need to have the space!


Capacity for Peak & Typical Flows

- Jockey Pump is more efficient at typical flows: 70% vs 56%
- Payback 8-13 years
- Access and removal was a concern
- Ultimately decided not to include




Easier wet well O&M

- Replaced section of floor with grating
- Added a dividing wall
- Added H₂S-resistant epoxy coating




Space Configuration

- NFPA 820 adds a challenge to upgrading existing wastewater facilities.
- Ventilate at high rates
or
- Explosion-proof equipment
- Add walls to separate spaces



Architectural Goals

- Architectural Goals:
 - Improve building aesthetics and “curb appeal”
 - Match Deer Street Pump Station
 - Solar lighting
 - Interior Painting
 - Handrails that meet code
 - Improve energy efficiency
 - Provide maintenance access (pump removal)
 - NFPA 820 Gas-tight separation of spaces (intumescent collars on PVC pipes)



Before, During, After



Before and After



Before and After




Architectural Renderings

- Renderings
 - Aided in color selection
 - Helped with roof profile and dormer locations
 - Located several “faux” windows for symmetry




Pump Removal

- NFPA 820 Class 1 Division 2 electrical requirements
- Manual powered hoist and trolley have easily moved 2,000 lb pumps several times now
- Bridge crane allowed for increased maneuverability
- Upper level monorail, with access through door, tall enough to land pump on a 4' tailgate
- Check head clearances with shop drawings



Analysis of Existing Structure

- Finite Element Analysis (FEA) of modified structure to meet current codes
 - wet well floor removal
 - Electrical equipment loads on upper slab



Reinforcement of Existing Structure

- International Existing Building Code (IEBC) requirements:
 - Level 1 Alteration (removal and replacement of existing items)
 - Level 2 Alteration (adding/removing openings)
 - Level 3 Alteration (> 50% of building area)
 - Requires complying with current IBC level wind and seismic provisions
- Original design vs current code loading requirements:
 - Original Design: ??
 - 2006 IBC w/ City of Portsmouth Amendments: 100 MPH 3-second wind gust, Seismic Design Category C (1% probability of collapse in 50 years)




Reinforcement of Existing Structure

- Building envelope changes
 - New roof profile
 - New openings
 - Taller walls



Reinforcement of Existing Structure

- Field investigation confirmed unreinforced masonry
- Check of existing masonry for out-of-plane bending/shear, and in-plane-shear with new roof diaphragm loads. Not enough capacity to meet modern codes.
- Three-cell CMU issues and solutions



Reinforcement of Existing Structure

- Designed reinforcing scheme to satisfy current codes.
 - Reinforced piers integral to wall, no loss of interior space
 - Needed close coordination with louvers and windows



Lessons Learned

- New construction vs. retrofit
- More solar tubes
- Resilient hinged check valves



Project Financials

| Project Phase | Cost (Million Dollars) |
|---------------------|------------------------------|
| Engineer's Estimate | 2.95 |
| Bids (March 2017) | 2.57 2.71 2.78 4.22 |
| Final Cost with CO | 2.63 (2% CO) |



Acknowledgements

- Mike Baker – Pump Station Manager
- Terry Desmarais, P.E. - City Engineer
- Norm Dugas – Resident Engineer
- PRB Construction – General Contractor





Questions and Answers

Lafayette Road Pump Station
Portsmouth NH



NEWEA
WORKING FOR WATER QUALITY

Capacity for Peak & Typical Flows

