

BUILDING A WORLD OF DIFFERENCE

Leveraging Research & Real World
Experience to Clarify Phosphorus LOT
with Ballasted Sedimentation



Patrick Dunlap
Jim Fitzpatrick
Will Walkup




BLACK & VEATCH

Danbury CT WPCF Background



Danbury WPCF – Current Site




Project Drivers


- **Increase Plant Capacity from 11.0 mgd to 12.0 mgd**
 - (9.0 mgd current average flow)
- **Continue to Meet N Load Goals**
 - ~4.5 mg/L-N Max Limit at Design Flows
- **More Stringent P Limits**
 - Local Water Quality Based Limits for Lime-Kiln Brook
 - Currently must Achieve ~0.6 mg/L-P
 - Load Based P Limit eq. to 0.075 mg/L-P at Design Flow
(Apr-Oct Seasonal Avg. Limit)
 - Monthly & Daily Avg. Limits of 0.14 & 0.31 mg/L-P




Meeting Low Level P Limits Planning/Project History




High Rate Ballasted Sedimentation Process



Site constraints favor ballasted sedimentation




Deep Bed Filters



Ballasted Sedimentation




Deep Bed Filters Hydraulic Profile



- 6.54 feet of head required
- Intermediate pumping needed



Proposed Hydraulic Profile



- 3.96 feet of head required
- Fits within hydraulic window available



Ballasted Sedimentation Summary



Advantages	Disadvantages
Smaller footprint	Less common / newer technology
Lower head loss	Higher dependency on coagulation and flocculation sub-processes
Less hydraulic impact of peak flows/loads	Lower TSS Removal
Lower capital cost	

Recommendation to further evaluate ballasted sedimentation while leaving accommodations for 2nd Tertiary Stage Filters




LOW LEVEL P-REMOVAL

Forms of P in Tertiary/Secondary Effluent



P Removal Treatment Options




Several alternatives

- Chemically enhanced clarification / filtration / DAF
- ~~Media adsorption / IX~~
- ~~Algal-based activated sludge~~
- ~~Reverse Osmosis~~




The particle formation is key to chemically enhanced treatment



REVIEW OF BALLASTED SEDIMENTATION PERFORMANCE



1 & 2 Stage Tertiary P Removal – Full Scale Eff. P Fractionation (from WERF, 2014)




- *Single Stage Sedimentation similar to single stage Filtration*
- *2-Stage Processes to achieve <0.05 mg/L-P*
- *Previous case Studies*




ACTIFLO Installations for Low Level P



CoMag Installations for Low Level P




Review of publically available DMRs




Facilities nearly meet Danbury limits despite higher limits...



What was the cause of exceedances?



Facility 1 – ACTIFLO w/ 2° Chem P Removal



Facility 1 – ACTIFLO w/ 2° Chem P Removal





Facility 1


- **Chemical P Removal Secondary Process maintaining a consistent SE TP concentration ~0.5 mg/L-P**
- **Various problems lead to periods of FE TSS > 5.0 mg/L-P which drives FE TP concentration**
 - **High loading & poor tertiary flow spitting at high flows**
 - **Polymer system failures**
- **Regular cleaning of Lamellas & polymer system preventative maintenance important to maintaining TSS removal performance**



Facility 2 – ACTIFLO w/ 2° Bio-P Removal



Facility 2 – 2° EBPR (for SE OP < 0.5 mg/L)





Facility 2

- Secondary effluent TP varies to >1.0 mg/L-P which is major determinant of FE P Concentration
- Limit is 0.2 or 1.0 mg/L-P depending on seasons but tertiary treatment is used year-round for metals limits
- Effluent TSS < 5.0 mg/L 95% of the time
- When SE OP is controlled to <0.5 mg/L-P (as at Danbury) Danbury effluent P goals are achieved



SITE SPECIFIC CONSIDERATIONS

Danbury Jar Testing (SE TP ~0.55 mg/L-P)




At optimal dose settled TP ~20 ppb

Spec. Samplings indicate sNRP 5-15 ppb




Selective Removal of Precipitates?




Relationship between Eff TSS and TP in Facility 1 Data suggests selective removal of solids with higher %P

Critical Factors to Achieve Seasonal Average P Limit of 0.075 mg/L-P

- sP < 0.02-0.03 mg/L-P
 - Soluble Reactive P almost fully removed
 - Soluble non-reactive P in typical range
- xP < 0.03-0.04 mg/L-P
 - TSS ~3.0 mg/L at 1.0-1.5% P by weight.



TSS Removal Comparison w/ Single Stage Deep Bed Granular Media Filtration



*All things being equal filters could achieve 0.02-0.03 mg/L-
P lower effluent TP through additional TSS removal*



Design / Ops Considerations

- Hydraulic Loading < 30 gpd/sf at Peak flow w/ n-1 units
- Particle formation best practices (rapid mix/ flocculation zone HRT & mixing intensity) from WTPs
- Easy to maintain and robust poly feed system
- Frequent Cleaning of Lamella Plate
- Well defined dry & wet weather SOPs
- Soluble Reactive P removal by continuing to control SE TP at current levels



Risks and Mitigations Strategies

- **Risks**


- sNRP spikes
- Lower P limits
 - Pop. exceeds projected
 - More stringent load limit

- **Mitigation**


- Higher upstream P removal
- Source control if sNRP is unusually high
- Earlier implementation of 2nd stage of tertiary treatment
 - Filtration or coagulation/filtration depending on limit




Questions



Danbury WPCF



EPA (2007) Evaluation



DESCRIPTION	VALUE
Number of Treatment Trains	3 (2 duty, 1 standby)
Maximum Capacity per Train	14.0 mgd
Rapid Mix (per train)	
HRT at 14.0 mgd	2.1 minutes
Mixing velocity gradient (G)	300 to 320 s ⁻¹
Injection (per train)	
HRT at 14.0 mgd	2.1 minutes
Mixing velocity gradient (G)	250 to 290 s ⁻¹
Flocculation (per train)	
HRT at 14.0 mgd	4.7 minutes
Mixing velocity gradient (G)	100 to 200 s ⁻¹
Settling (per train)	
Maximum HLR at 14 mgd ⁽¹⁾	28.8 gpm/ft ²
Microsand Recirculation (per train)	
Number of pumps	1 duty + 1 standby
Flow rate at 14 mgd	290 gpm per pump
De-sanded Sludge Generation (per train)	
Flow rate at 14 mgd	232 gpm (without sludge recirculation)
Sludge solids concentration	0.05 - 0.5 percent TS
Sludge Recirculation (per train)	
Flow rate at 14 mgd ⁽²⁾	115 gpm


Notes:

- Hydraulic loading rate is based on the surface area of settling tank equipped with lamella settling tubes or plates.
- Sludge recirculation rate assumed to be 50% of the de-sanded sludge generated by the hydrocyclones. The sludge recirculation rate will be confirmed during detailed design.
- Refer to Chapter 3 for preliminary design criteria for the coagulant, polymer, and micro-sand feed systems. Jar testing of secondary effluent from the Danbury WWTP is needed to confirm coagulant and polymer type and to determine minimum, average, and maximum design dosages.



Steps 1-3 Determine Success


- Coagulation
 - $\text{Al}^{3+}/\text{Fe}^{3+}/\text{Ca}^{2+}$ dose
 - Alkalinity/pH
 - Rapid mixing criteria
- Flocculation
 - Polymer type and dose
 - Rapid mixing criteria
 - Slow mixing criteria
 - Sludge recirculation



- Coagulant dose higher than PO_4 precipitation alone
- Metal hydroxyl floc formation
 - pH/alkalinity
 - Deflocculation from monovalent cations



10 Years of Monthly Flow Factors



Clarification Mechanisms

Gravimetric


Particle Conditioning



Surface Charge
Neutralization

Coagulation
Co-precipitation

Flocculation
Adsorption




Filtration*

Sieving (Surface)



Adsorption (Depth)



* Generally requires particle conditioning, depends upon waste and filter type.

