



City of O'Fallon

First of it's Kind Treated Effluent Discharge Saves Millions



NEWEA ANNUAL CONFERENCE 2020


Robert Polys, P.E. | Woodard & Curran, Inc.

Max Kenney, EIT | Woodard & Curran, Inc.



COMMITMENT & INTEGRITY DRIVE RESULTS

Presentation Overview

- Overview of City of O'Fallon, MO
 - Overview of O'Fallon Water Resource Recovery Facility (WRRF)
 - Project Need & Drivers
 - Antidegradation Evaluation for New Discharge
 - Notable Successes
 - Lessons Learned
- 


City of O'Fallon - Overview

- Mid-West City – Just West of St. Louis
- Population ~ 88,000 - 7th largest City In Missouri
- **O'Fallon Wastewater System**
 - City Own's & Operates O'Fallon WRRF
 - 18 Collection System Lift Stations
 - 200 Miles of Sewer & 6,000 Manholes
 - 16,000 User Connections
- Accepts Flow From
 - Neighboring City of Lake St. Louis
 - Public Water Supply District #2



City of O'Fallon - Location

Missouri



City of O'Fallon - Aerial



O'Fallon WRRF - Overview

- O'Fallon WRRF
 - 11.25 MGD Permitted Average Day Flow
 - 7.5 MGD Current Average Day Flow
 - 16.5 MGD Current Max Day Flow
- Permitted Discharge to Mississippi River
 - 6 Mile Force Main
 - Large Effluent Pump Station-(4)-150hp Pumps
- Typical Secondary Treatment Permit Limits
 - CBOD/TSS: 25/30 mg/L
 - Ammonia: 23.8 mg/L
 - E Coli: 126/100 mL



O'Fallon WRRF Overview

- Influent Offline Equalization
 - 7.8 MG of Storage
- Preliminary Treatment
 - Screening & Grit Removal
- Primary Clarification
- Biological Treatment
 - Biofilter/Activated Sludge Treatment Process
- Final Clarification
- UV Disinfection
- Effluent Lift Station – To Mississippi River
- Biosolids
 - Thickening, Dewatering & Class-A Processing
 - Biosolids Disposal – Land Application



O'Fallon WRRF Aerial




O'Fallon WRRF Outfall



Project Need & Driver #1

- #1- New & Future Permit Limits:
 - Missouri Department of Natural Resources (MDNR)
 - More stringent Ammonia limits
 - Discharge Permit Renewal in 2016
 - Current Limits: 23.8 mg/L (Monthly Average)
 - Proposed Limits:
17.8 mg/L (summer monthly average) | 17.0 mg/L (winter monthly average)
 - Required to meet new limits by September 2022
- Existing WRRF Cannot Meet New Limits



Project Need & Driver #2

- #2 – Effluent Pump Station Capacity Limitations
 - Flooding & Backups Into UV Disinfection System
 - Compromise Safety & Permit Compliance


- Cause = Mississippi River Flooding
 - Significant Increase in Static Head
 - Limited Effluent Lift Station Capacity to ~12 MGD
 - Peak Plant Flows Up to 16.5 MGD

- Excess Effluent Flow of 4.5 MGD

- No Where to Go But Backup!



UV Disinfection Flooding



Project Need & Driver #3

- #3 - Additional Capital Improvements
 - Major Electrical Upgrades-80% WRRF
 - Remove Grounded B-Phase System
 - Major Control System Upgrades
 - Primary & Secondary Clarifier Flow Split Upgrades



Overall Need & Driver Summary

- Two Parallel Path Project Needs
 - #1-New Ammonia Limits – April 2021
 - #2-Mitigate Effluent Lift Station Capacity Limitations

- Ammonia Limits Summary – Mississippi River
 - Current Monthly Average = 23.8 mg/L
 - Next Permit Cycle = 17 mg/L
 - Future EPA Limits = 7.2/18.5 mg/L
 - Gil Breathing Snails & Freshwater Mussels
 - Future Total Phosphorous Limits?
 - Future Total Nitrogen Limits?



O'Fallon WRRF Past Outfalls

- 1970's to Early 1990's
 - Treated Effluent Discharge to Peruque Creek
- Early 1990's to Present
 - Treated Effluent Discharge to Mississippi River
- Peruque Creek
 - 7Q10 & Mixing Flow = 0.1 & 0.025 CFS
- Mississippi River – 20,347 CFS @ 7Q10 – Main Channel
 - Mixing Flow In Permit = 508 CFS
- Discharge to Slough of Mississippi River
 - Not Main Channel



Innovative Idea & Challenge!

- Second Treated Effluent Discharge to Peruque Creek
 - Peruque Creek – Adjacent to WRRF Site
 - Favorable Location for Excess Treated Effluent
- Fully Treated & Disinfected Effluent
 - No Bypasses of Secondary Treatment (Blending)
- Significant Challenge
 - No Permitted Discharges Like This in Missouri
 - No Specific Missouri Permit Procedures
 - New Discharge Would Require Antidegradation Evaluation



High Flow to Peruque Creek?



Antidegradation

- Missouri's Antidegradation Implementation Procedure (AIP)
- Similar to Other States – **Goals To...**
 - Justify the New Discharge
 - Ensure Compliance with State Water Quality Standards (WQS)
 - Justify Economic Benefit of Discharge
 - Conduct a Pollutant by Pollutant Review
- End Product & Delivery
 - Antidegradation Evaluation Report to MDNR



Missouri Antidegradation Rule and Implementation Procedure

Step #1 – Review Levels

- Tier I – Waterbodies on States 303D List as Impaired
- Tier II – Waterbodies With Water Quality Above State WQS
- Peruque Creek
 - On 303D List – Impaired for Dissolved Oxygen
- Tier I & II Review Combined
 - DO – Tier I Review – 303D Listing
 - Other Pollutants – Tier II Review




Step #2 – Receiving Water Flow

- Goal – Correlate Limits At High Flow Creek Conditions
- Challenges
 - What Are Peruque Creek Flows During High Flow Conditions?
 - No Discharge @ Low Flow
- City Operating Data Evaluation
- When Did Capacity Limitations Occur?
 - Typically UV Surcharges – 2-inches of Rain in a Day
 - Typically UV Surcharges – 3-inches of Rain over 3-days


Step #2 – Evaluation of Pollutants

- USGS & NOAA Data (Flow & Rainfall)
 - Peruque Creek Flow At Corresponding Rainfalls
 - Establish Baseline High Flow Conditions
- Peruque Creek High Flow = 704 CFS (455 MGD)
 - Mixing Zone of 176 CFS (113 MGD)
 - Much More Favorable Than 0.025 CFS Low Flow Mixing Zone
 - 176 CFS Used for Pollutant by Pollutant Evaluation
 - Treated Effluent Discharge of 4.5 MGD
- Max Day & Max Week Limits Calculation Basis
- Anticipated Discharge Frequency
 - 0 to 5 Times Per Year



Step #2 – Evaluation of Dissolved Oxygen

- Peruque Creek Impaired for DO
- DO Modeling of Discharge to Peruque Creek
 - Streeter-Phelps Evaluation
 - Stream Background DO & BOD
- Evaluation Determined
 - To Meet Minimum Day DO Limit of 5 mg/L
 - Reaeration Would Be Needed At WRRF
 - Maximum Day BOD₅ Limit of 45 mg/L
- Ensured Protection of WQS



Summary of Permit Limits

Parameter	Units	Final Effluent Limits			Monitoring Requirements	
		Daily Maximum	Weekly Average	Monthly Average	Measurement Frequency	Sample Type
Flow ⁽¹⁾	MGD	(Note #1)	----	----	once/day	(Note #1)
BOD ₅ ⁽²⁾	mg/L	----	45	----	twice/week	24 hr Comp.
TSS ⁽²⁾	mg/L	----	45	----	twice/week	24 hr Comp.
pH Units ⁽³⁾	SU	6.5-9.0	----	----	once/day	Grab
E. Coli ⁽⁴⁾	#/100mL	----	630	----	twice/week	Grab
Ammonia-N (4/1 to 9/30)	mg/L	23.8	----	----	once/month	Grab
Ammonia-N (10/1 to 3/31)	mg/L	23.8	----	----	once/month	Grab
Oil & Grease	mg/L	15	----	10	once/month	Grab
Total Phosphorous ⁽⁵⁾	mg/L	Monitor	----	0.5 to 1	once/quarter	Unknown
Total Nitrogen ⁽⁵⁾	mg/L	Monitor	----	8 to 10	once/quarter	Unknown
Copper ⁽¹⁾ (Total Recoverable)	µg/L	Monitor	----	Monitor	once/quarter	Grab
Zinc ⁽¹⁾ (Total Recoverable)	µg/L	Monitor	----	Monitor	once/quarter	Grab
Dissolved Oxygen ⁽⁶⁾	mg/L	5.0 mg/L ⁽⁶⁾	----	----	once/day	Grab

Step #3 – Less Degrading Alternatives Evaluation

- Requirement of the Missouri AIP
- Base Project & Three Less Degrading Alternatives
 - Base Project – Activated Sludge With BNR & Selectors (BNR AS)
 - Less Degrading #1 – BNR AS & Tertiary Filtration
 - Less Degrading #2 – BNR AS & Filtration + Chemical Addition
 - Less Degrading #3 – Membrane Bioreactor (MBR)
- Missouri AIP – Total LCC at or Below 120% of the Base Project = Economically Viable
- Cost Effective to Further Minimize Degradation?

Less Degrading Alternatives Evaluation Summary

Parameter	BNR Activated Sludge	BNR Activated Sludge with Tertiary Filtration	BNR Activated Sludge with Tertiary Filtration & Chemical Addition	Membrane Bioreactor
Practicability	Yes	Yes	Yes	Yes
Total Initial Capital Cost (I)	\$ 29,720,000	\$ 43,579,000	\$ 46,684,000	\$ 48,872,000
Present Value of O&M Costs (O&M)	\$ 7,270,000	\$ 7,358,000	\$ 15,141,000	\$ 14,133,000
Present Value Salvage Value (S)	\$ (2,101,000)	\$ (2,252,000)	\$ (2,888,000)	\$ (1,493,000)
Total Present Worth (I-C)	\$ 34,889,000	\$ 48,685,000	\$ 58,937,000	\$ 61,512,000
Base-to-Alternative Cost Ratio	1.00	1.40	1.69	1.76
Total Annual Costs	\$ 411,000	\$ 416,000	\$ 856,000	\$ 799,000
Economic Efficiency	Economically Efficient	Not Economically Efficient	Not Economically Efficient	Not Economically Efficient

Step #3 - Non-Degrading Alternatives Evaluation

- Requirement of Missouri AIP
- No Increase Flow or Pollutant Loading to Receiving Water Body
- **“No Discharge” Alternatives**
 - Land Application & Seasonal Storage
 - Subsurface Disposal
 - Alternative Discharge Locations
 - Regionalization
 - Improved O&M
- All Not Feasible



Step #3 – Viable Non-Degrading Alternatives

- Non-Degrading Alternative #1 – Additional Effluent Pumping Capacity – High Flows
 - New High Flow Pump Station & Large Pumps (~1,000 hp each)
 - Major Electrical Improvements
- Non-Degrading Alternative #2 – Parallel Effluent Force Main – Reduce Head Loss
 - Second 30-inch Force Main to Mississippi River
 - 6-Miles Long
 - Reduces Dynamic Head But Not Static Head (Mississippi Flooding)

Step #3 – Non-Degrading Alternatives Summary

Parameter	Peruque Creek High Flow Discharge	Additional Effluent Pump Station Capacity	Parallel Effluent Pump Station Force Main
Practicability	Yes	Yes	Yes
Degrading/Non-Degrading	Degrading	Non-Degrading	Non-Degrading
Total Initial Capital Cost (I)	\$ 3,400,000	\$ 8,000,000	\$ 12,873,000
Present Value of O&M Costs (O&M)	\$ 18,000	\$ 213,000	\$ 36,000
Present Value Salvage Value (S)	\$ (75,000)	\$ (137,000)	\$ (1,791,000)
Total Present Worth (LCC)	\$ 3,343,000	\$ 8,076,000	\$ 11,118,000
Base-to-Alternative Cost Ratio	1.00	2.42	3.33
Total Annual Costs	\$ 1,000	\$ 12,000	\$ 2,000
Economic Efficiency	Economically Efficient	Not Economically Efficient	Not Economically Efficient

Proposed Solution

- High Flow Discharge Lift Station to Peruque Creek
- New Cascade Reaeration System
- New Outfall Pipe to Peruque Creek



How & When to Discharge?

- How & When Will Discharge Be Allowed?
- Mississippi River Level At or Above Flood Stage
 - Measurement: (USGS Station-Grafton, IL)
- Period Which Caused Backups at WRRF
- Correlated This Level to Peruque Creek Flows
 - At High Flow Discharge Periods




Overview – Proposed Solution



Where We Are & Where We Are Going

- Currently In Bid Phase of \$30M Upgrade to WRRF
 - High Flow Discharge to Peruque Creek One Part of Project



Notable Successes

- Getting This Discharge Permitted
 - First of it's Kind in History of State of Missouri
- Significant Cost Savings for City
 - ~\$7M Less Than Other Alternatives Evaluated
 - High Flow Lift Station, Cascade Aerator & Outfall
 - Opinion of Probable Cost = \$2M
 - Even Better Savings Than Anticipated Initially
- Reasonable Effluent Limits
 - Both for Current & Future Permit Requirements



Lessons to Share

- Communicate Early & Often With Agencies
 - Even Before Starting Work or Application
 - Very Successful & Integral Part of this Process
- See What Information is Available Already About Receiving Water
 - Site Specific Water Quality & Flow Data
 - Previous Watershed Studies
 - Previous Agency Studies
- Research Other Discharges of Similar Nature
- **Don't Believe the Naysayers!**



Acknowledgements

- **City of O'Fallon**
 - Water & Sewer Division Management Staff
 - WRRF Operations Staff

- **Missouri Department of Natural Resources**
 - John Rustige, P.E. – Wastewater Engineering Chief
 - Refaat Mefrakis – Water Protection Program Engineering Chief
 - All MDNR Outstanding Partners In This Process





THANK YOU!!

QUESTIONS?



COMMITMENT & INTEGRITY DRIVE RESULTS