



OPTIMIZING CAPACITY AT A HYBRID ROTATING BIOLOGICAL CONTACTOR PLANT

WHERE DO WE STAND AND WHERE DO WE INVEST NEXT TO
GET THE CAPACITY WE NEED?

NEWEA Annual Conference, January 28, 2020

Frederick Mueller, PE, Tighe & Bond
Cynthia Castellon, PE, Tighe & Bond

Peter Boria, Town of Charlton

OUTLINE

- **Plant Overview**
- **Events that Led to Study**
- **Study Goals**
- **Study Recommendations**
- **Plant Changes Since Study**



PLANT OVERVIEW

- **Service Area**

- Charlton (600 Households)
- Mass Pike Charlton Rest Stops
 - High Strength (BOD/Grease) @ 0.06 MGD
- Various Commercial

- **Upgrade History**

- 1995 Plant Constructed (2 RBCs)
- 2000 Plant Upgrade (2+6= 8 RBCs)
- 2008 Plant Upgrade (8+2= 10 RBCs)
 - Low Level Phosphorus <0.11 mg/l (Comag)

- **2017 New Customer**

- Destination Brewery



PLANT OVERVIEW

• NPDES Discharge to Cady Brook (Quinebaug)


- TSS/BOD5 14 mg/l Summer, 21 mg/l Winter
- Ammonia 1.42 mg/l Summer
- Aluminum Limit 0.093 mg/l
- Phosphorus 0.11 mg/l Summer

(Weekly Sample –Collected Tuesday 7 AM)

• How?


- EQ Tanks
- RBCs
- Clarifiers
- CoMag – Phosphorus Removal
 - Add Ferric Chloride - Multipoint
- Add Sodium Bicarbonate
- Final pH Adjust – Sodium Hydroxide





PLANT OVERVIEW

- RBCs – 4 Stage



PLANT OVERVIEW

• 2009 Upgrade Design Capacity

	Avg	Max Month
- Design Flow	0.45	0.675 MGD
- Current Flow	0.21	0.31 MGD (about 46% of design flow)
- BOD Load	1,032	1,435 lbs/day (about 55% loaded)
- Ammonia Load	189	295 lbs/day (about 50% loaded)
- TKN Load	311	506 lbs/day (about 40% loaded)*

• Basis

- Flow & Load are Equalized (EQ tanks)
- 10 RBCs in Service
- Treatment Effect from MLSS in EQ Tanks

• Typical Operations

- 2 RBCs needed repair
- 6 RBCs in service to Jan 2016
- 7 RBCs in service to Jan 2018
- 8 RBCs since Jan 2018

* Limited Data on TKN.



EVENTS THAT LEAD TO THE STUDY

- **2017 – Permit Violations – NH₃ (>> 1.42 mg/L)**

- 8.8 mg/L - Columbus Day (collected Tuesday 7 AM)
- 2.52 mg/l - Week Prior

- **Why Did this Happen?**

- Was there a loss of Alkalinity ?
 - Recently Started Dosing Manually – No Smoking Gun
- Did New BOD Loads from Brewery impact Capacity?
- Did a Holiday Rush Overload Plant (7 RBCs) ?
 - Influent BOD Loads prior Monday much higher **✗**
 - TKN was typical both weeks **✗**
 - Could a BOD Overload impact the nitrifiers on RBC?



BREWERY WAS NOT FOCUS OF STUDY

- **No Problems Prior**
- **End of Summer Busy Season**
- **Estimated Loads**
 - 7,000± gpd BOD @ 1,500 mg/l = 90 lbs/day (< 10% of Plant)
- **Recent Brewery Improvements**
 - Recently Installed a 15,000 gallon EQ tank
 - Switching from Batch to Continuous Discharge
 - Investing in Aquapoint Pretreatment System



STUDY GOALS

- **Complete a Maximum Headworks Loading Analysis**
 - What was actual Plant Capacity?
 - How does it change?
- **Factors Considered**
 - BOD vs TKN/Ammonia Treatment Capacity
 - # of RBCs on line
 - Season (water temperature)
 - EQ Tank Operations
 - MLSS Concentration
 - Operating Levels
 - Air Delivered




RBC Prior to Covers

CHARLTON, MA HEADWORKS LOADING

10 RBCs; Summer Conditions


At 0.45 mgd flow, 13 degrees C, and 0.5 mg/L Effluent NH₃-N



CHARLTON, MA HEADWORKS LOADING

10 RBCs; Summer Conditions


At 0.45 mgd flow, 13 degrees C, and 0.5 mg/L Effluent NH₃-N



CHARLTON, MA HEADWORKS LOADING

10 RBCs; Summer Conditions


At 0.45 mgd flow, 13 degrees C, and 0.5 mg-N/L Effluent NH₃



CHARLTON, MA HEADWORKS LOADING

10 RBCs; Summer Conditions

At 0.45 mgd flow, 13 degrees C, and 0.5 mg/L Effluent NH3-N



STUDY RESULTS

- **Provided Multiple Capacity Charts:**


- Different # of RBCs in Service
- Winter/Summer Seasons
- Assumed EQ Tank Operations
 - Typical levels in Past (4-5.5 feet)
 - Existing Aeration Blower Capacity (4 @ 180 SCFM)
 - Typical MLSS Levels (3,500-4,000 mg/l)



STUDY RESULTS

6 RBCs; Winter Conditions

At 0.45 mgd flow, 10 degrees C, and 5 mg-/L Effluent NH3-N



STUDY RESULTS


- **Sensitivity Analysis on EQ Operation:**
 - EQ Tank
 - Modify Pumping Controls
 - Increase Lower EQ Tank Operating levels (7+/- feet)
 - Was MLSS Optimized
 - Clarifier Capacity?



STUDY RESULTS

6 RBCs; Average Operating Water Level = 4.4 ft


At 0.45 mgd flow, 10 degrees C, and 5 mg-N/L Effluent NH3



STUDY RESULTS


6 RBCs; Average Operating Water Level = 7 ft

At 0.45 mgd flow, 10 degrees C, and 5 mg-N/L Effluent NH3




STUDY RESULTS- EQ TANK OPERATION

Existing- Fixed Wet Well Level Setpoints




STUDY RESULTS- EQ TANK OPERATION

Recommended- Hourly Varying Wet Well Level Setpoint



STUDY RESULTS

- Clarifier Capacity & EQ Tank Operations Limit Max MLSS. (Capacity Diagrams)



SAMPLES COLLECTED FOR MICROBIAL ECOLOGY SURVEY*



- **MLSS Samples**

- Nitrifiers: 0.06% abundance Nitrosonomas (Very Low)
- PAOs: 4 % abundance Dechloromonas

- **RBC 1st Stage Fixed Film Samples**

- Nitrifiers: 1.1% abundance Nitrospira (Low)
- PAOs: 10 % abundance Dechloromonas

*Center for Microbial Communities
3/18-6/19 study facilitated by
(Prof. Nick Tooker

UMass
Amherst



SAMPLE COLLECTION FOR MICROBIAL ECOLOGY SURVEY

- **Conclusions:**

- Confirmed EQ Tank MLSS Model:
 - Is helping: BOD removal
 - Not helping: Ammonia removal.

- **New Questions (Not answered)**

- Is abundance of PAOs due to alternating anoxic/anaerobic then Oxidic conditions?
 - Anaerobic? in EQ tank then Oxidic at RBCs
 - Anaerobic? In RBC Media Underwater, Oxidic in Air
- No evidence luxury uptake P was being performed
- Can chemical usage be reduced?
 - Anaerobic Tank prior to EQ tanks
 - Would need RDT to thicken sludge (No Decant)

PLANT CHANGES SINCE STUDY

- **Repaired Original 2 RBCs**
 - Repaired leak in steel tanks
- **EQ Tank Operations**
 - Inspected Tanks (Covered) – Repaired Diffusers
 - Operating at Higher EQ Tank Levels
 - Considering Increasing Blower Size
- **No Violations**



Tighe&Bond

Engineers | Environmental Specialists

Acknowledgements

Steve Wandland - Charlton Water & Sewer

John Oatley – Veolia

Keith Labbe – Veolia

Frederick Mueller, PE
Tighe & Bond, Inc
213 Court Street
Middletown CT 06457
P: 860-704-4768
E: famueller@tighebond.com

Peter Boria
Charlton Water & Sewer
t 37 Main Street
Charlton, MA 01507
P: (508) 248-2225
E: Peter.Boria@townofcharlton.net

THANK YOU



Tighe&Bond

Engineers | Environmental Specialists