



Doing More with Less: A Tale of Enhanced Biological Phosphorous Removal

David Ford, Town of Wolfeboro
Jacob Metch, HDR
Rebecca Elwood, HDR




*Town of
Wolfeboro*

January 24, 2022

Acknowledgement



- 1 Steve Broadbent – Cyclic Aeration Idea Back in 2007 Workshop
- 2 John Craigie and Steve Mancini – Woodard & Curran Operators



1 Nutrient Removal Biology

2 Wolfboro WWRF

3 Biological Process
Evaluation Objectives

4 Data Review & Sampling


5 BioWin Model
Development & Findings

6 Conclusions & Significance




Nutrient Removal Review

Nitrogen Removal Review



Biological Phosphorus Removal




- Requires anaerobic zone followed by aerobic/anoxic zone
 - PAOs release PO_4 and take up VFAs in anaerobic zone
 - PAOs take up PO_4 in aerobic/anoxic zone
- Adequate supply of volatile fatty acids (VFAs) in anaerobic zone
- Oxygen and NO_3 returns disrupt anaerobic zone
 - Must avoid for stable Bio-P



Wolfeboro Wastewater Treatment Facility

Overview of Wolfeboro WWTF



* Taken from Case Studies on Implementing Low-Cost Modifications to Improve Nutrient Reduction at Wastewater Treatment Plants, EPA, 2015.

Biological Process Evaluation Objectives

- Understand the process
 - Existing flow and load conditions
- Examine Alternatives
- Tool for the Future





Data Review and Supplemental Sampling

Data Analysis

- Preliminary Data Review
 - Influent characterization
 - Aeration tank and secondary clarifier process information
 - Monthly operating reports
 - Effluent and effluent storage pond
- Supplemental Sampling and Testing
 - Influent VFA characterization
 - Aeration tank profiling



Influent Characterization

- 10 yrs of data evaluated
- 3 years used for statistical analysis
- Medium to high strength municipal wastewater

| Parameter | Average | Max Month | Max Day |
|---------------------------|---------|-----------|---------|
| Flow (gpd) | 290,000 | 390,000 | 550,000 |
| TSS (mg/L) | 420 | 430 | 11,000 |
| BOD5 (mg/L) | 250 | 350 | 2,100 |
| NH ₃ -N (mg/L) | 26 | 35 | 56 |
| TKN (mg/L) | 41 | 55 | 180 |
| Orthophosphate-P (mg/L) | 2.2 | 3.3 | 14 |
| TP (mg/L) | 9.9 | 20 | 130 |


Plant Operation and Performance

- Summary of operation
 - SRT of ~10 days in summer and ~20 days in winter
 - Cyclic aeration
 - ~60 min air-on and ~45 min air off
 - Adjusted based on conditions
 - RAS rate of ~70-100%
- Summary of performance
 - Effluent consistently meets NPDES permit limits
 - Occasional spikes in effluent ammonia

| Secondary Effluent Parameter | NPDES Permit | Average |
|------------------------------|--------------|---------|
| CBOD5 (mg/L) | 30 | 11 |
| TSS (mg/L) | 30 | 8.2 |
| Total Nitrogen (mg/L) | 10 | 3.6 |
| Total Phosphorus (mg/L) | - | 0.8 |

Supplemental Sampling

- Understand environmental conditions created by cyclic aeration in flow-through basins
- Twice daily for one-week
- DO, pH, oxidation-reduction potential, nitrate, and orthophosphate
- Measured along the length of the basin during air on and air off cycles.



Supplemental Sampling – Influent Volatile Fatty Acids (VFAs)


Influent VFAs in mg/L-COD

| Date | 6/14/2021 7:15 | 6/15/2021 7:20 | 6/16/2021 7:20 | 6/17/2021 7:25 | 6/18/2021 7:15 | Average |
|----------------|-------------------|-------------------|-------------------|-------------------|-------------------|-------------|
| Acetic Acid | 29.2 | 24.1 | 28.9 | 38.5 | 51.2 | 34.4 |
| Propionic Acid | 9.7 | 8.5 | 16.2 | 15.7 | 26.3 | 15.3 |
| Total | 39.0 | 32.6 | 45.1 | 54.2 | 77.5 | 49.7 |

- VFA concentrations within typical range
- VFA to average BOD ratio is higher than industry standards
- May indicate fermentation in the collection system

Supplemental Sampling - Nutrients


- DO and ORP
 - Data erratic and difficult to interpret
 - Very low DO even during air-on cycles
- Non-detectable nitrate for all samples
- Orthophosphate release during anoxic cycle






BioWin Model Development and Findings

BioWin Model Development




Predicted DO Profile

- DO profile along length of tank.
- Low air demand at effluent end
 - Low BOD
 - Better oxygen transfer
- Airflow not adequate to hit DO target in most of tank
 - DO probe location at effluent end



Phosphorus Removal - Inlet End Anaerobic Zone



Anaerobic zone created to facilitate P release and VFA formation

Conclusions and Significance

- Conclusions


- Flow-through cyclic-aeration can sustain both biological nitrogen reduction and EBPR
- Aeration control using a DO probe at the effluent end of the basin caused anaerobic conditions at the influent end of the basin as predicted by the process model
- High influent VFA concentration likely bolster EBPR at this facility

- Significance

- Small WWTPs may be able to achieve EBPR in flow-through cyclic-aeration process potentially saving capital costs in basin expansion.


- Future

- Keep doing more with less
- Keeping the bugs happy




Nitrogen Removal and SRT

- Nitrification and denitrification requires longer SRTs than only nitrification.
- Cold weather in Wolfeboro requires high SRTs.



Process Evaluation

- Relatively high MLSS compared to industry standards.
- SRT spikes correspond to all basins being online (not actual 100 day SRT).
- Average SRT of 23 days




Secondary Effluent and Effluent Storage Pond (ESP)

- CBOD5 and TSS effluent values comply with NPDES permit
- Max day ESP effluent ammonia greater than NPDES permit
- Low effluent TP indicative of enhanced biological phosphorus removal (EBPR)

| Parameter | NPDES Permit | Average | Max Month ¹ | Max Day ² |
|--------------------------------|--------------|---------|------------------------|----------------------|
| Secondary Effluent | | | | |
| CBOD5 (mg/L) | - | 11 | 18 | 64 |
| TSS (mg/L) | - | 8.2 | 14 | 68 |
| Ammonia-N (mg/L) | - | 3.0 | 8.1 | 17 |
| Total Nitrogen (mg/L) | - | 3.6 | 4.0 | 8.8 |
| Total Phosphorus (mg/L) | - | 0.8 | 1.6 | 4.6 |
| Effluent Storage Lagoon | | | | |
| CBOD5 (mg/L) ³ | 30 | 7.6 | 10 | 55 |
| TSS (mg/L) ³ | 30 | 9.5 | 17 | 33 |
| Ammonia-N (mg/L) | 5 | 1.9 | 3.5 | 12 |
| Total Nitrogen (mg/L) | 10 | ND | ND | ND |
| Total Phosphorus (mg/L) | - | 0.8 | 1.1 | 4.3 |


1. Max month based on the 91.7th percentile.
 2. Max day based on the 99.7th percentile.
 3. CBOD5 and TSS limits are average monthly values.
- ND: Data not provided.

Process Performance



Spike in effluent BOD and effluent TSS corresponds to high influent loading and increased F:M ratio.

Process Performance



- Spikes in effluent NH₃-N and NO₃-N (typically in summer months)
- Consistently low NO₂-N concentrations indicate complete nitrification