



# Optimizing Aeration Control to meet the needs of Process Intensification

Paul Dombrowski, PE, BCEE, WEF Fellow  
Woodard & Curran, Inc.

NEWEA 2022 Annual Conference & Exhibit

**Navigating the Tides:  
FOSTERING DIVERSITY  
AND LEADING CHANGE**



# Warren, RI WWTF Background

- ▶ WWTF upgraded to secondary treatment in 1981
- ▶ NPDES Permit (expired in 2010)
  - Monthly Average Permitted Capacity = 2.01 MGD
  - Typical secondary treatment limits ( $\text{BOD}_5$ ,  $\text{TSS}=30 \text{ mg/L}$ ,  $\text{FC}=200 \text{ col/100 ml}$ )
- ▶ Daily flows from 2010–2015 averaged 1.88 MGD with max month flows exceeding 3 MGD and estimated peak flows of 9 MGD during Spring conditions



# 2010 NPDES Permit & 2013 Modification

- ▶ 2010 Permit included both monthly TN mass and conc. limits
- ▶ WWTF also needed flow limit increase
- ▶ 2013 Permit Modification
  - Monthly and Seasonal considerations for both flow and pollutant loading
  - Flow
  - Total Nitrogen
  - BOD<sub>5</sub> and TSS (17 and 23 mg/L seasonally)


Permit Season	Flow (MGD)	Monthly Mass Limit (lbs/d)	Seasonal Mass Limit (lbs/d)	Equivalent Concentration based on Seasonal Load Limit (mg/L)	Monthly Average Concentration Limit in Permit (mg/L)
<b>Limits from 2010 NPDES Permit</b>					
Winter	2.01	239.7	N/A	14.3	14.3
Summer	2.01	83.8	N/A	5.0	5
<b>Limits with typical monthly flow limit approach</b>					
Winter	3.43	239.7	N/A	8.4	8.4
Summer	3.43	83.8	N/A	2.9	2.9
<b>Limits from 2013 NPDES Permit Modification</b>					
Winter	3.43	N/A	239.7	8.4	9.5
Summer	2.53	N/A	83.8	4.0	5





# WWTF Upgrade Drivers

- Facility needs:
  - Increased wet weather capacity
  - Seasonal low level TN removal
  - Overall/Reliability Updates
- Facility Challenges:
  - Constrained site
  - Secondary clarifiers
- Limited available area, stringent TN limits and smaller secondary clarifiers required a high biomass solution – “process intensification”




# Variable Operating Mode (VOM) Process Summary


- ▶ Summer Permit Season
  - 4-Stage Bardenpho mode
  - 5 mg/L monthly TN limit, 4 mg/L seasonal
- ▶ Winter Permit Season
  - Modified Ludzack-Ettinger (MLE) mode
  - 9.5 mg/L monthly TN limit, 8.3 mg/L seasonal
- ▶ Wet Weather Operation
  - Contact Stabilization mode
  - Reduces MLSS concentration to increase secondary clarifier capacity while achieving a moderate level of TN removal
  - Process modelling predicts TN performance of 8-12 mg/L during contact stab. operation
- ▶ Mode selection impacts on Aeration System
  - Independent mixing and aeration were required for many zones
  - During overnight operation of 4-Stage or MLE mode, airflows to Main Aeration Zone (Trains 1B, 2B) are 0-20 scfm
  - During Contact Stabilization mode, airflows to Main Aeration Zone are 800-1,000 scfm




# 4-Stage Bardenpho Process



# Modified Ludzack-Ettinger Process




# Modified Contact-Stabilization Process







# 4-Stage Bardenpho Process – Warren, RI



# Trains 1A and 2A




# Trains 1B and 2B



# Aeration and Mixing Key for Efficient BNR

- Required multiple modes of operation
- Flexibility with “swing zones”
  - Anoxic, Aerobic, or
  - Operating under Aerobic conditions but under very low airflows
- Invent Mixer/Aerators selected during design
  - Provides independent mixing
  - Allows turn down to protect against over aeration
  - Provides rapid increase in speed for efficient O<sub>2</sub> delivery
  - Allows precise control of DO in every zone of reactors



# Typical Fine Bubble Aeration Control System

- System consists of:
  - Blowers deliver the air through the piping system
  - Valves control the distribution of air to the various diffuser grids in the aeration tanks
  - Diffusers generate the fine bubbles for efficient diffusion of oxygen into mixed liquor
  - Dissolved oxygen (DO) probes measure the oxygen levels in the mixed liquor
  - Airflow meters measure the airflow to each portion of the system receiving independent control
- Typical control approach includes:
  - DO probes measure actual vs. setpoint, and the control system determines a new target airflow with the blower speed adjusted based on overall system demand error
  - Valves are modulated to achieve new target airflows through each control valve with 1 valve remaining fully open as the “Most Open Valve” (MOV)



# Typical Fine Bubble Aeration Control System

- Keys to Precise and Stable Aeration Control
  - All control logic “runs” through airflow meter values both for blower speed and valve position control
  - Accurate control requires stable control of blower output and precise modulation of airflows, typically with specialized valves or actuators




Iris Diaphragm Valve



Rexa Hydraulic Actuator with Butterfly Valve

# Aeration Control with Mixer/Aerators

- Mixer speed impacts 2 aspects of  $O_2$  transfer:
  - Faster mixer speed = better oxygen transfer
  - Faster mixer speed = “pulls” more air to that mixer/aerator
  - Helps control air distribution and reduces valve changes
- Mixer speed changes provide exceptional aeration turndown
  - Typical 2 operating blower with diffused air provides 4:1 turndown
  - Mixer/Aerators provide 50:1 turndown
- Precise DO control allows optimization of each reactor zone
  - Provides precise DO operation in aerobic zones
  - Minimizes DO carry over to adjacent zones
- W&C Process and SCADA team developed this enhanced DO control method and worked closely with Mixer-Aerator supplier



Mixer/Aerator body  
and sparge ring



Train 2A

# Mixer-Aerator System Dissolved Oxygen Control

1. System evaluation timer – 10 minutes (floating proportional)
  - a. Converts DO error from setpoint in all zones to a new speed target for blowers
  - b. Use of mixer/aerators prohibits use of airflow as an intermediate parameter for valves
2. Mixer/Aerator changes speed directly in response to DO – 10 to 30 seconds (proportional with “downshift and range control mechanisms”)
  - a. 0.1% speed change when outside DO deadband
  - b. Mixer/aerators change both O<sub>2</sub> transfer efficiency and airflow to each zone
3. Valve position evaluation timer – Typically every 5 minutes (step)
  - a. Each header calculates a change in valve position when outside of deadband
  - b. Single deadband – if outside deadband, changes valve position 2%
4. Valves use “Most Open Valve” (MOV) logic, but...
  - a. Mixer/aerators function as “inner” deadband (0.1 mg/L DO)
  - b. Valves function as “outer” deadband (0.2 mg/L DO)



00: 09: 34

01 / 15 / 22

# Town of Warren Rhode Island

## Primary Effluent Trend

NAVIGATION  
MENU

TRENDS

ACKNOWLEDGE  
ALL

ALARMS

Alarm Banner

0

2


0

0

0

Primary Effluent Trend Saturday, January 1, 2022 - Sunday, January 2, 2022

Primary Effluent Flow on 1/1/2022



Caption	12:09:36 AM	Min	Max
PRIMARY EFFLUENT FLOW	1.35	0.00	3.00 MGD
Effluent Pump P504 Spd Fdbck	0.00	0.00	3.00 %

Display PRIMARY EFFLUENT TREND

Clear Clear All



00: 04: 58

01 / 15 / 22

# Town of Warren Rhode Island

## BLOWER SPEED

NAVIGATION  
MENU

TRENDS

ALARMS

ACKNOWLEDGE  
ALL

Alarm Banner

0

2


0

0

0

BLOWER SPEEDS Saturday, January 1, 2022 - Sunday, January 2, 2022

Blower Speed on 1/1/2022



Caption	12:04:59 AM	Min	Max
BLOWER 1 SPEED	0.00	0.00	100.00 %
BLOWER 2 SPEED	54.52	0.00	100.00 %
BLOWER 3 SPEED	0.00	0.00	100.00 %
BLOWER 1 RPM	0.00	0.00	3,650.00 rpm
BLOWER 2 RPM	1,949.00	0.00	3,650.00 rpm
BLOWER 3 RPM	0.00	0.00	3,650.00 rpm
BLOWER LOW DEMAND SPEED	60.00	0.00	100.00 %





00: 00: 37

01 / 15 / 22

# Town of Warren Rhode Island

## DO Trend

NAVIGATION  
MENU

TRENDS

ACKNOWLEDGE  
ALL

ALARMS

Alarm Banner

0

2

0

0

0

✓

👤

🔄


DO TREND Saturday, January 1, 2022 - Sunday, January 2, 2022

4:03:27 AM

DO Values on 1/1/2022

1B and 2B Aeration Zones  
DO SP = 1.3 mg/L +/- 0.3

Train 1A and 2A Pre-Swing Zones  
DO SP = 2.0 mg/L +/- 0.2



11:58:58 PM

4:46:58

9:34:58

2:22:58

7:10:58

11:58:58 PM

Caption	12:00:38 AM	Min	Max	
DO AE-530A Train 1A Pre-Swing 1	1.99	0.00	5.00	mg/L
DO AE-531A Train 1A Pre-Swing 2	2.07	0.00	5.00	mg/L
DO AE-555B Train 1B Aeration	2.21	0.00	5.00	mg/L
DO AE-550B Train 1B Post-Swing 1	0.72	0.00	5.00	mg/L
DO AE-530B Train 2A Pre-Swing 1	1.98	0.00	5.00	mg/L
DO AE-531B Train 2A Pre-Swing 2	2.03	0.00	5.00	mg/L
DO AE-555A Train 2B Aeration	2.10	0.00	5.00	mg/L
DO AE-550A Train 2B Post-Swing 1	0.05	0.00	5.00	mg/L



00: 03: 00

01 / 15 / 22

# Town of Warren Rhode Island

## Header Valve Position

NAVIGATION  
MENU

TRENDS

ACKNOWLEDGE  
ALL

ALARMS

Alarm Banner

0

2

0

0

0

0


Header Valve Position    Saturday, January 1, 2022 - Sunday, January 2, 2022

Aeration Valve Position Changes on 1/1/2022


1B and 2B Air Valves @ full open

2A Air Valve

1A Air Valve



Caption	12:03:02 AM	Min	Max	Units
Train 1A Header Valve	27.00	0.00	100.00	%
Train 2A Header Valve	21.00	0.00	100.00	%
Train 1B Header Valve	71.00	0.00	100.00	%
Train 2B Header Valve	70.00	0.00	100.00	%





01: 19: 41  
01 / 15 / 22

# Town of Warren Rhode Island

## DO Trend

- NAVIGATION MENU
- TRENDS
- ALARMS
- ACKNOWLEDGE ALL

Alarm Banner

0


2

0

0

0

DO TREND Wednesday, September 1, 2021 - Thursday, September 2, 2021



Design Max Daily Flow = 4.77 MGD  
Design Peak Hourly Flow = 9.08 MGD  
September 2, 2021 – TS Ida  
Daily Flow = 7.13 MGD  
Peak Hourly Flow = 11.29 MGD  
Effluent Quality:  
BOD<sub>5</sub> = 3 mg/L  
TSS = 3 mg/L  
NH<sub>3</sub>-N = 0.2 mg/L  
Total Nitrogen = 3.05 mg/L


DO Concentrations  
Tropical Storm Ida – 9/1 – 9/2

	Caption	1:19:42 AM	Min	Max	
	DO AE-530A Train 1A Pre-Swing 1	2.05	0.00	5.00	mg/L
	DO AE-531A Train 1A Pre-Swing 2	2.04	0.00	5.00	mg/L
	DO AE-555B Train 1B Aeration	2.13	0.00	5.00	mg/L
	DO AE-550B Train 1B Post-Swing 1	0.67	0.00	5.00	mg/L
	DO AE-530B Train 2A Pre-Swing 1	2.00	0.00	5.00	mg/L
	DO AE-531B Train 2A Pre-Swing 2	2.09	0.00	5.00	mg/L
	DO AE-555A Train 2B Aeration	2.09	0.00	5.00	mg/L
	DO AE-550A Train 2B Post-Swing 1	0.09	0.00	5.00	mg/L



# Summary

- Combination of mixer/aerators and most open valve approach provides responsive, stable, precise and efficient DO control
- Does not require specialized or expensive valves or actuators
- In 4-Stage Mode, system consistently achieves  $<5$  mg/L for BOD and TSS as well as  $<3$  mg/L for Total Nitrogen without supplemental carbon or alkalinity addition
- Turndown capability of the system has been demonstrated at 50:1 while maintaining accurate DO control





# Thanks

- Town of Warren:
  - Kate Michaud
  - Bob Rulli
- Suez / H2O Innovation
  - Dave Komiega
  - Norm Blank
  - Eric Komiega
- Woodard & Curran
  - Jon Himlan
  - Craig Gaudet







# Questions

[pdombrowski@woodardcurran.com](mailto:pdombrowski@woodardcurran.com)