

# WPCA Facilities Planning in Bridgeport:

## Balancing Critical WWTP Infrastructure Needs & Resolving CSO Discharges

Alexandra Greenfield  
(Bowen), P.E.

Jane Madden, P.E.,  
BCEE

Lauren McBennett  
Mappa, P.E.

*January 24, 2022*




**CDM  
Smith**



# WPCA, City of Bridgeport, CT

- Combined Sewers
- Separated Sewers
- Pump Stations
- ★ WWTPs
- Sewer Regulators



# Administrative Order

## *Long-Term CSO Control Plan (LTCP)*

### **Objective: control the 1-year, 24-hour storm**

- Illicit connection elimination program
- Sewer Separation in four sewersheds
- Low impact technologies (green infrastructure)
- Two, 1.5-MG CSO storage tanks
- CSO relief sewers
- Deep rock CSO storage tunnel
- Continuous WQ monitoring and modeling program

Approved by  
CT DEEP in  
January 2018

# Second Administrative Order: March 2019

## *WWTP Facilities Plan*

### **Objectives:**


- Improve performance and operation of WWTPs
- Replace aging assets
- Manage high flows to reduce CSOs
- Improve wet weather discharge quality
- Improve BNR to optimize nitrogen credits
- Provide system resiliency
- Update instrumentation and controls

# West Side WWTP

- AADF: 30 mgd
- Secondary Treatment Capacity: 58 mgd
- WW Capacity: 90 mgd
- General Permit for Nitrogen: 1,041 lb/day (4.2 mg/L)
- 19 NPDES Permitted CSO Outfalls



# West Side WWTP Process Flow






# East Side WWTP

- AADF: 10 mgd
- Secondary Treatment Capacity: 24 mgd
- WW Capacity: 40 mgd
- General Permit for Nitrogen: 362 lb/day (4.3 mg/L)
- 6 NPDES Permitted CSO Outfalls




# East Side WWTP Process Flow






# Revisiting & Refining the LTCP's SWMM Model



- LTCP did not evaluate expanding WW capacities at WWTPs per EPA's CSO Control Guidance Documents
- Modeled CSO volumes at various WWTP capacities @ 1-year, 24-hour storm


# Increase WWTP Capacities to Reduce CSOs

## West Side WWTP



Consider Expansion to: 90, 140, 180 & 200 mgd

## East Side WWTP




Consider Expansion to: 40 & 80 mgd

# How to expand capacities at built-out sites?

West Side WWTP: 8.5 acres




East Side WWTP: 8.8 acres




# Sizing Up Other WWTPs:

*MG-treated/Acre*



# Sizing Up Other WWTPs:

*MG-treated/Acre*



# Liquid Treatment Train Technologies

## INFLUENT PUMPING

Dry-Pit Direct Coupled Centrifugal  
**Dry-Pit Extended Shaft Centrifugal**  
Dry-Pit Submersible Centrifugal  
Wet-Pit Submersible Centrifugal  
Axial Flow  
Archimedes Screw

## SCREENING

Climber Type Screen  
**Multiple Rake Bar Screen**  
Perforated Plate/Band Screen  
Center Flow Screen  
Step Style Screen

## GRIT REMOVAL

Vortex Grit  
**Stacked Tray**  
Aerated Grit

## PRIMARY TREATMENT

Traditional  
Traditional with CEPT  
**Primary Filtration**  
High Rate Clarification

## SECONDARY TREATMENT AND NITROGEN REMOVAL

**Conventional 4-Stage Activated  
Sludge**  
**Conventional 4-Stage w/IFAS**  
Membrane Bioreactor (MBR)  
Membrane Aerated Biofilm Reactor (MABR)  
Downflow Denite Filters  
Upflow Denite Filters

## DISINFECTION

Sodium Hypochlorite  
Chlorine Dioxide  
Peracetic Acid (PAA)  
Ozone  
**Ultraviolet Irradiation**

## SLUDGE THICKENING

Dissolved Air Floatation  
Gravity Belt Thickeners  
**Rotary Drum Thickeners**  
**Gravity Thickeners**  
Centrifuge Thickening

## SLUDGE DEWATERING

Belt Filter Press  
Centrifuge  
Rotary Press  
Screw Press

## SLUDGE STABILIZATION

Digestion  
Gasification  
Incineration  
Drying

## ODOR CONTROL

Carbon Adsorption  
Biotrickling Filters  
**Biofiltration**  
**Chemical Scrubbers**  
Dispersion Fan

## EFFLUENT PUMPING

Dry-Pit Direct Coupled Centrifugal  
Dry-Pit Extended Shaft Centrifugal  
Dry-Pit Submersible Centrifugal  
Wet-Pit Submersible Centrifugal  
**Axial Flow**  
Archimedes Screw


### KEY

Candidate Processes  
Processes Passing Screening  
**Recommended Process-**



# Preliminary Treatment

- Deficient screening
  - Equipment > 30 years old
  - No grit removal
  - Primary sludge degritting ineffective
  - Entire facility below existing flood el.
- Deficient influent pumping
  - 3 duty/1 standby 23,500 gpm @ 51 TDH
  - 400 HP motors w/VFDs
  - At pumped flows >80 mgd, wet well level > high level set point



# Preliminary Treatment Recommended Improvements

Coarse Bar Screens

Pumping

Fine Screens

Grit Removal



Multiple Rake Bar Screen





Climber Screen

Dry-pit centrifugal – close coupled

Extended shaft centrifugal


Dry-pit submersible centrifugal




Perf plate/band screens

Center flow screens


Step screens



Vortex grit




Headcell



Aerated grit

# Dual-Use Wet Weather/Primary Clarification

Flow Condition	Overflow Rate (all three tanks in service)	TR-16 Overflow Rate
Design ADF: 30 mgd	2,042 gpd/ft <sup>2</sup>	1,200 gpd/ft <sup>2</sup>
Design Wet Weather: 90 mgd	6,127 gpd/ft <sup>2</sup>	3,000 gpd/ft <sup>2</sup>






- Undersized
- Poor performance (negligible removal)
- Conventional clarification + CEPT not viable



# Alternative Primary Treatment Technologies

PCMF Adaptations



**AquaPrime**  
*Primary Cloth Filtration*  
 Aqua Aerobic Systems, Inc.

**Proteus**  
*Upflow Media Filtration*  
 Tomorrow Water




**ACTIFLO**  
*Ballasted Flocculation*  
 Kruger





# Alternative Primary Treatment Technologies



PCMF Adaptations



**AquaPrime**  
*Primary Cloth Filtration*  
Aqua Aerobic Systems, Inc.


**Proteus**  
*Upflow Media Filtration*  
Tomorrow Water

**ACTIFLO**  
*Ballasted Flocculation*  
Kruger






# Biological Nitrogen Removal

- 6 bioreactors (MLE) □ 3 secondary clarifiers
- Insufficient  $V_{\text{aeration}}$  [ $>5$  MG deficit]
  - Carry HIGH MLSS exceeding secondary clarifier capacity (solids washout)
- Conventional suspended growth AS processes NOT viable
- Must intensify process






# Alt Integrated Activated Sludge Processes



**IFAS**  
*4-Stage Suspended AS w/ Media +  
 Secondary Clarification*



**ZeeLung (MABR)**  
*2-Stage Suspended AS  
 w/Membrane Diffused Air in  
 Anoxic + Secondary Clarification*







Figure 6: ZeeLung installation concept at Bridgeport WWTP West Plant

**MBRs**  
*4-Stage Suspended AS +  
 Membrane Filtration*



# Alt Integrated Activated Sludge Processes



**IFAS**  
*4-Stage Suspended AS w/ Media + Secondary Clarification*

**ZeeLung (MABR)**  
*2-Stage Suspended AS w/Membrane Diffused Air in Anoxic + Secondary Clarification*

**MBRs**  
*4-Stage Suspended AS + Membrane Filtration*






Figure 6: ZeeLung installation concept at Bridgeport WWTP West Plant



# Disinfection

- Dual-use wet weather and secondary effluent
- Sodium Hypochlorite and sodium bisulfite
- CCT old primary settling tanks - not appropriately sized
  - L:W ratio causes short circuiting
- Aerate CCT
- Scum on CCTs
- Below 100-year flood plain elevation




# Alternative Disinfection Technologies

- Conventional disinfection w/hypo and dechlor not feasible due to site constrains
- Peracetic acid (PAA) disinfection
  - Potentially short contact time
  - No dechlorination required
- UV disinfection
- Combined primary effluent + secondary effluent system?
- Two separate disinfection systems?



# 13 Treatment Trains w/Site Layouts Developed




## Extensive considerations taken into account:

- Maintenance of plant operations
- Hydraulics
- Constructability

# Facilities Plan Revised Schedule



## Overall Schedule Considerations






# Dual-Use Primary/Wet Weather Treatment Pilot

- Establish TSS, BOD & TKN removals
  - Limit BOD removal
- Monitor PE UVT for UV disinfection system size
- Confirm vendor proposed design criteria
  - Hydraulic loading rates
  - Solids loading rates
  - Backwash frequencies & volumes
- Quantify solids generation & settleability
- System response to FOG
- Inform O&M costs
- Refine system performance guarantees
- Demonstrate system operation to staff

# Revised Implementation Schedule Drives Results



## CONTACT US!

**Jane Madden**

(617) 452-6545

MaddenJE@cdmsmith.com

**Allie Bowen**

(617) 452-6669

BowenAB@cdmsmith.com



Water  
Partnership  
with **CDM  
Smith**

◆ Precious resources ◆ Powerful insights ◆ A future we build together

Learn more about the water partnership  
at [cdmsmith.com/water](https://cdmsmith.com/water) and [@CDMSmith](https://twitter.com/CDMSmith)