

# Feasibility and Design of a Biosolids Dryer at the LAWPCA WWTP

January 24, 2022



# Today's Agenda


1. LAWPCA History
2. Feasibility Study
3. Design Considerations
4. Where do we go from here?



# Short History of LAWPCA and Biosolids Management

# Lewiston Auburn Water Pollution Control Authority: A Short History

- 1974: Authority formed to treat sewage from the Cities of Lewiston and Auburn
- Service population: ~60,000 + septic and holding waste from surrounding communities
- 18 significant industrial users
- Design Flow: 14.2 MGD (activated sludge)
- 1988: started land applying dewatered biosolids, excess went to landfill
- 1992: Compost Facility opened
- 2009: Path to solids volume reduction chosen (anaerobic digestion)



# LAWPCA Historical Biosolids Management

- 2013: Anaerobic digesters online
- 2016: Dewatering equipment upgraded to screw presses
  - 2012 dry volume = 24,000 yd<sup>3</sup>/yr
  - AD + screw presses = 8,000-8,300 yd<sup>3</sup>/yr
- 2018: Biofilter issues at compost facility
- March 2019: DEP PFAS memo comes out halting land application and composting
- Spring /summer 2019: soil testing on LAWPCA sites. Annual biosolids management cost increases over \$300,000
- Fall 2019: Pilot study at CF (no use of biofilter)
- Spring 2020: DEP approves operation of compost facility without use of the biofilter, but ultimately moth-balled again due to staffing and capital needs as well as PFAS regulatory uncertainty



Lewiston-Auburn Wastewater Treatment Plant



Former Compost Facility

# LAWPCA Current State of Biosolids Management

- 2021 biosolids: 75% landfill at a disposal cost of \$95/ton and 25% land application
- Concerns
  - Landfill acceptance and limited regional outlets
  - USEPA PFAS risk assessment ongoing
  - LD1600: Maine PFAS surcharge fee
  - PFAS unknown future impacts
- Brown & Caldwell to perform Dryer Feasibility Study
- Currently, dryer technology is the most promising option to best position LAWPCA to pivot regardless of where PFAS goes



Lewiston-Auburn Wastewater Treatment Plant




Former Compost Facility



# Dryer Feasibility Study: LAWPCA

# PFAS Concerns



## Maine DEP Establishes Aggressive Requirement for PFAS Testing in Biosolids

Presque Isle to spend \$15.6M fixing its wastewater sludge problem

'Forever chemicals' found in 18 private wells near Fairfield dairy farm

Maine DEP enacts biosolids screenings standards

## Concerns grow over tainted sewage sludge spread on croplands

*Bulk agriculture land application of biosolids slows to a halt...*



# Market Overview

- Across the Eastern US, landfill costs are going up 50-200%
- Landfills are getting tired of biosolids
- In the Northeast, land application opportunities are limited
- PFAS concerns exerting additional pressures (PFAS riders in contracts)
- Have observed management costs as high \$130-150/WT in Maine




# Why Evaluate Thermal Drying

## Pros


- Volume Reduction (70%-85%)
- Reduces Truck Traffic and Disposal Fees
- Class A Beneficial Reuse
- Less Odorous Product

## Cons

- Energy Consumption
- Safety Concerns
- Capital Investment
- **Does Not Destroy PFAS**



# Drying as a Tool to Address Biosolids Management Risks



Reduced volume, moisture, content and odors makes dried product more amenable to landfilling

Opens up non-agricultural and soil or fertilizer blending outlets


Can be used as alternative fuel for offsite industry or incorporated into future non-incineration destruction process

# Energy Content of Solids

~8,000 Btu/lb

Combustion Risk

- Oxygen
- Ignition Source
- Combustible Dust




Critical Temperatures	Degrees F
Temperature at which self heating can occur	±122
Minimum dust cloud ignition temperature (NFPA 654)	329

# Existing Conditions




# High-Level Dryer Overview and Screening


**Rotary Drum**



**Belt**



**Contact (Paddle)**




## Greenfield Dryer Installation at Small – Medium Sized Facility


Appropriate to Size	2-3d/wk operation	Can run 24/7	Can run 24/7
Operational Complexity	Highest	Moderate	Lower (8hr shutdown)
Capital Cost	3.0x	1.0x	1.5x
Safety	Low	High	Low

# Belt Dryer Type Comparison: Heating


## Direct-Fired (Gryphon, Haarslev, Andritz)



## Indirect-Fired (Shincci, Huber, Suez, Kruger, Andritz)



## Heat Pump (Shincci, Suez)



# Hot Water Belt Dryer Commercial Offerings

## Established

Manufacturer	US Installs	Operating Yrs.	Heating	Product Screening
Andritz	5	40	Direct/Indirect/Heat Pump	Y
Huber	5	16	Indirect	N

## Emerging


Manufacturer	US Installs	Operating Yrs.	Heating	Product Screening
Haarslev	3	11	Indirect/Direct	Y
Shincci	2	1	Indirect/Heat Pump	N
Suez	2	1	Indirect/Heat Pump	N



# Recommended Alternative: Indirect-Fired Belt Dryer with Building Addition

## Key Advantages

- Class A product
- Utilizes Waste Heat from Biogas Cogeneration
- Lower Operating Temps for Safety in Operation
- Lower Price Point
- Easier Operation and Maintenance






# Preliminary Design Considerations

# Renewable Energy

- CHP Cogeneration Facility (2x230 kW engines) Installed with the Digesters 2013
- Had maintenance issues, poor runtime, vendor went out of business
- 2021 Engine Overhaul
- New service provider LIMA Company
- One engine online burning digester gas. A second will be online soon and LAWPCA will resume looking for beneficial feedstocks



**EXISTING LAWPCA HEAT AND ENERGY BALANCE**  
**AVERAGE SUMMER ANALYSIS (NO HSW)**  
 (ALL UNITS IN MMBTU/HR)



**Notes:**

Systems shown schematically for simplicity (actual heat loop/pumps not shown)

AA = annual average, DG = digester gas, F = fuel, HW = hot water


Assumes 45° F sludge winter temp and 65° F sludge summer temp and 30% shell loss


Equipment capacity and efficiency per June 2011 Anaerobic Digestion / Energy Recovery Project Drawings Design Criteria (G-2)


# Building Considerations

- Pre-Engineered Building
- Spread Footing Foundation
- Flat Roof to match existing Process/Administration Building
- Partitioned Electrical Room
- Process Room Classified Class 2 Div 2 within 10 feet of dryer
- Rough Dimensions 84' x 40' x 30' high













# Life Cycle Cost Analysis

Baseline – 5% management cost escalation, dried cake landfilled



Worst Case – 7% management cost escalation, dried cake land applied



# Next Steps

- Present Results of Revised Economic Evaluation to Board of Directors
- Pursue funding opportunities
- Preprocurement of Dryer
- Final Design
- Construction





# Thank you. Questions?


Don Song, P.E.

[dsong@brwnncald.com](mailto:dsong@brwnncald.com)

John Ross, P.E.

[jross@brwnncald.com](mailto:jross@brwnncald.com)

# Hot Water Loop



- New Boilers
- 194 degree F temperature minimum dryer
- 170 degree F temperature maximum at engine (without radiating heat)

**Brown** AND  
**Caldwell**

