

# Innovative Disposal System Performs Well Under Performance-Based Groundwater Discharge Permit

NEWEA Annual Conference 2022

January 2022

Adam Higgins, EIT



**Project Background**  
**Hydrogeologic Evaluations**  
**Effluent Disposal Design**  
**WWTF Design**  
**WWTF Performance**  
**Rapid Infiltration Basin Performance**  
**Summary/Conclusions**  
**Acknowledgements**

**engine**



## Developer

- Affordable Residential Housing (Ch. 40B)
- 300 Bedrooms
- 40 More Bedrooms added Later



## Effluent Disposal

- Challenging Site for Disposal
- Tight Glacial Soils, Stumps
- Near and Upgradient of Town Drinking Water Supply
- Property Abuts Landfill, Wetlands, and MassDOT Salt Storage



## Monitoring Requirements

- MassDEP Groundwater Discharge Permit Requirements, Standard
- Town Water Commission Requirements, More Stringent








- ENSR
- 2-Year Effort
- 69 Test Pits, 52 first year
- 72 Soil Borings
- 21 Ledge Probes

# ngine

# Hydrogeologic Study – Continued



- 30 Monitoring Wells
- 3 Piezometer Locations
- 11 Infiltration Tests
- Loading Test Cell

ngine






Constructed Test Cell

## Hydraulic Load Test

- Why needed?
  - Favorable sands and gravels found 30' down during site work
  - Suitable Location if proven
- Test Specifics
  - Test Cell 2,800 sq. ft.
  - 5 weeks – one of the wettest Autumns on record
  - Proved at least 3 gpd/sq. ft. possible

## Groundwater Discharge Goals


1. Avoid Ponding at RIB Surface
2. Maintain 4-foot Vadose Zone at Seasonal High-water Conditions
3. Prevent Early Emergence of Effluent-impacted Groundwater
4. Account for Fate of Nutrients at Downgradient Receptor



# Engine



# Fluent Mosal Design



- Sitework
- Over-excavation to expose favorable soils
- 20 feet of crushed stone
- High Groundwater ~95'

gine

## Wastewater Treatment Plant Design - Continued



- 4 RIBs, 40 x 40 feet each
- Design loading rate, 3.5 gpd/sq. ft. on top area, 1.9 gpd/sq. ft. on exposure to favorable soil area (approx. 20 feet below grade)
- 33,500 gpd capacity

gine

### MassDEP Conclusions

- Thorough Hydrogeologic Investigation
- Appropriate Effluent Disposal Design
- Standard Groundwater Discharge Permit Issued
- Typical Monitoring Well Requirements


### Town Water Commissioners Requirements

- Build It, But Performance Needs to Be Proven
- Prove Mound No Closer Than 4 feet Below RIB Surface
- Prove Mound No Closer Than 6 Inches Below Ground Surface 150 Feet Away
- If Mound Is Too High, Reduce Effluent Flow
- Prove No Significant Groundwater P Concentration 100 Feet Away
- If P Migration Occurs, Add P Removal In WWTF
- Design WWTF to Total Nitrogen of 5 mg/L

# Engine




# The Layer – Monitoring Requirements



# WTF Design

## Process Flow Schematic



- Residential WW
- Package MBR System
- 37,900 gpd
- Pre-Treatment Tank
- Flow Equalization
- Bioreactor – Anoxic, Aeration, Post-Anoxic
- Membrane System
- UV Disinfection
- Effluent Pumping
- Solids Holding

# ngine


## WTF Performance (2018-2021)

Parameter	Effluent
Flow (gpd)	
Maximum Day	46,130
Maximum Month	27,082
2018-2021 Average	20,750
BOD (mg/L)	
2018- 2021 Average	2.4
TSS (mg/L)	
2018- 2021 Average	9.0
Total Nitrogen (mg/L)	
2018- 2021 Average	2.4
Total Phosphorus (mg/L)	
2018- 2021 Average	0.6
Ortho-Phosphorus (mg/L)	
2018- 2021 Average	0.4


IGF  
Engine




# WTF Performance – Flow Over Time



# 3 Performance Water Table Over Time, DEP Wells



## 3 Performance Water Table Over Time, MW-4DG



RIB Surface Elevation


4-Ft Vadose Threshold

MW-4DG Water Level

gine



# 3 Performance Water Table Over Time, MW-6DG




MW-6DG Surface Elevation

MW-6DG Water Level

gine


## 3 Performance Phosphorus Over Time, DEP Wells



- Consistent over time
- Below 0.5 threshold
- Sometimes Below Upgradient Values

gine

## 3 Performance Nitrate Over Time, DEP Wells



- Very low concentrations
- Consistent results over time
- No appreciable difference between up and downgradient

gine



- **Very Difficult Site for Treated Effluent Disposal**
- **Complicated Hydrogeologic Investigations and Evaluation**
- **MassDEP Approved Study and Design, Typical Permit Issued**
- **Protection of Town Water Supply Led to Stringent Monitoring and WWTF Design**
- **9 Years of Excellent WWTF and Effluent Disposal Performance**
  - **Proven WWTF and Disposal Design**
  - **Met 4 Groundwater Discharge Goals**

# Engine

# WRIGHT Engine

acknowledgements



WhiteWater Inc.



Wright-Pierce Co-Authors  
Mike Giggey, PE



Wright-Pierce Co-Authors  
Kevin Olson, PE

Contact Information



Adam Higgins

[adam.higgins@wright-pierce.com](mailto:adam.higgins@wright-pierce.com)

978.416.8020

Engine

WRIGHT  
THANK YOU  

---

Engine