

How's Brockton Doing? 2 Years of Process Optimization to Achieve 3 mg/L TN

Brockton, Massachusetts – Advanced Water Reclamation Facility

Bill McConnell, CDM Smith
David Norton, City of Brockton
David Salvador, Veolia NA

January 24, 2023




**CDM
Smith**



2023 Annual Conference & Exhibit
January 22-25 | Boston

Topics

- Background/history
- BNR upgrade/configurations
- Performance Summary
 - Effluent quality
 - rDON
- On-Line instrumentation and Optimization




Brockton AWRF

- City population <100,000
- Activated sludge late 1960s
- Expansion early 1980s (2-stage process)
 - 18 mgd average annual flow
 - 36 mgd max day flow
 - 60 mgd peak
- Upgrade in mid 2000s (nutrient removal)
 - Expansion to 20.5 mgd
 - N removal to 5.5 mg/L TN (MLE)
 - Chemical P removal to 0.2 mg/L
 - AquaDiamond cloth filters




Brockton AWRF




3 mg/L TN Pending...?

- Around 2012-2013 Brockton anticipated that at some point that a TN limit might be included in NPDES permit
- 3 mg/L a possibility?
- Conceptual evaluation of alternatives
 - Option 1: Achieve 3 mg/L TN with existing (modified) processes
 - Option 2: Add tertiary denitrification (at cost of \$10Ms)
 - Process evaluation determined that Option 1 could work – but would be challenging
 - Piloting conducted to verify possible performance




Process Model Predicted Nitrogen Profile



Piloting

- One of AWRF's treatment trains modified
- Confirmed that 4-stage Bardenpho followed by effluent filters can achieve 3 mg/L TN




2 Years of Pilot Nitrogen Removal Performance

Parameter	Average	Maximum
NH ₃ -N	0.12 mg/L	0.31 mg/L
NO ₂ -N	0.011 mg/L	0.020 mg/L
NO ₃ -N	1.16 mg/L	2.91 mg/L
TIN	1.29 mg/L	3.1 mg/L



NPDES Limits (2017 Renewal)

	Average Monthly	Average Weekly	Maximum Daily
CBOD5 (5/1 – 10/31)	5 mg/L	8 mg/L	15 mg/L
CBOD5 (11/1 – 4/30)	15 mg/L	25 mg/L	30 mg/L
TSS (5/1 – 10/31)	5 mg/L	8 mg/L	15 mg/L
TSS (11/1 – 4/30)	15 mg/L	25 mg/L	30 mg/L
Total phosphorus (4/1 – 10/31)	0.101 mg/L	--	--
Total phosphorus (9/1 – 3/31)	1.0 mg/L	--	--
Ammonia-nitrogen (6/1 – 10/31)	1 mg/L	1 mg/L	1.5 mg/L
Ammonia-nitrogen (11/1 – 11/30)	6.3 mg/L	--	--
Ammonia-nitrogen (12/1 – 4/30)	9.5 mg/L	--	--
Ammonia-nitrogen (5/1 – 5/31)	3.2 mg/L	--	--
Total nitrogen (5/1 – 10/31)	450 lbs/day (seasonal average)		


Aeration Basin No. 1 Process Layout (No. 2 Similar)



Aeration Basin Nos. 3 and 4 Process Layout





Aeration Basin No. 7 Process Layout (Nos. 5 and 6 similar)





Basin Modifications





Basin Modifications





Effluent TN Concentrations





Effluent TN Loads




2021 Effluent Ammonia and Nitrate






2022 Effluent Ammonia and Nitrate




Analyzer Data




May 2021 Observations



July 2021, Basin 3: Nitrification and IR rate




May 2022 – TIN Comparison




ABAC – Ammonia-Based Aeration Control



- Installed in northern system (basins 1-4)
- Operational April 21; ammonia setpoint of 0.5 mg/L in aerobic zone
- Moved sensor to middle of zone; ammonia setpoint 1.0 mg/L
- Increased setpoint to 1.3 mg/L in 2022



June 2022 – ABAC Performance



June 2022 – ABAC Performance



Conclusions

- Process performance has demonstrated that the Brockton AWWRF can achieve 3 mg/L TN without tertiary denitrification
- Not easily!
 - Diligent operation
 - Significant investment in instrumentation (initial and ongoing)
 - High-performing effluent filters to remove particulate TKN
 - rDON is a potential issue
- Supplemental carbon still available
- ABAC system is providing benefit

Connect With Us!



Find more insights through our water partnership at cdmsmith.com/water and [@CDMSmith](https://twitter.com/CDMSmith)



Bill McConnell

CDM Smith

401-457-0318

mcconnellwc@cdmsmith.com

David Norton

City of Brockton

508-580-7885

dnorton@cobma.us

David Salvador

Veolia North America

508-580-7885

david.salvador@veolia.com