



Improving Treatment to Reduce Storage

Erik Osborn, PE
Kevin Trainor, PE


January 24, 2023





Agenda

- Background
- Technical Approach
 - ▶ Collection System Improvements
 - ▶ Treatment Plant Optimization
 - ▶ Right-Sized Storage
- Conceptual Design and Cost Estimating
- Conclusion



Background – Wastewater Collection & Treatment

- City of Auburn
 - West side of Androscoggin River
 - Pop ~24,000
- Auburn Sewerage District (ASD)
 - ~112 miles collection system piping
 - 4"-54"
 - Crosses Androscoggin River through triple siphon (2x18" 1x24")
- City of Lewiston
 - East side of Androscoggin River
 - Pop ~37,000
 - ~155 miles collection system piping
 - 4"-6'x12'
- Lewiston Auburn Water Pollution Control Authority (LAWPCA) WWTP
 - Constructed 1971
 - Primary + Secondary + Disinfection
 - 32 MGD Peak Wet Weather Capacity

Background – CSO Abatement Progress (First CWAMP in 1998)

	ASD	Lewiston	LAWPCA
CSO Outfalls (initial)	8	32	1
CSO Outfalls (present)	2	8	1
Annual CSO Volume (MG) 2000	45	100	200
Annual CSO Volume (MG) 2017 – 2021	0.2 – 1.7	8.5 – 23	14.5 – 33.7
Percent Public Roads Separated	100%	96%	NA
Investment in Reduction 2000 – 2021	\$22M	\$37.5	\$3.25
Cost per MG (approx.)	\$0.5M	\$0.4M	\$0.02M



**Avg:
\$0.2M/MG**

Next Step - Storage at LAWPCA (3.1 MG)	
Storage Tank	\$40+M
Annual CSO Volume Post Project (est.)	0-8 MG
Cost per MG (approx.)	\$2+M

Project Objective

Eliminate overflow at Structure B during 1-year, 6-hour design event: 2.05 inches; 1.6 in/hour

CSO Event February 27, 2020




LAWPCA WWTP

Project Approach




**Collection System
Analysis**



**Treatment Plant
Optimization**


Design Event Storage



**Right-Sized
Storage**

Best Value [\$/MG]


Collection System Analysis



Lewiston Sewer Model Review

Identified Inflow Sources

- 262 drain structures connected to sewer
- 41 catch basins scheduled for separation (2019 CWAMP)
- 62 additional structures identified for potential separation
- **Up to 0.6 MG CSO volume reduction**



Lewiston Sewer Model Review

Identified pipes with excess capacity during design event

- Northwood Rd to Jepson Brook (0.07 MG)
- Railroad Park to Cedar St (0.07 MG)
- **Up to 0.14 MG CSO volume reduction**

**Total Collection System Improvements Cost:
\$2.8M; 0.74 MG**



Treatment Plant Optimization





Treatment Plant Optimization


- Hydraulic Capacity
 - Influent Pumps
 - Gravity Hydraulics

- Process Capacity
 - Secondary Clarifiers
 - Other Processes
 - » Flow meters
 - » Influent Screens
 - » Grit
 - » Primary
 - » Chlorine Contact

- Capacity can be increased from 32 MGD to 38 MGD with modest improvements


Influent Pumps

- Three 200 hp pumps
- 32 MGD with two pumps
- Increasing speed achieves 38 MGD
 - ▶ 640 rpm, 186 hp
 - ▶ Still a good operating point
 - ▶ Switch from 12 to 10-pole motors
 - ▶ Increase speed to 63 Hz
- Other options:
 - ▶ Fourth pump (39 MGD)
 - ▶ Parallel FM (37 MGD)
 - ▶ Fourth Pump and Parallel FM (50 MGD)
 - ▶ Larger pumps (45 MGD)




Gravity Hydraulics

- Primary clarifier weir submerges at 36 to 40 MGD
 - Operators observe this occurs at 33 MGD
 - Investigate possible blockage of PE pipe
- Could push the plant to 43 to 47 MGD
 - Scum systems are submerged



Secondary Clarifiers



→ Clarifier operating diagram based on modified state-point equation

Secondary Clarifiers

	Sludge Volume Index (g/mL)		
	100	125	150
Mixed Liquor Concentration (mg/L)	Secondary Clarifier Peak Hour Flow Capacity (MGD)		
1000	49	46	43
1500	42	38	35
2000	35	31	28
2500	29	25	22

→ Process optimization can achieve 38 MGD clarifier capacity

- wet weather contact stabilization
- chemical addition
- selector optimization

→ Capital improvement required for higher flows


- Intensification
- Additional Clarifier



Other Processes

- Influent Flow Meters
 - currently being evaluated
- Influent Screens
 - design underway for new multi-rake screens
- Grit
 - 38 to 76 MGD capacity
- Primary
 - 44 MGD nominal capacity based on surface overflow rate
 - consider baffling or chemical addition
- Chlorine Contact
 - 38 MGD (15 min contact time)
 - 42 MGD (upstream dosing)
 - Increase doses of hypo & bisulfate


Conceptual Plant Upgrade Cost




Right-Sized Storage & Alternatives Analysis

Treatment Plant Capacity vs Storage Size


CSO Volume Required Without Plant or Collection System Improvements: 3.1 MG



Gravity vs. Pump




Conceptual Layout - LAWPCA parcel



Alternatives Evaluated

Scenario	Treatment Plant Capacity	Collection System Improvements	Tank Depth	Pumping	Tank Volume (MG)
1	38	No	Shallow	Required to fill	2.1
2	38	Yes	Shallow	Required to fill	1.75
3	32	Yes	Shallow	Required to fill	2.5
4	32	No	Shallow	Required to fill	3.1
5	38	Yes	Deep	Required to empty	1.75
6	38	No	Deep	Required to empty	2.1
7	32	Yes	Deep	Required to empty	2.5
8	32	No	Deep	Required to empty	3.1


Alternatives Cost Comparison



Conceptual Design & Cost Estimate

Conceptual Design Layout

- DIVERSION STRUCTURE
- WET WELL & PUMP STATION
- VALVE VAULT
- STORAGE CONDUITS
- DRAIN GATES & PIPING
- ELECTRICAL BUILDING & GENERATOR




Opinion of Probable Project Cost

Project Component	Estimated Cost
Storage Conduit & Piping	\$16,370,000
Pump Station & Valve Vault	\$2,980,000
Electrical Building, Equipment, & Site Utilities	\$1,950,000
Treatment Plant Optimization	\$1,400,000
Estimated Total Project Cost	\$22,700,000

Note: Project costs include design, permitting, CA, construction contingency, and Owner's contingency


Next Step - Storage at LAWPCA

Option	Project Cost	Approx. Cost/MG Abated
3.1 MG Deep Storage Tank	\$40+M	\$2M/MG
3.1 MG Shallow Storage Tank	\$31.4M	\$1.6M/MG
2.1 MG Shallow Storage Conduits	\$22.7M	\$1.1M/MG



Conclusion

- Early phases of LTCP attack low-hanging fruit
- Costs per gallon abated only increase
- As the investment gets bigger, more detail is warranted
- **If spending \$1.4M can save \$8.7M, it's worth looking closer**





Contact Info:

Kevin Trainor – ktrainor@woodardcurran.com

Erik Osborn – eosborn@woodardcurran.com

Thank You!