

# Navigating low effluent phosphorus limits: “Right sizing” phosphorus reduction strategies through Monte Carlo based evaluations.

Tom Johnson, PE  
Colin Fitzgerald, PE

# What is an Uncertainty Analysis based evaluation?

- Evaluation of performance **reliability**.
- Understand operational and design associated **risk**.
- To **minimize** over design tendencies.
- To compare **likely** operating cost ranges.



## How is it useful?

- Also referred to as a **Monte Carlo analysis**.
- A statistical technique used to understand the **probability** of observing a given outcome based **uncertain** input parameters
- Static values associated with **uncertain parameters** are replaced with probability distributions.

# Basis of an uncertainty analysis is understanding probability distributions and correlations between parameters.

- Relationship between 30-day average of parameters variables is factored into the randomization of model inputs
- Correlation values  $> 0.2$  or  $< (-0.2)$  are considered significant




Green = positive correlation

Red = negative correlation

	Flow	Peak Flow	COD	TSS	TKN	TP	NH3/TKN	PC TSS	Temp	SVI
Flow	1.00	0.45	0.04	0.09	0.14	0.14	-0.24	-0.05	-0.59	0.26
Peak Flow	0.45	1.00	0.06	0.01	0.03	0.09	-0.17	0.09	-0.22	0.12
COD	0.04	0.06	1.00	0.12	0.19	0.19	-0.09	0.14	0.13	-0.11
TSS	0.09	0.01	0.12	1.00	0.43	0.65	-0.32	0.22	-0.08	-0.14
TKN	0.14	0.03	0.19	0.43	1.00	0.70	-0.24	0.18	-0.10	-0.13
TP	0.14	0.09	0.19	0.65	0.70	1.00	-0.30	0.16	-0.12	-0.02
NH3/TKN	-0.24	-0.17	-0.09	-0.32	-0.24	-0.30	1.00	-0.36	0.40	-0.05
PC TSS	-0.05	0.09	0.14	0.22	0.18	0.16	-0.36	1.00	0.07	-0.07
Temp	-0.59	-0.22	0.13	-0.08	-0.10	-0.12	0.40	0.07	1.00	-0.47
SVI	0.26	0.12	-0.11	-0.14	-0.13	-0.02	-0.05	-0.07	-0.47	1.00

# Common uncertainty analysis applications:

- Process Model
- Process Performance
- Economic



# TMDL based limits drive implementation of uncertainty analysis methods

- New TMDL Based Limits
  - Set 6-month averaging periods (May to October and November to April).
  - Primarily driven by mass, some instances of concentration-based limits
  - TMDL results in more stringent limits for most utilities.
  
- Permits require:
  - Operational evaluations targeting optimization
  - Preliminary and Final Compliance Alternatives Plans identifying paths towards compliance through treatment or alternative approaches
  - Defined implementation schedule

# Case studies implementing the uncertainty analysis method for Low – P planning.

**City of Oshkosh, WI**  
Secondary treatment stability, permit uncertainty, and tertiary sizing.



**NEW Water (Green Bay MSD)**  
Secondary treatment stability, required mass reduction, tertiary sizing.



# Uncertainty analysis drivers for the City of Oshkosh:

- Uncertainty in future effluent limits
  - Waiting completion of Lake Winnebago TMDL
  - Extremely stringent Water Quality Based Effluent Limit (WQBEL) for phosphorus.  
TP = 0.04 mg/L & 6.8 ppd
- Biological vs. Chemical Phosphorus removal stability and life cycle cost
- “Right sized” tertiary treatment alternatives





# City of Oshkosh WWTP


- Flows:
  - 12 mgd average day flow
  - 120 mgd peak hour flow
- Chemical Phosphorus Removal
- Liquids Processes
  - Preliminary and Primary Treatment, Conventional Activated Sludge, Final Clarification, Disinfection
- Solids processes
  - Anaerobic Digestion and Dewatering



# Secondary Treatment Evaluation Goals



Identify	the most stable Bio-P alternative specific to Oshkosh WW characteristics.
Compare	performance of selected Bio-P alternative to the existing Chem-P
Establish	life-cycle cost considerations between alternatives

# MUCT provides the highest stability of the Bio-P processes evaluated




# Uncertainty analysis used to assess stability and life cycle costs

- Simulated 100 dynamic years with unique loading conditions.
- Hydrographs prorated to 2035 design flow 15.7 mgd and paired with loading conditions
- Consistent temperature profile used for all simulations.
- Uncertain Inputs:
  - BOD
  - TP
  - TKN
  - NH<sub>3</sub>/TKN Ratio
  - PO<sub>4</sub>/TP Ratio




# ChemP provides a lower average effluent phosphorus level with more stability


### Chemical P- Removal



### MUCT, Bio-P




# Incorporation of loan payment favors Chemical P with no capital improvements



\*Polishing ferric added to Bio-P alternatives to create equivalent effluent concentrations

# No capital investment for ChemP results in lowest NPV *if* basin improvements are not completed



# City of Oshkosh Conclusions

- Secondary Performance
  - The MUCT process provides the most stable Bio-P alternative.
  - Chem-P does not exhibit seasonal TP increases.
- Economic
  - Bio-P reduces annual operating costs compared to Chem-P
  - Chem-P with no modifications to the aeration basins provides the lowest life cycle cost.
- Results from secondary evaluation fed into tertiary system sizing approach.



## Uncertainty analysis drivers for NEW Water:

- How much phosphorus will we need to remove in 20 years?
- Uncertainty in future performance due to new sidestream loads
- “Right sized” phosphorus management alternatives

The logo for NEW Water is displayed on the side of a large, tan-colored cylindrical water tower. The word "NEW" is in green, and "Water" is in blue with a stylized wave graphic underneath. The tower is part of a larger industrial facility with other structures and pipes visible in the background under a clear blue sky.

NEW Water



# NEW Water's WWTPs

- Bubble Permit for the Green Bay Facility and De Pere Facility.
- TMDL Allocation will be 68 ppd
- Green Bay Facility
  - Average Day Flow = 30 mgd
  - Biological phosphorus removal
- De Pere Facility
  - Average Day Flow = 8 mgd
  - Biological phosphorus removal
  - Tertiary Sand Filtration (w/backup chem)
- Construction of Resource Recovery and Electrical Energy (R2E2) solids process will impact sidestream loading at the Green Bay Facility



# Phosphorus Reduction Plan Goals

1

Understand the likely range of future effluent loads based on historical observations and future conditions

2



Establish an acceptable level of planning level risk to reduce costs, ease operations, and allow flexibility

3

Identify a “No Regrets Plan”

# Effluent Loads projected for both facilities using probability distributions of historical observations


- 9 combinations comprised of:
  - Historical Average performance:
    - DPF = 0.15 mg-P/L & GBF = 0.3 mg-P/L
  - “Optimized” Performance:
    - DPF = 0.1 mg-P/L & GBF = 0.2 mg-P/L
  - Worse Performance:
    - DPF = 0.2 mg-P/L & GBF = 0.4 mg-P/L
- 10-historical hydrographs prorated to 2040 design year.
- Hydrographs combined with performance to create 900 versions of the design year




# Phosphorus reduction alternatives evaluated

- Green Bay Facility Tertiary Treatment
  - Ballasted Flocculation
  - Tertiary Filtration
  - Tertiary Membranes
- De Pere Facility Improvements
  - Cloth Filter Retrofit
  - Tertiary Chemical Addition
- Alternatives Evaluated
  - 12.5 mgd + Watershed
  - 25 mgd Tertiary + Watershed
  - Full tertiary treatment
  - Full adaptive management
  - Water Quality Trading
- Tertiary Capacity size based on acceptable level of risk.


### De Pere Facility



### Green Bay Facility



# Balancing risk, tertiary capacity, and capital cost.



# Defining an acceptable level of “risk”




- Types of “risk”
  - **Interim:** Chance of annual permit violations
  - **Long-term:** Likelihood realizing flow and load projections
- Can the accepted risk be mitigated?
  - **Interim:** Mitigated through provisional methods (i.e. supplemental ferric addition)
  - **Long-term:** Provisions to accommodate infrastructure for the “worst case” scenarios
- Goal: Develop the “No Regrets” Plan

# Acceptable “risk” established as 2 percent exceedance (one out 50 possible design years)

Number of Years Exceeded in 100 Simulations	Percent Exceedance	TP Reduction Req'd (lbs P/yr)	
		Current	Design Year 2040
0	0.0%	12,900	20,700
1	1.0%	12,600	20,300
2	2.0%	11,300	18,800
5	5.0%	11,200	18,700
10	10.0%	10,500	17,700
20	20.0%	9,600	16,800

*Note: 1,500 ppd = 0.05 mg/L at 10 mgd*

# Estimated Annual reductions





# NEW Water Conclusions

- Quantifying the range of future mass loadings allowed for informed decision making based on statistical likelihoods.
- Tertiary sizing optimized by accepting a marginal level of risk that can be mitigated.
- Approach was extended watershed based approaches to aid in watershed selection.
- Preliminary plan compared Watershed only alternatives, treatment only alternatives, and hybrid approaches.



# Understanding Risk allows for the development of a “No Regrets Plan”

- Identify opportunities to reduce initial capital cost or deferment
- Quantifies uncertainty to allow for informed decisions
- Allows flexibility for chose solution to be adapted to future ‘realized’ conditions.



# Acknowledgements

- Phil Mentink, Nate Qualls – NEW Water



- Steve Brand – City of Oshkosh



- Colin Fitzgerald, PE  
Colin.Fitzgerald@jacobs.com



# Questions?

Tom Johnson, PE

[tom.johnson2@jacobs.com](mailto:tom.johnson2@jacobs.com)



Challenging today.  
Reinventing tomorrow.

