

# 2023 Joint NYWEA / NEWEA Spring Conference

## ***Optimizing Secondary Clarifiers - From Conception to Field Testing***



# Agenda

- 1** Overview of FEV, Existing Clarifiers & Challenges
- 2** What To Do?
- 3** Field Verification Testing
- 4** Optimization Modifications
- 5** Lessons Learned
- 6** Questions and Acknowledgements

# Today's Presenters



**Alan Oates, NYS 4A**

Assistant Chief WRRF Operator  
Monroe County



**Hannah Rockwell, PE**

Deputy Project Manager  
Arcadis




**NEWEA**  
WORKING FOR WATER QUALITY

# FEV WRRF

Rochester, NY

- Original construction 1900s, last major upgrade in 1970s
- Combined sewer
- Permitted for 135-mgd through high-rate secondary treatment
- Peak flow through biological treatment of 200-mgd, peak influent of 600-mgd
- Solids retention time 2 to 4 days with anaerobic selectors in plug flow, step feed, or contact stabilization
- Effluent limits:
  - Phosphorus – 1.0 mg/L
  - TSS – 30/45 mg/L; 85% removal
  - SS – 0.3/0.5 mL/L
  - BOD – 30/45 mg/L; 85% removal



SC5 was selected as the Test Clarifier

## Secondary Clarifiers – Existing Conditions

- **Existing Secondary Clarifiers:**
  - Six 145-foot diameter squircles
  - Installed in 1970s - beyond useful life
  - Circular collector mechanism
  - No corner sweeps – corner infills in 1990s
  - 14.5-foot side water depth
  - Cone bottom with slope of 1 to 12-feet
  - Center feed
  - Peripheral effluent
  - Scrappers with draft tubes
  - WAS hopper at center



# Observations of Existing Clarifier Performance

Ten State Standards	FEV WRRF Secondary Clarifiers
Solids Loading Rate (SLR) <i>Less than 40 lbs/day/sf</i>	<b>28 to 31 lbs/day/sf*</b>
Surface Overflow Rate <i>Minimum = 900 gpd/sf</i>	<b>113 mgd</b>
<i>Maximum = 1,200 gpd/sf</i>	<b>150 mgd</b>

## FEV experienced performance challenges:

- NYS DEC issued Consent Order – Jan 2018
- **Consent Order** required improvements to Secondary Clarifiers be **completed by 12/31/2026**

Meet permit at 135 mgd


Performance highly dependent on aeration

Performance challenges at high flow rates

- poorly functioning sludge removal mechanisms
- high sludge blankets
- internal density currents (**temperature changes!**)
- rapid flow changes
- uneven flow resulting from the hybrid square/circle shape

**What to Do?**

# What to Do?





# Project Phasing – Begin with a Test Clarifier

1


- Phase 1**
- Test Clarifier
  - Field Verification Testing
  - Optimization Modifications

2


- Phase 2**
- Remaining Clarifiers
  - MCC Replacement
  - Clarifier Drives

# CFD Model Validation

- 2016 Testing by Clarifier Performance Evaluations, Inc.
  - Velocity Estimates
  - Drogue Results
  - Vertical Solids Profile
  - Influent and Effluent Concentrations
- Refined model with small changes to model parameters that control turbulence levels and solids settlement




*Solids Profile in the Existing FEV Secondary Clarifiers*




*Velocity Profile in the Existing FEV Secondary Clarifiers*

# Inlet Configuration – Sludge Blanket Disturbance

**Existing Condition – 6.4 feet**



**LA-EDI – 2.6 feet**



**3.8-FOOT REDUCTION IN SLUDGE BLANKET DISTURBANCE FROM EXISTING CONDITION**


# Cylindrical Baffle Evaluation

## Existing clarifier:

- Strong density currents
- Upwelling at the sidewalls

## Proposed cylindrical baffle:

- Minimize density currents
- Reduce upwelling




Based on the results of the EDI evaluation, **the LA-EDI was used in the model to evaluate the cylindrical baffle options**

## Evaluation Steps




# Results of CFD Modeling Test Clarifier Design Components

Component		Test Clarifier Design Value
Inlet		LA-EDI
Feedwell	<i>Radius (FT)</i>	21
	<i>Depth (FT)</i>	7.5
	<i>Height (FT)</i>	9.6
Cylindrical Baffle	<i>Radius (FT)</i>	36.25 (½ clarifier radius)
	<i>Floor Gap (FT)</i>	1*
Effluent Weirs		Perimeter Weirs
Corner Launderers		Removed



The cylindrical baffle was designed with the **ability to add an additional 1ft segment** to close the floor gap for testing and optimization purposes.



# Test Clarifier Improvements - Construction

# Field Verification Testing

# Field Verification Testing – Methodology

- Compare Test Clarifier to SC 2
- Identify potential areas for further optimization
- **Over 200 samples collected by staff from MCDES and Arcadis**
- Samples analyzed by MCDES' laboratory for total suspended solids (TSS), dispersed suspended solids (DSS), and flocculated suspended solids (FSS)

## Flow Rates

- Overflow rate maintained at 17-mgd and 22-mgd
- RAS maintained at 8-mgd

## Dye/Flow Curve

- Measured concentration of dye in effluent at time intervals

## Vertical Solids Profiles


- Collected TSS measurements along walkway

## Current Measurements

- Drogue to measure currents

## DSS and FSS

- MLSS → Dispersed SS → Flocculated SS





# Field Verification Testing – Results

## Improvements

- Reduced density currents
- Increased hydraulic efficiency at high flow
- Reduced rate of rotation

## •Continuing Challenges

- Loss of solids in corners
- RAS rate is too low

# Optimization Modifications

**Benefits of Stepwise Approach**



# Improve RAS Rate



Optimization Modifications

# Improve RAS Rate – Draft Tubes and Plow Blades



# Improve RAS Rate - Increase Draft Tube Opening

Increase the size of the openings from the 10 draft tubes (sludge control valves) into the RAS b limit headloss.



# Improve RAS Rate - RAS Pipe Opening


Decrease the turbulence of the RAS entering the RAS pipe

- RAS ports in the influent column were widened
- Height of the RAS box was extended by 6-inches



36" RAS Pipe Opening

Draft Tubes





# Improve Effluent TSS

Optimization Modifications




# Density Current (Stamford) Baffle Installation






**NEWEA**  
WORKING FOR WATER QUALITY

# Cylindrical Baffle Modification




**BEFORE**





**Ortho-P**

**AFTER**



**TSS**



■ SC 2 Average   ■ Test Clarifier   ■ SC 4 Average







Time after  
Test Start

Secondary Clarifier 2  
(Stamford Baffles Installed)

Secondary Clarifier 4  
(Unimproved)

Secondary Clarifier 5  
(Test Clarifier)

20 minutes



40 minutes

# Dye Testing


# Lessons Learned

# What Did We Learn?



Why Optimize and  
What Are The Options

Performance vs Cost – EDIs, Cylindrical  
Baffles, and Stamford Baffles



Why Phase  
Improvements

\$4M Avoided Costs in Phase 2



Benefits of A  
Stepwise Approach

Understand Cause and Effect  
Return on Investment



This project would not have been a success without the contributions from the staff at:

**Monroe County Department  
of Environmental Services  
Monroe County  
Pure Waters  
John Esler with  
Clarifier Performance  
Evaluations, Inc.**



**NEWEA**  
WORKING FOR WATER QUALITY

 **ARCADIS**



## Questions & Discussion



**Alan Oates, NYS 4A**

Assistant Chief WRRF Operator  
Monroe County

[alanoates@monroecounty.gov](mailto:alanoates@monroecounty.gov)



**Hannah Rockwell, PE**

Project Engineer  
Arcadis  
585-662-4056

[hannah.rockwell@arcadis.com](mailto:hannah.rockwell@arcadis.com)