

# Energy Management Basics for WWTFs

---

PAUL CAMPBELL, JKMUUIR

MEGAN COLEMAN, JKMUUIR

# Agenda

---



Drivers for energy and carbon reduction




Strategic planning for energy management



Tools for energy management implementation


# Need for Reduction in Carbon Emissions



Source: Global Carbon Budget Project

- 1.5°C – Ideal limit for global temperature increase
- Most of budget already expended
- Drastic reduction in emissions necessary


# Urgency Around Decarbonization




- Significant reduction in usage across all industries
- Electrical sector has the most progress to make
- Timeframe is short

# Price Map

REAL TIME DAY AHEAD




# Fuel Mix



- 45% NATURAL GAS
  - 21% NUCLEAR
  - 15% OIL
  - 11% RENEWABLES
  - 4% HYDRO
  - 4% COAL
  - <1% OTHER
- 43% WIND
  - 27% REFUSE
  - 24% WOOD
  - 3% LANDFILL GAS
  - 2% SOLAR

# System Demand



15200 FORECASTED (MW)  
14745 ACTUAL (MW)

System Status ● NORMAL

Today's Snapshot  
AS OF 01/23/2022 07:50 AM

**23,014** AVAILABLE CAPACITY (MW)  
**17,450** FORECASTED PEAK DEMAND (MW)  
**3,022** SURPLUS CAPACITY (MW)  
**17,590** YESTERDAY'S PEAK DEMAND (MW)

# Our Responsibility: Energy Management is Carbon Management

---

---

**3%** Water sector's share of global GHG emissions<sup>1</sup>


---

**4%** Water sector's share of US energy use<sup>2</sup>

---


**5 X** Ratio of energy potential in wastewater to energy required for treatment<sup>3</sup>

---



# High Level Principles of Energy + Carbon Management

---



# Using Data to Inform Energy Management Decisions


- Energy management is only as good as the data we have
- Submetering – Real time power data
  - Trend process performance data against real time energy usage data to pinpoint energy intensive equipment
- Assess current energy usage against previous energy usage
- Spot readings from field testing





# Reducing Energy Needs in Water Utilities

- Typical WRRFs can reduce energy use by 15-30%<sup>1</sup>
- Focus on energy intensive processes/equipment
- Turn it off (or turn it down)
- Implement automated process controls
- Properly sized equipment
- Monitor equipment performance to maintain efficiency
- Onsite generation
- Demand response/battery storage



# What is an Energy Evaluation?



Steps	Actionable Items
Understand typical operations	<ul style="list-style-type: none"><li>➤ Understand billing and rates</li><li>➤ Evaluate equipment and process efficiency</li></ul>
Identify ways to save energy	<ul style="list-style-type: none"><li>➤ Identify energy conservation measures/operational changes</li></ul>
Plan for implementation	<ul style="list-style-type: none"><li>➤ Explore energy efficiency funding</li><li>➤ Integrate energy management into capital improvement plans</li></ul>
Integrate into culture	<ul style="list-style-type: none"><li>➤ Involve staff</li><li>➤ Prioritize energy efficient design</li></ul>

# Implement Energy Conservation Programs

---

## Formalize a Plan

- Implement low-cost operational adjustments
- Develop a schedule for improvement upgrades

## Create Accountability

- Designate an energy manager/energy team

## Evaluate Energy Usage Before + After Project Implementation

- Energy monitoring system or field verification
- Follow up with utility/site manager

## Integrate Plant Staff

- Report findings to staff to ensure inclusion and participation in energy management programs

# Understanding How You're Billed

## On Peak and Off Peak Hours

Peak charge is 2X more expensive

## Demand Charge

Demand charge is 22% of the total cost

### DETAIL OF CURRENT CHARGES

#### Delivery Services

	Energy-kWh	Demand-kW	Demand-kVA
Metered Usage	406990 kWh		
Peak	141865 kWh	824.0 kW	860.0 kVA
Off Peak	265125 kWh	852.0 kW	
<b>Billed Usage</b>	<b>406990 kWh</b>	<b>824.0 kW</b>	<b>860.0 kVA</b>
Customer Charge			223.00
Dist Chg On Peak	0.01617199 x 141865 kWh		2,294.23
Dist Chg Off Peak	0.00864199 x 265125 kWh		2,291.22
Transition Charge	0.00034205 x 406990 kWh		139.21
Transmission Charge	0.02111136 x 406990 kWh		8,592.11
Distribution Demand Chg	5.76 x 824 kW/kVA		4,746.24
High Voltage Discount	-0.52 x 824 kW		-428.48
Energy Efficiency Chg	0.00957 x 406990 kWh		3,894.90
Renewable Energy Chg	0.0005 x 406990 kWh		203.50
High Voltage Metering	-1.0 % x \$ 22384.41		-223.84
<b>Total Delivery Services</b>			<b>\$ 21,732.09</b>

# Energy Conservation Measure Opportunities

Operational  
Maintenance (OM)  
Measures  
ECMs/FCMs-  
Capital  
Improvement

ENERGY CONSERVATION MEASURES		Annual Energy Savings (kWh)	Annual GHG Emissions Reduction (MTCO <sub>2e</sub> )	First Year Annual Dollars Saved (\$)	Initial Budgetary Project Cost (\$)	Simple Payback (years)
OM 1	Reduce Cell #1 Anaerobic Mixer Operation	27,173	9.6	\$4,348	-	Immediate
OM 2	Optimize Cell #3 Aerobic Mixer Operation	97,216	34.4	\$15,555	-	Immediate
OM 3	Optimize Primary Sludge Pump Operation	223,161	79.0	\$35,706	-	Immediate
ECM 1	Replace Cell #3 Aerobic Mixers and Optimize Operation	165,364	58.5	\$26,458	\$308,220	11.6
ECM 2	RAS Pump Replacement	101,101	35.7	\$16,176	\$267,800	16.6
ECM 3	Plant Water Replacement	281,999	99.8	\$45,120	\$658,125	14.6
ECM 4	WAS Pump Replacement	48,734	17.2	\$7,797	\$200,200	17.2
ECM 5	Aeration Diffuser Replacement	342,312	121.2	\$54,770	\$450,000	8.2
<b>Potential Energy Program Cost and Savings</b>		<b>1,189,844</b>	<b>421.0</b>	<b>\$190,375</b>	<b>\$1,884,345</b>	<b>9.9</b>
Notes:						
1. OM 2 not included in total savings to avoid double counting the savings associated with ECM 1						

# ECM Case Study: Blower Operation

Blower	Blower Efficiency
1	58%
2	71%
3	66%

**Savings: 500,000 kWh/year = \$90,000**

# Energy Efficiency Incentive Programs

*Funding available for high efficiency equipment and controls for process, HVAC, and lighting equipment*

Pittsfield, MA Nutrient Removal Upgrade: \$200,000

- Mixing equipment, aeration blowers, aeration controls, boilers

South Street Ridgefield, CT Upgrade: \$410,000

- UV controls, process blowers, process pump and blower VFDs, lighting, HVAC

Enfield, CT Upgrades: \$500,000

- Aeration blowers, process pump VFDs, mixing equipment, mixer VFDs





**Rhode Island Energy™**

a PPL company



# Revenue Through Demand Response and Battery Storage

- Clip load during high-cost kWh times and charge from the grid during low-cost kWh times
- Participate in previous demand response programs + additional with more frequent events
- New England Utilities Daily Dispatch Program: \$200 - \$300/kW; up to 60 summer events
- NYSERDA offers upfront commercial storage incentives paired with renewables





# Daily Load Shedding Using Battery Storage


---

Program	Incentive Opportunity
ISO-NE	\$55/kW/year
EnergizeCT	\$200/kW/summer
Connected Solutions	\$200/kW/summer
RI Energy	\$400/kW/summer

# Hartford MDC Demand Response

## Event Performance

Metropolitan District Hartford (MC) | ADCR | 2019-2020 | 06/27/2019




## Revenue

Summer 2018	1,325 kW	\$57,227
Winter 18/19	1,580 kW	\$45,382
Summer 2019	1,941 kW	\$80,101
<b>Total</b>		<b>\$182,711</b>




# Electrification at Water Utilities: lower carbon emissions + drastically increase efficiency (without increasing costs)

### Heating Emission Comparison<sup>1</sup>



<sup>1</sup>From Acadia Center's EnergyVision2030


### Heat Pumps achieve efficiencies of over 400%



- Water source heat pumps can be used to recover/dump heat from/into process stream for heating/cooling spaces
- Air source heat pumps use the heat within outdoor air and can operate down to temperatures of -17°F
- Ground source heat pumps use the heat from underground to heat spaces

# Summary


Energy Savings



Reduce Costs



Create Revenue





Thank You



---

Paul Campbell  
pcampbell@jkmuir.com

Megan Coleman  
mcoleman@jkmuir.com

(860) 249-0989

[JKMuir.com](http://JKMuir.com)