

Innovative New Media with Advanced Deep Bed Primary Filtration Makes Significant Strides

Amit Kaldate, PhD
Tomorrow Water

29 January 2025
Boston, MA

History of Biologically Active Filters (BAF) Development



| | Technology | Media | Flow | Aeration | Application |
|-------|----------------------|------------------------------|------|------------------|---|
| 1950s | Trickling Filter | Rock (sunken) | Down | None (usually) | Secondary, Tertiary |
| 1970s | Flopac™ | Chamotte (sunken) | Down | Pre-filtration | Tertiary |
| 1980s | Biofor®, Biocarbone® | Biolite, Exp. Shale (sunken) | Up | Buried Diffusers | Secondary, Tertiary |
| | Dynasand™ | Sand (sunken) | Up | Airlift Pump | Tertiary |
| | Biostyr® | EPS spherical (float) | Up | Diffusers | Secondary, Tertiary |
| 1990s | BBF™ | EPP ovoid (float) | Up | Diffusers | Secondary, Tertiary |
| 2010s | Proteus™ | EPP cross (float) | Up | Diffusers | Primary, Secondary, Tertiary, Wet Weather |

APPLICATIONS



1. Primary Filtration



2. Wet Weather Flow (WWF) Treatment

3. Secondary BOD Removal

4. Secondary BNR

5. Tertiary Nitrogen Control



6. Split Bed DN & Reuse Polishing



7. Partial deNitrification Anammox (PdNA)



Primary Treatment Technologies

Conventional Primary Treatment

Clarification / Sedimentation




Caliskaner et al, WEFTEC 2023

Advanced Primary Treatment (APT)


- Chemically Enhanced Primary Treatment (CEPT)
- Filtration Technologies
 - Primary Filtration (PF)
 - Primary Biofiltration (PBF)
 - Primary Effluent Filtration (PEF)
- Microscreens
- Rotating Belt Screens/Filters
- Other Emerging Technologies

Primary Treatment Technologies

Conventional Primary Treatment



Advanced Primary Treatment *Filtration*



Adapted from Shewa and Dagnew (2020)

Drivers for Advanced Primary Filtration

Primary Clarifier

Slow - settling *by gravity* force

Controllable ? No. relies on gravity

Range of operation – limited,
<1.5Q

Average settling time: 60 to 90 minutes

Foot print – Large

Advanced Primary Filtration

Fast - filtration *by hydraulic* force

Controllable? Yes. With media size and bed depth

Range of operation – broad,
3-5 Q

Average filtration time: 7 to 15 minutes

*Foot print – smaller,
~20% of clarifier*

WHY ADVANCED PRIMARY FILTRATION?

FILTER PRIMARY SOLIDS
INSTEAD OF SETTLING

Huge 80% Footprint Reduction
Over Primary Clarifiers

CAPTURE MORE TSS

70-90% Removal
Instead of 30-60% in Clarifiers


ALLOWS FOR CARBON DIVERSION

Grab More BOD Upstream of Aeration
& Send To Digestors


10-25% Aeration Energy Reduction
10-25% More Secondary Treatment Capacity
20-30% Increase In Gas Production

Advanced Primary Filtration

Filtration



Periodic Backwash



Two Major Innovations

1. NEW MEDIA

Handles High Solids

Low Head Loss

More Effective Backwash

2. SPLIT-BED AERATION

Oxic on top, Anoxic below

High SSA means intensification



LEGACY MEDIA

Expanded Polypropylene (EPP)

- Long lifespan

Ovoid Shape

GREAT for Tertiary
Biofiltration

New Floating Media

1

50% MORE specific surface area: $2100 \text{ m}^2/\text{m}^3$

- 3x HIGHER than K5 (IFAS)
- 50% > other BAFs

2

High Void Fraction: 0.4~0.5

- Low head loss @ high solids

3

High SS Loading: $>3 \text{ kg}/\text{m}^3$ (216lb/1000 ft³)

- Minimizes backwash rate

4

High O₂ Transfer: SOTE 35-45%

- With only coarse-bubble aeration






5

Made With Expanded Polypropylene

- Cost-effective
- Long lifespan (>35 years)



Process Configurations



PROTEUS FULL-SCALE INSTALLATION

Jungnang WRF
Seoul, Korea

66 MGD
Complete Wastewater
Treatment Process

132 MGD WWF Filter
in parallel with Primary Filter

Commissioned 2017

85%


PRIMARY
TREATMENT
SMALLER

50%

MAIN
TREATMENT
SMALLER

PRIMARY


CONVENTIONAL



Proteus Primary™
Primary Filtration
(No Aeration, No Recycle)
TSS Capture Only

Proteus™-DN/N
DN/O Stage
(Aeration Bisects Media Layer)


Proteus-N™
N Stage (Full Aeration)
Recycle NO_3 to DN stage



JUNGNANG WRF

Seoul, Korea

Museum, Admin & Community Buildings
Constructed On Top of Biofilters



**Chemical P
Removal
(Alum + Filter)**

JUNGNANG WRRF PERFORMANCE DATA

Operating with zero permit violations
over 7 years

Actual HRT: 3.4 Hrs (excluding MDF)

Design HRT: 2.1 Hrs

Data from March-October 2018

| Parameter | | Influent | Permit | BBF Effluent | Plant Effluent |
|-----------|-----|------------|------------|--------------|----------------|
| BOD5 | Ave | 120 | 10 | 9.1 | 1.4 |
| | Max | 192 | | 17 | 3.2 |
| | Min | 42 | | 2.4 | 0.5 |
| SS | Ave | 102 | 10 | 4.9 | 2.5 |
| | Max | 236 | | 11 | 6 |
| | Min | 38 | | 1.5 | 0.4 |
| TN | Ave | 33 | 20 | 15 | 13 |
| | Max | 44 | | 20 | 19 |
| | Min | 8 | | 7 | 6.0 |
| TP | Ave | 3.1 | 0.5 | 1.6 | 0.23 |
| | Max | 4.2 | | 2.6 | 0.56 |
| | Min | 0.8 | | 0.2 | 0.05 |

Wet Weather Flow Treatment Strategies

Traditional

1. Increase Plant Capacity
2. Storage & Equalization
(Tunnels/Interceptor)
Big CAPEX, useless in dry weather,
needs cleaning
Presumes predictability of max flows
3. Divert & Blend
 - Risk violating permit without auxiliary treatment
 - Blending permits may be hard to get

New(er)

1. **Auxiliary High-Rate Treatment**
 - Physical filtration or biological treatment?
 - A lot of infrastructure just for rare WWF events
2. **Dual-Use Systems: The best of both worlds**
 - Provides treatment for dry weather flow
 - Switch feed or ramp up loading rate to manage WWF

1st DUAL-USE INSTALLATION

Seonam WRF, Seoul, Korea

- **95 MGD Primary Filter**

↳ Converts to


- ***190 MGD WWF Filter***

Flow velocity increased

- **Commissioned 2020**




Seonam WRC – 190 MGD (Dual-Use)



SEONAM WRRF



2020 WET WEATHER FILTER PERFORMANCE: Seonam (190 MGD)





| Event | Q (m3/d) | Influent | | Effluent | | Removal Efficiency | |
|----------------|-------------|----------------------------|--------------|----------------------------|--------------|--------------------|-----|
| | | BOD ₅ (mg/L) | SS (mg/L) | BOD ₅ (mg/L) | SS (mg/L) | BOD | SS |
| 1 | 720,000 | 79.8 | 288.0 | 21.6 | 34.8 | 73% | 88% |
| 2 | 720,000 | 102.3 | 242.0 | 20.7 | 32.8 | 80% | 86% |
| 3 | 720,000 | 116.7 | 232.0 | 2.8 | 27.2 | 98% | 88% |
| 4 | 720,000 | 91.5 | 232.0 | 9.2 | 22.0 | 90% | 91% |
| 5 | 720,000 | 84.4 | 222.0 | 20.6 | 11.4 | 76% | 95% |
| 6 | 720,000 | 78.0 | 195.0 | 23.9 | 3.6 | 69% | 98% |
| 7 | 720,000 | 82.8 | 185.0 | 7.5 | 5.4 | 91% | 97% |
| 8 | 720,000 | 79.2 | 164.0 | 23.2 | 3.0 | 71% | 98% |
| 9 | 720,000 | 77.1 | 143.0 | 0.4 | 2.4 | 99% | 98% |
| 10 | 720,000 | 71.1 | 145.0 | 21.8 | 4.1 | 69% | 97% |
| 11 | 720,000 | 78.9 | 111.0 | 22.4 | 5.3 | 72% | 95% |
| 12 | 720,000 | 84.0 | 132.0 | 14.4 | 5.4 | 83% | 96% |
| Average | | 85.5 | 190.9 | 15.7 | 13.1 | 81% | 94% |
| Max | | 116.7 | 288.0 | 23.9 | 34.8 | 99% | 98% |
| Min | | 71.1 | 111.0 | 0.4 | 2.4 | 69% | 86% |



Full-scale Plants – Jungnang (132 MGD) and Seonam (190 MGD)

PROTEUS PERFORMANCE



| Pilot Testing in North America

GCDC, Michigan

April, 2019 - May, 2020: 13 Month



Testing by Plant Lab and outside lab for special tests. Operation by TW (daily) and Plant staff (backup, daily)
Paper at WEFTEC 2020

MMSD, Wisconsin

Jan – June, 2022: 6 Month



Testing by Plant Lab and outside lab for special tests. Operation by Veolia staff (daily) and TW staff (monthly)
Paper at WEFTEC 2023

Additional Pilots

- Bridgeport, CT 2023 (WEFTEC 2024)
- Linda County, CA 2024 (WEFTEC 2024)
- Los Angeles County, CA 2025
- City of Cincinnati, OH 2025 **BAF**


PRIMARY & WWF 13-MONTH PILOT

GENESEE COUNTY MICHIGAN

PHASE 1: Wide range of influents (up to 133gpm), simulate wet weather flows

PHASE 2: Stable performance with dilute Primary Effluent

PLUS: Catch a real wet weather event



3rd Party Reviewer: Dr. Glen Daigger
Paper at WEFTEC 2020

Results Summary


| Removal | Phase 1 (Raw) Influent (mg/L) | Phase 2 (PE) Influent (mg/L) | Primary Filter Removal | | Biological Filter Removal | |
|-----------------|-------------------------------|------------------------------|------------------------|------------------|---------------------------|------------------|
| | | | Raw Water | Primary Effluent | Raw Water | Primary Effluent |
| TSS | 185 | 76 | 78% | 71% | 84% | 84% |
| BOD | 161 | 64 | 69% | 51% | 81% | 60% |
| Total P | 5.1 | 3.2 | 45% | 37% | 54% | 51% |
| Fecal Coliform | 7.5 CFU/mL | 2.3 CFU/mL | 51% | NA | 79% | 45% |
| Chlorine Demand | 0.67 | NA | 70% | NA | 88% | NA |

OPTIMUM VALUES FOR THIS PLANT:



Primary Filter: 15-20 m/hr (5-8 min EBCT)
 Biological Filter: 15-20 min EBCT

Proteus+ Biological Filter

13-Month Pilot
in Michigan



84% TSS removal
Higher removal than
primary filter (78%)




81% BOD Removal
at 15-20min EBCT
in plant influent
60% for PE



2022 Dual-Use Pilot for Milwaukee Metro Sewerage District

- 5-month pilot at South Shore WRF
- Operated by MMSD, validation by Black & Veatch
- Tested Primary and Bio Filter Retrofit Designs
- Tested 6 different SLRs of 0.9-8.7 gpm/sf (equiv. 40 – 572 MGD)
- TSS up to 1200 ppm, plus low-flow slugs
- Shallow bed to fit to hydraulic profile at MMSD SSWRF




Influent vs Effluent during low-flow solids slug




RESULTS: Influent Quality & Flow

Influent TSS





Influent Total COD



| Parameter | Low Flow Period (1/18-3/20) | | Average Flow Period (3/21-6/2) | |
|-------------------|-----------------------------|--------------|--------------------------------|--------------|
| | Average (mg/L) | Range (mg/L) | Average (mg/L) | Range (mg/L) |
| TSS | 328 | 170-1200 | 171 | 93-290 |
| tCOD | 793 | 340-1200 | 416 | 150-1000 |
| cBOD ₅ | 376 | 300-460 | 192 | 95-280 |
| sCOD | 393 | 172-754 | 185 | 77-757 |

RESULTS: Proteus vs Primary Clarifiers

- Proteus outperformed South Shore's primary clarifiers **at all flow rates** for median TSS removal
 - Despite iron salts dosed in primary clarifiers (vs. no chemical dose in Proteus)
- Proteus removal **more consistent than clarifiers**. Removal efficiency decreased only ~10% as SLRs increase



California Energy Commission Project at Linda County Water District, CA



| Overall Treatment Performance ¹ | | | | | |
|--|----------|------|-----------------------|----------|------|
| TSS | | | Total COD | | |
| Avg. Influent | 471 | mg/L | Avg. Influent | 1097 | mg/L |
| Avg. Effluent | 62 | mg/L | Avg. Effluent | 360 | mg/L |
| Removal Efficiency | 85 | % | Removal Efficiency | 65 | % |
| PC Removal Efficiency ² | 62 | % | PC Removal Efficiency | 37 | % |
| VSS/TSS Ratio | Influent | 0.83 | COD/TSS Ratio | Influent | 2.12 |
| | Effluent | 0.74 | | Effluent | 5.77 |
| Carbonaceous BOD | | | Soluble COD | | |
| Avg. Influent | 315 | mg/L | Avg. Influent | 202 | mg/L |
| Avg. Effluent | 186 | mg/L | Avg. Effluent | 206 | mg/L |


¹ Performance under ADF (2gpm/ft²) and media height of 2m is presented in TSS and ~~t~~COD removal efficiency.

² PCs at Linda WWTP are typically operated at surface overflow rates between 400 and 1000 gal/day/ft².


Program Manager: Caliskaner Water Technologies

TSS Removal at Different Media Heights and HLRs

Removal Efficiencies at media height of 2m under different HLRs



Removal Efficiencies at media height of 1.5m under different HLRs



Comparative loading and performance of full-scale plants and pilot plants



| Site | Flow (m ³ /d) | Surface Loading Rate (m ³ /m ² d) | Surface Loading Rate (gpm/sf) | Solids Loading Rate (kg SS/m ³ per cycle) | TSS Removal (Mean) | BOD Removal (Mean) |
|----------------------------------|--------------------------|---|-------------------------------|--|--------------------|--------------------|
| Jungnang Primary | 250,000 | 41-408 | 0.7-8.2 | 0.05—2.12 | 52% | 33% |
| Jungnang WWF *chemicals added | 500,000 | 480 | 8.2 | 4.2 | 87% | 63% |
| Seonam Primary *Larger Media | 360,000 | 250 | 4.3 | 1.3—9.2 | 32% | 25% |
| Seonam WWF *chemicals added | 720,000 | 468 | 8.6 | 1.7—4.0 | 94% | 81% |
| Michigan Primary | 725 | 360—480 | 6.1—8.2 | 1.5—7.3 | 75% | 60% |
| Michigan BEPT | 349 | 144—192 | 2.5—3.3 | | 84% | 81% |
| Milwaukee Primary | 27 | 52—510 | 0.9—8.7 | 1.5—4.3 | 75% | 46% |
| Milwaukee BEPT | 27 | 52—76 | 0.9—1.3 | 1.4—2.3 | 77% | 64% |
| Bridgeport Primary | 119 | 64—867 | 1.1—14.8 | 0.3—13.1 | 69% | 44% |

THANK YOU

Amit Kaldate, PhD

Vice President

ak@tomorrowwater.com

(804) 399-3203

tomorrowwater.com