



WPI




DESIGNING A FEASIBLE AND BENEFICIAL REUSE PROCESS

Jenna O'Connell (CHE), Mary Prescott (EVE), and Meghan Trahan (EVE)


Advisors: John Bergendahl (CEE), Steve Kmiotek (CHE), and Wayne Bates (CEE)

Need for Wastewater Reuse

September 20, 2016




September 13, 2017




<http://droughtmonitor.unl.edu/Home/StateDroughtMonitor.aspx?MA>

Need for Wastewater Reuse



Need for Wastewater Reuse




Drought Conditions across the United States from 1958 to 2007

Regulations Surrounding Wastewater Reuse

MEPA Regulation: 314 CMD 20.00

Permit Number: BRP WP 84



Regulations and Reuse Water Classes

Class A



Class B



Class C



Regulations and Reuse Water Classes

<i>Class A</i>	<p>pH = 6.5-8.5 BOD < 10 mg/l TSS < 5 mg/l Turbidity < average of 2 NTU within a 24-hour period, cannot exceed five NTU more than 5% of the time within a 24-hour period, and cannot exceed ten NTU at anytime Total Nitrogen < 10 mg/l Median of no detectable fecal coliform/100 ml over continuous seven-day sampling periods, not to exceed 14/100 ml in any one sample Other parameters as specified by the Department</p>
<i>Class B</i>	<p>pH = 6.5-8.5 BOD < 30 mg/l TSS < 10 mg/l Total Nitrogen < 10 mg/l Median of 14 detectable fecal coliform/100 ml over continuous 7-day sampling periods, not to exceed 100/100 ml in any one sample Other parameters as specified by the Department</p>
<i>Class C</i>	<p>pH = 6.5-8.5 BOD < 30 mg/l TSS < 30 mg/l Total Nitrogen < 10 mg/l Median of 200 detectable fecal coliform/100 ml Other parameters as specified by the Department</p>

Wheelabrator Technologies

800,000
gallons




Water Use by Type
Cooling Tower
Potable Water
Boiler Water
Fire Suppression


Determining Parameters of Concern

Parameter	Cass A Regulations	Exceedances of Class A Levels
pH	6.5 - 8.5	None
BOD	<10 mg/L	1 exceedance
TSS	<5 mg/L	96 exceedances
Turbidity	< 2 NTU ave; 5 NTU max	None
Total Nitrogen	<10 mg/L	3 exceedances
Fecal Coliform	0/100 mL ave; 14/100 mL max	Always exceeds


Total Suspended Solids: 2015-2016



Fecal Coliform Levels: 2015-2016




Resulting Design





Ultrafiltration Unit

DOW IntegraFlux SFP-2880XP (or equivalent)



Unit Design Specifications

Filtrate Flux: 40 gallons/ft²/day

Flow Rate per Module: 22.4 gpm

Filtration Area (per Module): 829 ft²


Total Unit Area: 25,000 ft²

Number of Units: 31

Unit Operating Conditions

Parameter	Typical	Maximum
Turbidity, NTU	< 50	300
TSS, mg/L	< 50	100
TOC, mg/L	< 10	40
COD, mg/L	< 20	60
Cl ₂ Continuous, mg/L	0.5	200
Oil/Grease, mg/L	0	< 2
pH Continuous	6 to 9	2 to 11
Temperature, °C	25	40
Particle Size (micron)	< 150	300

Ultraviolet Disinfection



UVLW-30800-24 from Evoqua (or equivalent)

Unit Design Specifications

Diameter: 20 inch

Length: 10 ft


Dosage: 80 mJ/cm²

Exposure time: 0.006 seconds

Number of Bulbs, 800 W: 30

Pumping Station

Gorman-Rupp 6"x6" stainless steel self-priming centrifugal pump (or equivalent)



Unit Design Specifications

Max operating pressure: 123 psi

Motor: 50 hp

Size: 6"x6"

Impeller diameter: 12.5"

Darcy-Weisbach Equation


$$h_f = f \frac{Lv^2}{2Dg}$$

Pipe Route

Piping to follow US Route 20

Length: 5,289 feet

Material: HDPE



Piping


Hazen-Williams Equation

$$h_f = \frac{10.44 \times Q^{1.85} \times L}{C^{1.85} \times D^{4.87}}$$

Change in elevation: 139 feet

Pipe Specifications


- 12 inch diameter
- Consistent with current water mains
- Allow for future expansion up to 5 MGD




Recommendations to Ensure Water Quality

- Sampling Station(s)
 - *At both UBWPAD and Wheelabrator*
- Daily reports sent to Wheelabrator
- Wheelabrator maintains Worcester/Millbury Lines
- Sabotage Prevention
 - *Generator*
 - *Security Measures*
- File permit as soon as possible
- Apply for Federal or State grants to aid funding
- Determine payment and maintenance plans


Estimated Cost Analysis



Payback Period



Conclusions



Acknowledgements

We would like to thank the following people for their guidance on this project:

Professors Bergendahl, Kmiotek, and Bates
Mark Johnson, UBWPAD
Wheelabrator Technologies
The Greater Lawrence Sanitary District



WPI

