



# Increasing Removal Efficiency of Primary Settling through Influent Solids Characterization and CFD Modeling

Sean McKelvey, Philadelphia Water Department  
Jacob Metch, HDR  
Hany Gerges, HDR



January 25, 2022



# Project Team



**Jacob Metch, PhD, PE**  
*HDR*



**Sean McKelvey, EIT**  
*Philadelphia Water Department*



**Haney Gerges, PhD, PE**  
*HDR*



**01** Background

**02** Northeast WPCP

**03** Primary Optimization Strategies

**04** Treatment Performance

**05** Field Sampling

**06** CFD Modeling

**07** Next Steps

01

---

**Background**



# Philadelphia Water Department (PWD)

- Municipal government-owned utility
- ~2000 full-time employees
- "One Water" services:
  - Water treatment
  - Wastewater treatment
  - Stormwater management
  - Watershed protection
  - Distribution
  - Conveyance




Image from [goodfreephotos.com](https://www.goodfreephotos.com) (2018)

# PWD Treatment Facilities







- Drinking Water Treatment
  - Baxter WTP
  - Belmont WTP
  - Queen Lane WTP
- Wastewater Treatment
  - Northeast WPCP
  - Southeast WPCP
  - Southwest WPCP
- Pump Stations
  - 12 drinking water
  - 16 wastewater
  - 3 stormwater



# PWD Drainage Districts



## Legend:

-  NEDD (City)
-  NEDD (Suburbs)
-  SEDD (City)
-  SEDD (Suburbs)
-  SWDD (City)
-  SWDD (Suburbs)



# PWD Wastewater Master Plan

- 25-year Master Plan
- 5-year Updates
- Major Activities
  - Data monitoring and analysis
  - Plan for future regulations
  - Integrated asset management
  - Plan for future conditions (e.g., climate change)






02

---

**Northeast WPCP**

# PWD Northeast WPCP

- Combined sewer system (dilute plant influent and high peaking factor )
- Annual average flow of ~160 mgd, Design flow of 210 mgd
- Discharges to Delaware Estuary (i.e., tidal portion)
- Combined heat and power (CHP) facility






# PWD Northeast WPCP Major Needs/Ongoing Projects

- CHP system engine replacement
- Improved nutrient removal
  - Currently nitrifying; potential future low  $\text{NH}_3$  or TN limits
- Peak flow management
  - Backup and flooding of PSTs during high-flow/high-high-tide events
  - Use of high-flow management system



# PWD Northeast WPCP Process Diagram





# PWD Northeast WPCP

- Two sets of primary settling tanks (PSTs)
- Rectangular, chain and flight tanks
- Approximately 50-50 flow split during normal flow
- Flow hydraulically favors PST Set 1 during high flow

|                 | PST Set 1       | PST Set 2                   |
|-----------------|-----------------|-----------------------------|
| Number of Tanks | 8               | 4                           |
| Tank Dimensions | 247 ft by 65 ft | 250 ft by 125 ft            |
| Inlets          | Submerged       | Submerged and non-submerged |



03

---

# Primary Optimization Strategies




# Drivers for Primary Optimization

- Increase solids/organics capture
  - Increase primary treatment capacity
  - Improve wet weather performance
- Increase biogas production (with anaerobic digesters)
- Increase downstream biological process capacity
- Decrease downstream oxygen demand



# Structural Modifications to Improve Performance

- Influent distribution improvements
- Improve solids capture



Flocculation Baffles



Mid-tank Baffles




Sludge Protector Baffles



# Structural Modifications Case Study

- Central Contra Costa Sanitary District, Martinez, CA
- 53.8 MGD Permitted Capacity






04

---


# Treatment Performance

# Treatment Performance


PST Set 1



PST Set 2



# Approach to Primary Settling Optimization






05

---

## **Field Sampling**

# Field Sampling

- Determine settling characteristics of influent solids
  - Settling velocity distribution
  - Influent TSS
  - Non-settleable solids (NSS)
  - Flocculated non-settleable solids (FNSS)
- Used to build CFD model to examine limitations and optimization options



Kemmerer Sampler

# Field Sampling Results



- Storm event occurred the first day of sampling
- Influent TSS lower than historic annual average (~200 mg/L)
- Influent TSS to particulate BOD ratio was approximately 2.0
- Percent NSS of TSS also higher than may be expected
- NSS concentration lower than industry standards (about 40-80 mg/L)
- FNSS lower than NSS indicating potential for improved removal in PSTs

| Analysis                                 | PST Set 1 | PST Set 2 |
|--|-----------|-----------|
| Influent TSS (mg/L)                      | 110       | 115       |
| Non-settleable solids (mg/L)             | 35        | 30        |
| Flocculated non-settleable solids (mg/L) | 26        | 18        |





# Field Sampling Results

- Supernatant TSS plotted vs time allowed to settle
- Used to create settling velocity distribution



# Field Sampling Results

- High percentage of non-settleable solids (0.06 in/min)
- Settling Velocity Distribution used to develop CFD model



06

---


# CFD Modeling




# CFD Modeling: Existing Conditions

- HACM Model and 2DR used
- Assumptions:
  - 280 mgd influent flow
  - Equal split between PST Sets

|                                  | PST Set 1 | PST Set 2 |
|----------------------------------|-----------|-----------|
| Flow per Bay (mgd)               | 4.0       | 5.5       |
| Effluent Suspended Solids (mg/L) | 45        | 80        |




PST Set 1 Existing Conditions




PST Set 2 Existing Conditions

# CFD Modeling: with Structural Modifications

- Model with similar conditions adding baffles
- Increase in solids capture at increased flow



|                                  | PST Set 1 | PST Set 2 |
|----------------------------------|-----------|-----------|
| Flow per Bay (mgd)               | 4.0       | 5.5       |
| Effluent Suspended Solids (mg/L) | 25        | 25        |
| Improved Removal                 | 40%       | 65%       |



# Conclusions & Optimization Recommendations

- Average NSS concentration low compared to a typical PST effluent presenting potential for improving performance.
- Average FNSS lower than NSS indicating that improving flocculation in the PST would yield higher TSS removal efficiencies.
- CFD modeling indicated addition of flocculation, mid-tank and sludge protector baffles has potential to improve performance.
- **It was recommended that PWD considers the addition of these baffles to both sets of PSTs. Planning for demonstration testing is ongoing.**



07

---

**Next Steps**

# Next Steps

- Due to budgetary and contractual constraints, PWD delayed further implementation of baffling at NE WPCP
- Currently planning for a demonstration test (single PST from each set) of baffles in the coming years



# Questions?

Jacob Metch

484.612.1129

[jacob.metch@hdrinc.com](mailto:jacob.metch@hdrinc.com)

Sean McKelvey

215.685.0032

[sean.mckelvey@phila.gov](mailto:sean.mckelvey@phila.gov)

## Acknowledgements

Nafissa Bizo and NEWPCP Operations

Adam Hendricks and Nick Tuttle (PWD Applied Research)

Alex McCorquodale, University of New Orleans (Model Review)

